

Page 1 of 8 This information was generated by the HP KEYMARK database on 18 Dec 2020

Summary of	WPF 35	Reg. N	lo.	0
Certificate Holder				
Name	STIEBEL ELTRON GmbH & Co K	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip		37603
City	Holzminden	Count	ry	Germany
Certification Body	DIN CERTCO Gesellschaft für Ko	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPF 35			
Heat Pump Type	Brine/Water			
Refrigerant	R410a			
Mass Of Refrigerant	10 kg	10 kg		
Certification Date	19.09.2016	19.09.2016		

# Model: WPF 35

General Data		
Power supply	3x400V 50Hz	

## Heating

EN 14511-4		
Chutting off the heat transfer medium flour	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	37.70 kW	34.49 kW	
El input	7.98 kW	11.47 kW	
СОР	4.72	3.01	
Indoor water flow rate	4.48 m³/h	4.48 m³/h	

### Average Climate



 $$\operatorname{\textit{Page}}\ 3$$  of 8 This information was generated by the HP KEYMARK database on 18 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	60 dB(A)	60 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	200 %	133 %
Prated	38.00 kW	34.00 kW
SCOP	5.19	3.52
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	38.10 kW	34.50 kW
COP Tj = -7°C	4.84	2.95
Pdh Tj = +2°C	38.60 kW	35.80 kW
COP Tj = +2°C	5.20	3.50
Pdh Tj = $+7^{\circ}$ C	39.00 kW	36.70 kW
COP Tj = +7°C	5.56	2.92
Pdh Tj = 12°C	39.30 kW	37.50 kW
COP Tj = 12°C	5.96	4.42
Pdh Tj = Tbiv	38.00 kW	34.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was genera	ted by the HP KEYMAR	KK database on 18 Dec 2020
COP Tj = Tbiv	4.75	2.82
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	38.00 kW	34.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.78	2.82
Rated airflow rate	0 m³/h	0 m³/h
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	o w
РТО	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

#### Warmer Climate

Annual energy consumption Qhe

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	60 dB(A)	60 dB(A)	
Sound power level outdoor	60 dB(A)	60 dB(A)	

15136 kWh

20029 kWh

EN 1482	25	
	Low temperature	Medium temperature





 $$\operatorname{\textit{Page}}\xspace\:5\:\:of\:\:8\:$  This information was generated by the HP KEYMARK database on 18 Dec 2020

$\eta_{s}$	199 %	132 %
Prated	38.00 kW	34.00 kW
SCOP	5.17	3.50
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = $-7$ °C	0.00 kW	0.00 kW
COP Tj = $-7$ °C	0.00	0.00
Pdh Tj = $+2$ °C	38.00 kW	34.10 kW
$COP Tj = +2^{\circ}C$	4.78	2.82
Pdh Tj = $+7^{\circ}$ C	38.50 kW	35.20 kW
$COP Tj = +7^{\circ}C$	5.12	3.24
Pdh Tj = 12°C	39.10 kW	37.00 kW
COP Tj = 12°C	5.69	4.08
Pdh Tj = Tbiv	38.00 kW	34.10 kW
COP Tj = Tbiv	4.78	2.82
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	38.00 kW	34.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.78	2.82
Rated airflow rate	0 m³/h	0 m³/h
Cdh	0.90	0.90
WTOL	60 °C	60 °C






Poff 0 W 0 W 7 W PTO 7 W **PSB** 7 W 7 W **PCK** 7 W 74 W Supplementary Heater: Type of energy input electricity electricity 0.00 kW 0.00 kW Supplementary Heater: PSUP Annual energy consumption Qhe 9834 kWh 13033 kWh

#### Colder Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	60 dB(A)	60 dB(A)	
Sound power level outdoor	60 dB(A)	60 dB(A)	

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	208 %	139 %
Prated	47.00 kW	43.00 kW
SCOP	5.41	3.66
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C





Pdh $Tj = -7$ °C	38.80 kW	35.80 kW
$COP Tj = -7^{\circ}C$	5.38	3.48
Pdh Tj = $+2$ °C	39.10 kW	36.70 kW
COP Tj = +2°C	5.67	3.91
Pdh Tj = $+7^{\circ}$ C	39.30 kW	37.40 kW
$COPTj = +7^{\circ}C$	5.90	4.32
Pdh Tj = 12°C	39.30 kW	37.90 kW
COP Tj = 12°C	5.94	4.66
Pdh Tj = Tbiv	38.60 kW	35.30 kW
COP Tj = Tbiv	5.26	3.25
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	38.60 kW	34.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.26	2.82
Rated airflow rate	0 m³/h	0 m³/h
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	o w	0 W
РТО	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	9.32 kW	9.15 kW



 $$\operatorname{\textit{Page}}$8$  of 8 This information was generated by the HP KEYMARK database on 18 Dec 2020