

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	JAMA Star-6	Reg. No.	012-SC0657-18
Certificate Holder			
Name	Kaukora		
Address	Tuotekatu 11	Zip	FI-21200
City	Raisio	Country	Finland
Certification Body	RISE CERT		
Subtype title	JAMA Star-6		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass of Refrigerant	1.5 kg		

## Model: Star-6

Configure model	
Model name	Star-6
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.10 kW	4.56 kW
El input	1.35 kW	1.50 kW
COP	4.52	3.04

### Colder Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	190 %	141 %
Prated	7.00 kW	6.00 kW
SCOP	4.95	3.73
Tbiv	-18 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	6.40 kW	5.20 kW
COP Tj = -7°C	4.96	3.58
Pdh Tj = +2°C	6.50 kW	5.60 kW
COP Tj = +2°C	5.10	3.96
Pdh Tj = +7°C	6.60 kW	5.90 kW
COP Tj = +7°C	5.18	4.25
Pdh Tj = 12°C	6.60 kW	6.10 kW
COP Tj = 12°C	4.97	4.33
Pdh Tj = Tbiv	6.20 kW	4.90 kW
COP Tj = Tbiv	4.75	3.32

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	6.10 kW	4.50 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.59	2.96
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.99	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	12 W	10 W
PSB	7 W	7 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.50 kW
Annual energy consumption $Q_{he}$	3487 kWh	3969 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	43 dB(A)	43 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	184 %	137 %
Prated	7.00 kW	6.00 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

SCOP	4.80	3.63
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	4.80 kW
COP Tj = -7°C	4.71	3.18
Pdh Tj = +2°C	6.30 kW	5.30 kW
COP Tj = +2°C	4.91	3.69
Pdh Tj = +7°C	6.50 kW	5.60 kW
COP Tj = +7°C	5.09	4.02
Pdh Tj = 12°C	6.70 kW	6.00 kW
COP Tj = 12°C	5.14	4.29
Pdh Tj = Tbiv	6.20 kW	4.90 kW
COP Tj = Tbiv	4.71	3.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.10 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.59	2.96
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	1 W	2 W
PTO	12 W	10 W
PSB	7 W	7 W
PCK	14 W	14 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.50 kW
Annual energy consumption Q <sub>he</sub>	3010 kWh	3425 kWh

## Model: Star-6 RST

Configure model	
Model name	Star-6 RST
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Off-peak product	No

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.10 kW	4.56 kW
El input	1.35 kW	1.50 kW
COP	4.52	3.04

### Colder Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	190 %	141 %
Prated	7.00 kW	6.00 kW
SCOP	4.95	3.73
Tbiv	-18 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	6.40 kW	5.20 kW
COP Tj = -7°C	4.96	3.58
Pdh Tj = +2°C	6.50 kW	5.60 kW
COP Tj = +2°C	5.10	3.96
Pdh Tj = +7°C	6.60 kW	5.90 kW
COP Tj = +7°C	5.18	4.25
Pdh Tj = 12°C	6.60 kW	6.10 kW
COP Tj = 12°C	4.97	4.33
Pdh Tj = Tbiv	6.20 kW	4.90 kW
COP Tj = Tbiv	4.75	3.32



This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	6.10 kW	4.50 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.59	2.96
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.99	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	12 W	10 W
PSB	7 W	7 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.50 kW
Annual energy consumption $Q_{he}$	3487 kWh	3969 kWh

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	43 dB(A)	43 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	184 %	137 %
Prated	7.00 kW	6.00 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

SCOP	4.80	3.63
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	4.80 kW
COP Tj = -7°C	4.71	3.18
Pdh Tj = +2°C	6.30 kW	5.30 kW
COP Tj = +2°C	4.91	3.69
Pdh Tj = +7°C	6.50 kW	5.60 kW
COP Tj = +7°C	5.09	4.02
Pdh Tj = 12°C	6.70 kW	6.00 kW
COP Tj = 12°C	5.14	4.29
Pdh Tj = Tbiv	6.20 kW	4.90 kW
COP Tj = Tbiv	4.71	3.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.10 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.59	2.96
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	1 W	2 W
PTO	12 W	10 W
PSB	7 W	7 W
PCK	14 W	14 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.50 kW
Annual energy consumption Q <sub>he</sub>	3010 kWh	3425 kWh

## Domestic Hot Water (DHW)

### Colder Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	98 %
COP	2.45
Heating up time	2:45 h:min
Standby power input	55.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	240 l

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	98 %
COP	2.45
Heating up time	2:45 h:min
Standby power input	55.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	240 l