

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	HPA-O 13 S Premium, HPA-O 13 CS Premium		Reg. No.	011-1W0231
Certificate Holder				
Name	STIEBEL ELTRON GmbH & Co KG			
Address	Dr. Stiebel Straße 33		Zip	37603
City	Holzminden		Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Name of testing laboratory	VDE Prüf- und Zertifizierungsinstitut GmbH			
Subtype title	HPA-O 13 S Premium, HPA-O 13 CS Premium			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	Other			
Mass Of Refrigerant	4.7 kg			
Certification Date	08.01.2018			

Model: HPA-O 13 S Premium

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	8.00 kW	7.52 kW
El input	1.66 kW	2.33 kW
COP	4.82	3.23
Indoor water flow rate	1.36 m ³ /h	0.81 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_s	173 %	136 %
Prated	15.00 kW	15.00 kW
SCOP	4.39	3.47
Tbiv	-5 °C	-5 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.00 kW	13.80 kW
COP Tj = -7°C	3.02	2.43
Cdh	0.90	0.90
Pdh Tj = +2°C	8.00 kW	7.70 kW
COP Tj = +2°C	4.40	3.37
Cdh	0.90	0.90
Pdh Tj = +7°C	8.10 kW	7.90 kW
COP Tj = +7°C	5.64	4.45
Cdh	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.66
Cdh	0.90	0.90
Pdh Tj = Tbiv	11.80 kW	12.40 kW
COP Tj = Tbiv	3.18	2.53

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	12.60 kW	13.40 kW
COP Tj = TOL	2.87	2.28
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	7055 kWh	8940 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	206 %	155 %
Prated	8.00 kW	7.00 kW
SCOP	5.21	3.95
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.90 kW	7.40 kW
COP Tj = +2°C	3.89	2.59

This information was generated by the HP KEYMARK database on 17 Dec 2020

Cdh	0.90	0.90
Pdh Tj = +7°C	8.10 kW	7.70 kW
COP Tj = +7°C	5.10	3.60
Cdh	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.90 kW	7.40 kW
COP Tj = Tbiv	3.89	2.59
Pdh Tj = TOL	17.60 kW	19.80 kW
COP Tj = TOL	2.72	2.29
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2050 kWh	2367 kWh

Colder Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_s	153 %	126 %
Prated	21.00 kW	22.00 kW
SCOP	3.89	3.23
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	12.80 kW	13.50 kW
COP Tj = -7°C	3.21	2.65
Cdh	0.90	0.90
Pdh Tj = +2°C	8.10 kW	7.90 kW
COP Tj = +2°C	4.75	3.75
Cdh	0.90	0.90
Pdh Tj = +7°C	8.20 kW	8.00 kW
COP Tj = +7°C	5.95	4.86
Cdh	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.95
Cdh	0.90	0.90
Pdh Tj = Tbiv	12.80 kW	13.50 kW
COP Tj = Tbiv	3.21	2.65

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	17.40 kW	19.30 kW
COP Tj = TOL	2.80	2.38
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	21.17 kW	22.26 kW
Annual energy consumption Qhe	13312 kWh	16814 kWh
Pdh Tj = -15°C (if TOL<-20°C)	17.40	19.30
COP Tj = -15°C (if TOL<-20°C)	2.80	2.38
Cdh	0.90	0.90

Model: HPA-O 13 CS Premium

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	8.00 kW	7.52 kW
El input	1.66 kW	2.33 kW
COP	4.82	3.23
Indoor water flow rate	1.36 m ³ /h	0.81 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_s	178 %	139 %
Prated	15.00 kW	15.00 kW
SCOP	4.53	3.55
Tbiv	-5 °C	-5 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.00 kW	13.80 kW
COP Tj = -7°C	3.02	2.43
Cdh	0.90	0.90
Pdh Tj = +2°C	8.00 kW	7.70 kW
COP Tj = +2°C	4.40	3.37
Cdh	0.90	0.90
Pdh Tj = +7°C	8.10 kW	7.90 kW
COP Tj = +7°C	5.64	4.45
Cdh	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.66
Cdh	0.90	0.90
Pdh Tj = Tbiv	11.80 kW	12.40 kW
COP Tj = Tbiv	3.18	2.53

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	12.60 kW	13.40 kW
COP Tj = TOL	2.87	2.28
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6839 kWh	8723 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	236 %	174 %
Prated	8.00 kW	7.00 kW
SCOP	5.97	4.44
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.90 kW	7.40 kW
COP Tj = +2°C	3.89	2.59

This information was generated by the HP KEYMARK database on 17 Dec 2020

Cdh	0.90	0.90
Pdh Tj = +7°C	8.10 kW	7.70 kW
COP Tj = +7°C	5.10	3.60
Cdh	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.90 kW	7.40 kW
COP Tj = Tbiv	3.89	2.59
Pdh Tj = TOL	17.60 kW	19.80 kW
COP Tj = TOL	2.72	2.29
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1789 kWh	2107 kWh

Colder Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_s	154 %	137 %
Prated	21.00 kW	22.00 kW
SCOP	3.93	3.25
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	12.80 kW	13.50 kW
COP Tj = -7°C	3.21	2.65
Cdh	0.90	0.90
Pdh Tj = +2°C	8.10 kW	7.90 kW
COP Tj = +2°C	4.75	3.75
Cdh	0.90	0.90
Pdh Tj = +7°C	8.20 kW	8.00 kW
COP Tj = +7°C	5.95	4.86
Cdh	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.95
Cdh	0.90	0.90
Pdh Tj = Tbiv	12.80 kW	13.50 kW
COP Tj = Tbiv	3.21	2.65

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	17.40 kW	19.30 kW
COP Tj = TOL	2.80	2.38
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	21.17 kW	22.26 kW
Annual energy consumption Qhe	13182 kWh	16684 kWh
Pdh Tj = -15°C (if TOL<-20°C)	17.40	19.30
COP Tj = -15°C (if TOL<-20°C)	2.80	2.38
Cdh	0.90	0.90