

This information was generated by the HP KEYMARK database on 21 Jan 2021

Summary of	WPF 20	Reg. No.	011-1W0275
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPF 20		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	5.99 kg		
Certification Date	24.01.2019		

Model: WPF 20

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	21.50 kW	20.10 kW
El input	4.61 kW	7.08 kW
COP	4.66	3.16
Indoor water flow rate	3.65 m ³ /h	2.65 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 21 Jan 2021

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	59 dB(A)	59 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	192 %	131 %
Prated	22.00 kW	20.00 kW
SCOP	5.00	3.48
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	21.50 kW	20.20 kW
COP Tj = -7°C	4.72	2.96
Pdh Tj = +2°C	21.70 kW	20.70 kW
COP Tj = +2°C	5.06	3.48
Pdh Tj = +7°C	21.80 kW	21.00 kW
COP Tj = +7°C	5.41	3.88
Pdh Tj = 12°C	22.00 kW	21.30 kW
COP Tj = 12°C	5.80	4.36
Pdh Tj = Tbiv	21.50 kW	20.10 kW

This information was generated by the HP KEYMARK database on 21 Jan 2021

COP $T_j = T_{biv}$	4.66	2.84
P _{dh} $T_j = TOL$ or P _{dh} $T_j = T_{designh}$ if $TOL < T_{designh}$	21.50 kW	20.10 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	4.66	2.84
C _{dh}	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	8904 kWh	11988 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	59 dB(A)	59 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 21 Jan 2021

η_s	188 %	128 %
Prated	22.00 kW	20.00 kW
SCOP	4.90	3.40
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	21.50 kW	20.10 kW
COP Tj = +2°C	4.66	2.84
Pdh Tj = +7°C	21.70 kW	20.50 kW
COP Tj = +7°C	4.99	3.24
Pdh Tj = 12°C	21.90 kW	21.10 kW
COP Tj = 12°C	5.54	4.03
Pdh Tj = Tbiv	21.50 kW	20.10 kW
COP Tj = Tbiv	4.66	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	21.50 kW	20.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.66	2.84
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W

This information was generated by the HP KEYMARK database on 21 Jan 2021

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	5871 kWh	7884 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	59 dB(A)	59 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	201 %	137 %
Prated	27.00 kW	25.00 kW
SCOP	5.23	3.62
T _{biv}	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = -7°C	21.80 kW	20.70 kW
COP T _j = -7°C	5.24	3.46
P _{dh} T _j = +2°C	21.90 kW	21.00 kW
COP T _j = +2°C	5.51	3.87

This information was generated by the HP KEYMARK database on 21 Jan 2021

Pdh Tj = +7°C	21.90 kW	21.30 kW
COP Tj = +7°C	5.74	4.26
Pdh Tj = 12°C	22.00 kW	21.50 kW
COP Tj = 12°C	5.78	4.60
Pdh Tj = Tbiv	21.70 kW	20.50 kW
COP Tj = Tbiv	5.12	3.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	21.50 kW	21.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.66	2.84
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	5.11 kW	5.05 kW
Annual energy consumption Qhe	12535 kWh	17067 kWh