

This information was generated by the HP KEYMARK database on 21 Jun 2022

[Login](#)

Summary of	THERMOR Alféa Excellia A.I. Tri size 11	Reg. No.	012-SC0219-19
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	THERMOR Alféa Excellia A.I. Tri size 11		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	05.06.2019		

Model: THERMOR Alféa Excellia Duo A.I. Tri 11

Configure model	
Model name	THERMOR Alféa Excellia Duo A.I. Tri 11
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.80 kW	9.29 kW
El input	2.51 kW	3.52 kW
COP	4.30	2.64

Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	154 %	112 %
Prated	11.00 kW	9.00 kW
SCOP	3.92	2.87
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.70	1.90
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.70
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.50	3.90
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	7.10	5.20
Pdh Tj = Tbiv	10.00 kW	8.20 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP $T_j = T_{biv}$	2.70	1.90
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	9.90 kW	8.10 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	44 W	32 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.20 kW
Annual energy consumption Q_{he}	5930 kWh	6669 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	88 %
COP	2.30
Heating up time	0:46 h:min
Standby power input	40.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	250 l

Model: THERMOR Alféa Excellia A.I. Tri 11

Configure model	
Model name	THERMOR Alféa Excellia A.I. Tri 11
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.80 kW	9.29 kW
El input	2.51 kW	3.52 kW
COP	4.30	2.64

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	154 %	112 %
Prated	11.00 kW	9.00 kW
SCOP	3.92	2.87
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.70	1.90
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.70
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.50	3.90
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	7.10	5.20
Pdh Tj = Tbiv	10.00 kW	8.20 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP $T_j = T_{biv}$	2.70	1.90
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	9.90 kW	8.10 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	44 W	32 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.20 kW
Annual energy consumption Q_{he}	5930 kWh	6669 kWh