This information was generated by the HP KEYMARK database on 13 Apr 2022

Login

Summary of	AQUATOP S06	Reg. No.	011-1W0304
Certificate Holder			
Name	ELCO GmbH		
Address	Hohenzollernstrasse 31	Zip	72379
City	Hechingen	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	AQUATOP S06		
Heat Pump Type	Brine/Water and Water/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.9 kg		
Certification Date	04.05.2019		

Model: AQUATOP S06

Configure model	
Model name	AQUATOP S06
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Brine/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Medium temperature	**Low temperature**
Heat output	5.59 kW	4.85 kW
El input	1.22 kW	1.86 kW
COP	4.58	2.61

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	189 %	137 %
Prated	6.00 kW	5.00 kW
SCOP	4.93	3.64
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.84 kW	5.35 kW
COP Tj = -7°C	4.47	2.79
Pdh Tj = +2°C	5.96 kW	5.61 kW
COP Tj = +2°C	5.00	3.65
Pdh Tj = +7°C	6.02 kW	5.77 kW
COP Tj = +7°C	5.39	4.27
Pdh Tj = 12°C	6.13 kW	5.98 kW
COP Tj = 12°C	5.79	5.02
Pdh Tj = Tbiv	5.79 kW	5.25 kW
COP Tj = Tbiv	4.39	2.59

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.79 kW	5.25 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.39	2.59
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	2426 kWh	2983 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	191 %	137 %
Prated	6.00 kW	5.00 kW

SCOP	4.97	3.63
Tbiv	2 °C	2 °C
TOL	-22 °C	-22 °C
Pdh Tj = +2°C	5.79 kW	5.25 kW
COP Tj = +2°C	4.39	2.57
Pdh Tj = +7°C	5.90 kW	5.51 kW
COP Tj = +7°C	5.53	3.26
Pdh Tj = 12°C	6.07 kW	5.88 kW
COP Tj = 12°C	5.53	4.48
Pdh Tj = Tbiv	5.79 kW	5.25 kW
COP Tj = Tbiv	4.39	2.59
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.79 kW	5.25 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.39	2.59
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW

Annual energy consumption Qhe	1556 kWh	1931 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	195 %	142 %
Prated	6.00 kW	5.00 kW
SCOP	5.08	3.75
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.40 kW	5.56 kW
COP Tj = -7°C	5.00	3.44
Pdh Tj = +2°C	5.46 kW	5.77 kW
COP Tj = +2°C	5.39	4.16
Pdh Tj = +7°C	5.51 kW	5.93 kW
COP Tj = +7°C	5.66	4.76
Pdh Tj = 12°C	5.56 kW	6.03 kW

COP Tj = 12°C	5.79	5.25
Pdh Tj = Tbiv	5.79 kW	5.25 kW
COP Tj = Tbiv	4.39	2.59
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.79 kW	5.25 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.39	2.59
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	2812 kWh	3453 kWh

Water/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.67 kW	6.07 kW
El input	1.19 kW	1.79 kW
COP	5.61	3.39

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	243 %	182 %
Prated	7.00 kW	6.00 kW

SCOP	6.28	6.00
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	6.73 kW	6.19 kW
COP Tj = -7°C	5.71	3.65
Pdh Tj = +2°C	6.87 kW	6.49 kW
COP Tj = +2°C	6.39	4.78
Pdh Tj = +7°C	6.93 kW	6.67 kW
COP Tj = +7°C	6.89	5.59
Pdh Tj = 12°C	7.06 kW	6.91 kW
COP Tj = 12°C	7.40	6.57
Pdh Tj = Tbiv	6.67 kW	6.07 kW
COP Tj = Tbiv	5.61	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.67 kW	6.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.61	3.39
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	2193 kWh	2645 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	245 %	182 %
Prated	7.00 kW	6.00 kW
SCOP	6.32	4.74
Tbiv	2 °C	2 °C
TOL	-22 °C	-22 °C
Pdh Tj = +2°C	6.67 kW	6.07 kW
COP Tj = +2°C	5.61	3.39
Pdh Tj = +7°C	6.80 kW	6.37 kW
COP Tj = +7°C	6.22	4.27
Pdh Tj = 12°C	6.99 kW	6.80 kW

COP Tj = 12°C	7.07	5.86
Pdh Tj = Tbiv	6.67 kW	6.07 kW
COP Tj = Tbiv	5.61	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.67 kW	6.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.61	3.39
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	1409 kWh	1711 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	39 dB(A)	39 dB(A)

EN 14825

	Low temperature	**Medium temperature**
η_s	250 %	188 %
Prated	7.00 kW	6.00 kW
SCOP	6.46	4.89
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	6.22 kW	6.43 kW
COP Tj = -7°C	6.39	4.50
Pdh Tj = +2°C	4.29 kW	6.67 kW
COP Tj = +2°C	6.89	5.44
Pdh Tj = +7°C	6.35 kW	6.86 kW
COP Tj = +7°C	7.23	6.23
Pdh Tj = 12°C	6.41 kW	6.97 kW
COP Tj = 12°C	7.40	6.87
Pdh Tj = Tbiv	6.67 kW	6.07 kW
COP Tj = Tbiv	5.61	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.67 kW	6.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.61	3.39
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	65 °C	65 °C
Poff	0 W	0 W

PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	2544 kWh	3059 kWh