

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	IDEAL HEATING Alféa Excellia A.I. 11	Reg. No.	012-SC0136-19
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	IDEAL HEATING Alféa Excellia A.I. 11		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	04.04.2020		

# Model: IDEAL HEATING Alféa Excellia A.I. 11

Configure model	
Model name	IDEAL HEATING Alféa Excellia A.I. 11
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.80 kW	7.59 kW
El input	2.54 kW	3.07 kW
COP	4.25	2.47

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	151 %	112 %
Prated	11.00 kW	9.00 kW
SCOP	3.85	2.87
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.60	1.90
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.80
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.30	3.80
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	6.90	4.80
Pdh Tj = Tbiv	10.00 kW	8.20 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.60	1.90
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.00 kW	8.00 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.20	1.70
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P <sub>off</sub>	8 W	8 W
PTO	45 W	22 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.30 kW	1.30 kW
Annual energy consumption $Q_{he}$	6062 kWh	6623 kWh