

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	TTL 3.5 ACS	Reg. No.	011-1W0116
Certificate Holder			
Name	tecalor GmbH		
Address	Fürstenbergerstr. 77	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TTL 3.5 ACS		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.1 kg		
Certification Date	19.01.2017		

# Model: TTL 3.5 ACS + HSBB 200 classic, HSBB 200 S classic

Configure model	
Model name	TTL 3.5 ACS + HSBB 200 classic, HSBB 200 S classic
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Average Climate

EN 14825		
	Low temperature	Medium temperature
$\eta_s$	166 %	116 %
Prated	3.62 kW	3.83 kW
SCOP	4.22	2.96
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-7 °C
Pdh Tj = -7°C	3.20 kW	2.79 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	1.95 kW	2.01 kW
COP Tj = +2°C	4.11	2.94

This information was generated by the HP KEYMARK database on 18 Mar 2022

Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.59 kW	1.25 kW
COP Tj = +7°C	5.81	4.13
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.66 kW	1.54 kW
COP Tj = 12°C	6.34	5.13
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.20 kW	3.09 kW
COP Tj = Tbiv	2.88	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.04 kW	2.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	2.01
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	30 W	30 W
PSB	17 W	17 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	3.83 kW
Annual energy consumption Qhe	1771 kWh	2672 kWh

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

## Heating

<b>EN 14511-4</b>	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	2.27 kW	1.92 kW
El input	0.50 kW	0.74 kW
COP	4.54	2.59

## Domestic Hot Water (DHW)

## Average Climate

<b>EN 16147</b>	
Mixed water at 40°C	245 l
Declared load profile	L
Efficiency $\eta_{DHW}$	113 %
COP	2.70
Heating up time	1:50 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C

## Model: TTL 3.5 ACS

Configure model	
Model name	TTL 3.5 ACS
Application	Heating (low temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

### Average Climate

EN 12102-1	
	Low temperature
Sound power level indoor	0 dB(A)
Sound power level outdoor	52 dB(A)

EN 14825	
	Low temperature
$\eta_s$	166 %
Prated	3.62 kW
SCOP	4.22
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	3.20 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = -7°C	2.88
Cdh Tj = -7 °C	0.900
Pdh Tj = +2°C	1.95 kW
COP Tj = +2°C	4.11
Cdh Tj = +2 °C	0.900
Pdh Tj = +7°C	1.59 kW
COP Tj = +7°C	5.81
Cdh Tj = +7 °C	0.900
Pdh Tj = 12°C	1.66 kW
COP Tj = 12°C	6.34
Cdh Tj = +12 °C	0.900
Pdh Tj = Tbiv	3.20 kW
COP Tj = Tbiv	2.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.07
Rated airflow rate	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900
WTOL	60 °C
Poff	17 W
PTO	30 W
PSB	17 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PCK	5 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.58 kW
Annual energy consumption Q <sub>he</sub>	1771 kWh

## Warmer Climate

<b>EN 12102-1</b>	
	<b>Low temperature</b>
Sound power level indoor	0 dB(A)
Sound power level outdoor	52 dB(A)

<b>EN 14825</b>	
	<b>Low temperature</b>
$\eta_s$	200 %
Prated	3.00 kW
SCOP	5.07
T <sub>biv</sub>	2 °C
TOL	2 °C
P <sub>dh</sub> T <sub>j</sub> = -7°C	0.00 kW
COP T <sub>j</sub> = -7°C	0.00
P <sub>dh</sub> T <sub>j</sub> = +2°C	3.04 kW



This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = +2°C	3.39
Cdh Tj = +2 °C	0.900
Pdh Tj = +7°C	1.95 kW
COP Tj = +7°C	5.18
Cdh Tj = +7 °C	0.900
Pdh Tj = 12°C	1.63 kW
COP Tj = 12°C	6.14
Cdh Tj = +12 °C	0.900
Pdh Tj = Tbiv	3.04 kW
COP Tj = Tbiv	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.04 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.39
Rated airflow rate	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900
WTOL	60 °C
Poff	17 W
PTO	30 W
PSB	17 W
PCK	5 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW

Annual energy consumption $Q_{he}$	791 kWh
------------------------------------	---------

## Colder Climate

<b>EN 12102-1</b>	
	<b>Low temperature</b>
Sound power level indoor	0 dB(A)
Sound power level outdoor	52 dB(A)

<b>EN 14825</b>	
	<b>Low temperature</b>
$\eta_s$	148 %
Prated	3.38 kW
SCOP	3.77
Tbiv	-15 °C
TOL	-20 °C
Pdh Tj = -7°C	2.05 kW
COP Tj = -7°C	3.20
Cdh Tj = -7 °C	0.900
Pdh Tj = +2°C	1.25 kW
COP Tj = +2°C	4.55
Cdh Tj = +2 °C	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +7°C	1.39 kW
COP Tj = +7°C	6.03
Cdh Tj = +7 °C	0.900
Pdh Tj = 12°C	1.64 kW
COP Tj = 12°C	6.22
Cdh Tj = +12 °C	0.900
Pdh Tj = Tbiv	2.76 kW
COP Tj = Tbiv	2.56
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.13
Rated airflow rate	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900
WTOL	60 °C
Poff	17 W
PTO	30 W
PSB	17 W
PCK	5 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	3.38 kW
Annual energy consumption Qhe	2208 kWh
Pdh Tj = -15°C (if TOL<-20°C)	

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = -15°C (if TOL<-20°C)	
Cdh Tj = -15 °C	

## Heating

<b>EN 14511-4</b>	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

<b>EN 14511-2</b>	
	<b>Low temperature</b>
Heat output	2.27 kW
El input	0.50 kW
COP	4.54

# Model: TTL 3.5 ACS + HSBC 200, HSBC 200 S

Configure model	
Model name	TTL 3.5 ACS + HSBC 200, HSBC 200 S
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Average Climate

EN 14825		
	Low temperature	Medium temperature
$\eta_s$	166 %	116 %
Prated	3.62 kW	3.83 kW
SCOP	4.22	2.96
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-7 °C
Pdh Tj = -7°C	3.20 kW	2.79 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	1.95 kW	2.01 kW
COP Tj = +2°C	4.11	2.94
Cdh Tj = +2 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +7°C	1.59 kW	1.25 kW
COP Tj = +7°C	5.81	4.13
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.66 kW	1.54 kW
COP Tj = 12°C	6.34	5.13
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.20 kW	3.09 kW
COP Tj = Tbiv	2.88	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.20 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.88	2.20
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	30 W	30 W
PSB	17 W	17 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	3.83 kW
Annual energy consumption Qhe	1771 kWh	2672 kWh

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

## Heating

<b>EN 14511-4</b>	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	2.27 kW	1.92 kW
El input	0.50 kW	0.74 kW
COP	4.54	2.59

## Domestic Hot Water (DHW)

## Average Climate

<b>EN 16147</b>	
Mixed water at 40°C	245 l
Declared load profile	L
Efficiency $\eta_{DHW}$	113 %
COP	2.70
Heating up time	1:50 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C