

Summary of	WPF 7 basic	Reg. No.	011-1W0017
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co	KG	
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für	Konformitätsbewertur	ng mbH
Subtype title	WPF 7 basic	WPF 7 basic	
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2 kg		
Certification Date	25.08.2016	25.08.2016	



Model: WPF 7 basic, all climates

Gener	al Data
Power supply	3x400V 50Hz

Heating

EN 14511-2	
	Low temperature
Heat output	7.64 kW
El input	1.70 kW
СОР	4.50
Indoor water flow rate	1.27 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	failed
Starting and operating test	passed

Average Climate



EN 12102-1	
	Low temperature
Sound power level indoor	55 dB(A)

EN 14825	
	Low temperature
η_s	192 %
Prated	8.00 kW
SCOP	5.01
Tbiv	-10 °C
TOL	-20 °C
Pdh Tj = -7°C	7.70 kW
COP Tj = -7°C	4.56
Cdh	0.90
Pdh Tj = +2°C	7.80 kW
COP Tj = +2°C	4.93
Cdh	0.90
Pdh Tj = +7°C	7.80 kW
COP Tj = +7°C	5.31
Cdh	0.90
Pdh Tj = 12°C	7.90 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





	•
COP Tj = 12°C	5.74
Cdh	0.90
Pdh Tj = Tbiv	7.60 kW
COP Tj = Tbiv	4.49
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.49
WTOL	60 °C
Poff	0 W
PTO	78 W
PSB	3 W
PCK	o w
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	3153 kWh
·	

Warmer Climate

EN 14825	
	Low temperature
η_{s}	191 %
Prated	8.00 kW
SCOP	4.97
	·





This information was generated by the In Rein	
Tbiv	2 °C
TOL	2 °C
Pdh Tj = +2°C	7.60 kW
$COP Tj = +2^{\circ}C$	4.49
Cdh	0.90
Pdh Tj = +7°C	7.70 kW
$COPTj = +7^{\circ}C$	4.85
Cdh	0.90
Pdh Tj = 12°C	7.90 kW
COP Tj = 12°C	5.45
Cdh	0.90
Pdh Tj = Tbiv	7.60 kW
COP Tj = Tbiv	4.49
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.49
WTOL	60 °C
Poff	o w
РТО	78 W
PSB	3 W
PCK	o w
Supplementary Heater: Type of energy input	electricity





Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2052 kWh

EN 12102-	1
	Low temperature
Sound power level indoor	55 dB(A)

Colder Climate

EN 14825	
	Low temperature
η_{s}	200 %
Prated	10.00 kW
SCOP	5.20
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	7.80 kW
COP Tj = -7°C	5.13
Cdh	0.90
Pdh Tj = +2°C	7.90 kW
COP Tj = +2°C	5.42
Cdh	0.90

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the fir KLT	
Pdh Tj = $+7^{\circ}$ C	7.90 kW
$COPTj = +7^{\circ}C$	5.42
Cdh	0.90
Pdh Tj = 12°C	7.90 kW
COP Tj = 12°C	5.68
Cdh	0.90
Pdh Tj = Tbiv	7.80 kW
COP Tj = Tbiv	5.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.00
WTOL	60 °C
Poff	o w
РТО	78 W
PSB	3 W
РСК	o w
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	1.89 kW
Annual energy consumption Qhe	4517 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.80
COP Tj = -15°C (if TOL<-20°C)	2.53
Cdh	0.90
	1





EN 12102-1		
	Low temperature	
Sound power level indoor	55 dB(A)	



Model: WPF 7 basic, average climates


General Data		
Power supply 3x400V 50Hz		

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	7.64 kW	6.76 kW	
El input	1.70 kW	2.67 kW	
СОР	4.50	2.53	
Indoor water flow rate	1.27 m³/h	0.91 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	failed	
Starting and operating test	passed	

Average Climate





EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	192 %	122 %
Prated	8.00 kW	7.00 kW
SCOP	5.01	3.25
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C
Pdh Tj = -7°C	7.70 kW	6.80 kW
$COP Tj = -7^{\circ}C$	4.56	2.66
Cdh	0.90	0.90
Pdh Tj = $+2$ °C	7.80 kW	7.10 kW
$COP Tj = +2^{\circ}C$	4.93	3.19
Cdh	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	7.80 kW	7.30 kW
COP Tj = +7°C	5.31	3.60
Cdh	0.90	0.90
Pdh Tj = 12°C	7.90 kW	7.50 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 11 of 11

COP Tj = 12°C	5.74	4.11
Cdh	0.90	0.90
Pdh Tj = Tbiv	7.60 kW	6.80 kW
COP Tj = Tbiv	4.49	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.60 kW	6.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.49	2.53
WTOL	60 °C	60 °C
Poff	o w	0 W
РТО	78 W	78 W
PSB	3 W	3 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3153 kWh	4298 kWh