

Page 1 of 4

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	Buderus Logatherm WPS 64.2 HT	Reg. No.	011-1W0165	
Certificate Holder				
Name	Bosch Thermotechnik GmbH (Buderus)			
Address	Sophienstraße 30-32	Zip	35576	
City	Wetzlar	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Subtype title	Buderus Logatherm WPS 64.2 HT			
Heat Pump Type	Brine/Water			
Refrigerant	R410A			
Mass of Refrigerant	9.3 kg			



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: Buderus Logatherm WPS 64.2 HT

Configure model			
Model name	Buderus Logatherm WPS 64.2 HT		
Application	Heating (medium temp)		
Units	Indoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	63.90 kW	64.68 kW	
El input	12.10 kW	21.81 kW	
СОР	4.43	2.97	

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	

Average Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	67 dB(A)	67 dB(A)

	EN 14825	
	Low temperature	Medium temperature
η_{s}	199 %	158 %
Prated	62.00 kW	63.00 kW
SCOP	5.17	4.14
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	54.85 kW	55.73 kW
COP Tj = -7°C	4.52	3.36
Pdh Tj = +2°C	33.62 kW	33.90 kW
COP Tj = +2°C	5.28	4.21
Pdh Tj = +7°C	33.56 kW	33.78 kW
COP Tj = +7°C	5.40	4.50
Pdh Tj = 12°C	33.51 kW	33.68 kW
COP Tj = 12°C	5.49	4.74
Pdh Tj = Tbiv	63.90 kW	64.68 kW
COP Tj = Tbiv	4.43	2.97

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	63.90 kW	64.68 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.43	2.97
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	68 °C	68 °C
Poff	25 W	25 W
РТО	25 W	25 W
PSB	25 W	25 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	24782 kWh	31422 kWh