

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Ideal Boiler Hysae Hybrid	Reg. No.	012-C700001
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	SP		
Subtype title	Ideal Boiler Hysae Hybrid		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.05 kg		
Certification Date	02.12.2019		
Testing basis	EN 14511:2013, EN 14825:2013, EN 12102:2013		

## Model: Ideal Boiler Hysae Hybrid 6012/28

### General Data

Power supply	1x230V 50Hz
--------------	-------------

### Heating

#### EN 14511-2

	Low temperature
Heat output	2.96 kW
El input	0.68 kW
COP	4.34
Indoor water flow rate	0.50 m <sup>3</sup> /h

#### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature
Sound power level indoor	47 dB(A)
Sound power level outdoor	58 dB(A)

### EN 14825

	Low temperature
$\eta_s$	160 %
Prated	4.00 kW
SCOP	4.07
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	4.00 kW
COP Tj = -7°C	2.60
Pdh Tj = +2°C	2.30 kW
COP Tj = +2°C	3.80
Pdh Tj = +7°C	1.50 kW
COP Tj = +7°C	6.10
Pdh Tj = 12°C	1.70 kW
COP Tj = 12°C	7.40
Cdh	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = Tbiv	4.00 kW
COP Tj = Tbiv	2.60
Pdh Tj = TOL	3.60 kW
COP Tj = TOL	2.40
Cdh	0.90
WTOL	50 °C
Poff	5 W
PTO	20 W
PSB	5 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.80 kW
Annual energy consumption Qhe	2233 kWh

# Model: Ideal Boiler Hysae Hybrid 6012/35

## General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature
Heat output	2.96 kW
El input	0.68 kW
COP	4.34
Indoor water flow rate	0.50 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature
Sound power level indoor	47 dB(A)
Sound power level outdoor	58 dB(A)

### EN 14825

	Low temperature
$\eta_s$	160 %
Prated	4.00 kW
SCOP	4.07
Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	4.00 kW
COP Tj = -7°C	2.60
Pdh Tj = +2°C	2.30 kW
COP Tj = +2°C	3.80
Pdh Tj = +7°C	1.50 kW
COP Tj = +7°C	6.10
Pdh Tj = 12°C	1.70 kW
COP Tj = 12°C	7.40
Cdh	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = Tbiv	4.00 kW
COP Tj = Tbiv	2.60
Pdh Tj = TOL	3.60 kW
COP Tj = TOL	2.40
Cdh	0.90
WTOL	50 °C
Poff	5 W
PTO	20 W
PSB	5 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.80 kW
Annual energy consumption Qhe	2233 kWh