

Page 1 of 4 This information was generated by the HP KEYMARK database on 27 Jan 2021

Summary of	BoxAir Inverter BA45IS-1	Reg. No.	037-0071-21
Certificate Holder	-		
Name	Master Therm tepelna cerpadla s.r.o.		
Address	Vaclavske namesti 819/43	Zip	110 00
City	Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	BoxAir Inverter BA45IS-1		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	4.7 kg		
Certification Date	26.01.2021		
Testing basis	HP Keymark scheme rules rev. no. 7		

This information was generated by the HP KEYMARK database on 27 Jan 2021

Model: BoxAir Inverter BA45IS-1

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	15.29 kW	14.19 kW	
El input	3.23 kW	4.51 kW	
СОР	4.73	3.15	
Indoor water flow rate	2.63 m³/h	1.53 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



This information was generated by the HP KEYMARK database on 27 Jan 2021

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	48 dB(A)	48 dB(A)	
Sound power level outdoor	62 dB(A)	62 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	176 %	136 %
Prated	13.37 kW	12.05 kW
SCOP	4.46	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.83 kW	10.66 kW
COP Tj = -7°C	2.77	2.10
Cdh	0.90	0.90
Pdh Tj = +2°C	7.91 kW	6.82 kW
COP Tj = +2°C	4.17	3.28
Cdh	0.90	0.90
Pdh Tj = +7°C	4.88 kW	4.38 kW
COP Tj = +7°C	6.44	5.00
Cdh	0.90	0.90

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 27 Jan 2021

Pdh Tj = 12°C	5.73 kW	4.83 kW
COP Tj = 12°C	7.93	6.13
Cdh	0.97	0.98
Pdh Tj = Tbiv	11.83 kW	10.66 kW
COP Tj = Tbiv	2.77	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.96 kW	9.57 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.32	1.77
WTOL	60 °C	60 °C
Poff	19 W	19 W
РТО	19 W	19 W
PSB	19 W	19 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.42 kW	2.48 kW
Annual energy consumption Qhe	6190 kWh	7160 kWh