

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	AEROTOP T32 / T32R	Reg. No.	011-1W0302
Certificate Holder			
Name	ELCO GmbH		
Address	Hohenzollernstrasse 31	Zip	72379
City	Hechingen	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	AEROTOP T32 / T32R		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass of Refrigerant	9.2 kg		
Certification Date	04.05.2019		

Model: AEROTOP T32

Configure model	
Model name	AEROTOP T32
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	38.00 kW	37.00 kW
El input	8.84 kW	13.70 kW
COP	4.30	2.70

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	63 dB(A)	63 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	187 %	122 %
Prated	24.00 kW	33.00 kW
SCOP	4.74	3.13
Tbiv	2 °C	2 °C
TOL	-20 °C	-10 °C
Pdh Tj = +2°C	27.39 kW	26.90 kW
COP Tj = +2°C	3.26	2.40
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	38.20 kW	37.45 kW
COP Tj = +7°C	4.74	3.26
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	43.41 kW	42.51 kW
COP Tj = 12°C	5.67	2.22
Cdh Tj = +12 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	27.39 kW	43.41 kW
COP Tj = Tbiv	3.26	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	27.39 kW	43.41 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.26	2.40
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	57 °C	57 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	80 W	80 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6876 kWh	13864 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	63 dB(A)	63 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 7 Jul 2022

	Low temperature	Medium temperature
η_s	139 %	94 %
Prated	24.00 kW	34.00 kW
SCOP	3.54	2.44
Tbiv	-15 °C	-10 °C
TOL	-20 °C	-10 °C
Pdh Tj = -7°C	24.83 kW	23.63 kW
COP Tj = -7°C	3.08	2.33
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	27.59 kW	27.34 kW
COP Tj = +2°C	3.95	3.09
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	38.50 kW	38.15 kW
COP Tj = +7°C	5.39	4.63
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	43.63 kW	43.18 kW
COP Tj = 12°C	5.90	5.44
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	19.30 kW	21.68 kW
COP Tj = Tbiv	2.25	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	19.30 kW	21.68 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	2.15
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	57 °C	57 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	80 W	80 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	16470 kWh	34596 kWh
Pdh Tj = -15°C (if TOL<-20°C)	0.01	0.01
COP Tj = -15°C (if TOL<-20°C)	0.01	0.01
Cdh Tj = -15 °C	0.90	0.90

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	63 dB(A)	63 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 7 Jul 2022

	Low temperature	Medium temperature
η_s	152 %	114 %
Prated	23.00 kW	23.00 kW
SCOP	3.89	2.93
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C
Pdh Tj = -7°C	24.49 kW	22.95 kW
COP Tj = -7°C	2.86	2.01
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	27.51 kW	27.22 kW
COP Tj = +2°C	3.69	2.69
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	38.40 kW	37.95 kW
COP Tj = +7°C	5.17	4.19
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	43.63 kW	42.96 kW
COP Tj = 12°C	5.90	5.20
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	43.41 kW	21.00 kW
COP Tj = Tbiv	2.60	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	22.50 kW	21.00 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.60	1.80
Cdh $T_j = TOL$ or Pdh $T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	57 °C	57 °C
P _{off}	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	80 W	80 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	11960 kWh	16478 kWh

Model: AEROTOP T32R

Configure model	
Model name	AEROTOP T32R
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	38.00 kW	37.00 kW
El input	8.84 kW	13.70 kW
COP	4.30	2.70

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	63 dB(A)	63 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	197 %	126 %
Prated	24.00 kW	33.00 kW
SCOP	5.00	3.21
Tbiv	2 °C	2 °C
TOL	-20 °C	-10 °C
Pdh Tj = +2°C	27.39 kW	26.90 kW
COP Tj = +2°C	3.26	2.40
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	38.20 kW	37.45 kW
COP Tj = +7°C	4.74	3.26
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	43.41 kW	42.51 kW
COP Tj = 12°C	5.67	2.22
Cdh Tj = +12 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = Tbiv	27.39 kW	26.90 kW
COP Tj = Tbiv	3.26	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	27.39 kW	26.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.26	2.40
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	57 °C	57 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	80 W	80 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6523 kWh	13511 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	63 dB(A)	63 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 7 Jul 2022

	Low temperature	Medium temperature
η_s	140 %	95 %
Prated	24.00 kW	34.00 kW
SCOP	3.58	2.45
Tbiv	-15 °C	-10 °C
TOL	-20 °C	-10 °C
Pdh Tj = -7°C	24.83 kW	23.63 kW
COP Tj = -7°C	3.08	2.33
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	27.59 kW	27.34 kW
COP Tj = +2°C	3.95	3.09
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	38.50 kW	38.15 kW
COP Tj = +7°C	5.39	4.63
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	43.63 kW	43.18 kW
COP Tj = 12°C	5.90	5.44
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	19.30 kW	21.68 kW
COP Tj = Tbiv	2.25	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	19.30 kW	21.68 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.22	2.15
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	57 °C	57 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	80 W	80 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	16294 kWh	34419 kWh
Pdh Tj = -15°C (if TOL<-20°C)	0.01	0.01
COP Tj = -15°C (if TOL<-20°C)	0.01	0.01
Cdh Tj = -15 °C	0.90	0.90

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	63 dB(A)	63 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 7 Jul 2022

	Low temperature	Medium temperature
η_s	156 %	116 %
Prated	23.00 kW	23.00 kW
SCOP	3.98	2.99
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C
Pdh Tj = -7°C	24.49 kW	22.95 kW
COP Tj = -7°C	2.86	2.01
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	27.51 kW	27.22 kW
COP Tj = +2°C	3.69	2.69
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	38.40 kW	37.95 kW
COP Tj = +7°C	5.17	4.19
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	43.63 kW	42.96 kW
COP Tj = 12°C	5.90	5.20
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	43.41 kW	21.00 kW
COP Tj = Tbiv	2.60	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	22.50 kW	21.00 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	57 °C	57 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	80 W	80 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	11666 kWh	16185 kWh