

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	Aquantia MO PRO Mono HP	Reg. No.	041-K009-11
Certificate Holder			
Name	Frigicoll		
Address	Blasco de Garay, 4 6	Zip	08960
City	Sant Just Desvern	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	Aquantia MO PRO Mono HP		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	5 kg		
Certification Date	31.03.2021		
Testing basis	HP Keymark Scheme Rules Rev 08		

Model: KHP-MO 18 DTR2

Configure model	
Model name	KHP-MO 18 DTR2
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	18.32 kW	18.10 kW
El input	3.96 kW	6.63 kW
COP	4.63	2.73

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	226 %	157 %
Prated	17.67 kW	18.07 kW
SCOP	5.74	4.00
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	17.67 kW	18.07 kW
COP Tj = +2°C	3.53	2.12
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	11.36 kW	11.62 kW
COP Tj = +7°C	5.16	3.49
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.45 kW	5.35 kW
COP Tj = 12°C	7.01	5.09
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.36 kW	11.62 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP $T_j = T_{biv}$	5.16	3.49
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	17.67 kW	18.07 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	3.53	2.12
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$		
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	4116 kWh	6041 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	146 %	97 %

This information was generated by the HP KEYMARK database on 23 Jun 2022

Prated	17.76 kW	18.38 kW
SCOP	3.73	2.50
Tbiv	-15 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	11.21 kW	11.13 kW
COP Tj = -7°C	3.09	1.98
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.64 kW	6.65 kW
COP Tj = +2°C	4.50	3.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.77 kW	4.66 kW
COP Tj = +7°C	5.85	4.35
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.95 kW	3.74 kW
COP Tj = 12°C	7.18	5.68
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.49 kW	11.13 kW
COP Tj = Tbiv	2.42	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.14 kW	13.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.67	1.21
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 23 Jun 2022

Poff	20 W	20 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.62 kW	18.38 kW
Annual energy consumption Q _{he}	11740 kWh	18156 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	14.49	13.56
COP T _j = -15°C (if TOL<-20°C)	2.42	1.21
C _{dh} T _j = -15 °C	0.90	0.90

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	181 %	125 %
Prated	17.99 kW	17.67 kW
SCOP	4.60	3.21

This information was generated by the HP KEYMARK database on 23 Jun 2022

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	15.90 kW	15.61 kW
COP Tj = -7°C	2.85	1.72
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	9.66 kW	9.59 kW
COP Tj = +2°C	4.59	3.32
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.56 kW	6.37 kW
COP Tj = +7°C	5.99	4.48
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.76 kW	3.57 kW
COP Tj = 12°C	7.08	5.27
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	15.90 kW	15.61 kW
COP Tj = Tbiv	2.85	1.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.99 kW	15.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.17
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	18 W	18 W

This information was generated by the HP KEYMARK database on 23 Jun 2022

PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	2.64 kW
Annual energy consumption Q _{he}	8086 kWh	11375 kWh

Model: KHP-MO 22 DTR2

Configure model	
Model name	KHP-MO 22 DTR2
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	22.30 kW	22.10 kW
El input	5.13 kW	8.33 kW
COP	4.35	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	234 %	161 %
Prated	21.90 kW	22.01 kW
SCOP	5.85	4.09
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	21.81 kW	22.01 kW
COP Tj = +2°C	3.31	2.12
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	14.08 kW	14.15 kW
COP Tj = +7°C	5.20	3.50
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	6.44 kW	6.38 kW
COP Tj = 12°C	7.50	5.34
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	14.08 kW	14.15 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = Tbiv	5.20	3.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	21.81 kW	22.01 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.31	2.12
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.09 kW	0.00 kW
Annual energy consumption Qhe	4945 kWh	7180 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	146 %	102 %

This information was generated by the HP KEYMARK database on 23 Jun 2022

Prated	21.40 kW	22.36 kW
SCOP	3.72	2.62
Tbiv	-15 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	13.30 kW	13.53 kW
COP Tj = -7°C	3.12	2.07
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.25 kW	8.61 kW
COP Tj = +2°C	4.42	3.70
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.45 kW	5.21 kW
COP Tj = +7°C	5.87	4.49
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.98 kW	3.74 kW
COP Tj = 12°C	7.19	5.76
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	17.46 kW	13.53 kW
COP Tj = Tbiv	2.36	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.27 kW	13.78 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.69	1.24
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 23 Jun 2022

Poff	20 W	20 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	8.13 kW	22.36 kW
Annual energy consumption Qhe	14179 kWh	21067 kWh
Pdh Tj = -15°C (if TOL<-20°C)	17.46	13.78
COP Tj = -15°C (if TOL<-20°C)	2.36	1.24
Cdh Tj = -15 °C	0.90	0.90

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	178 %	126 %
Prated	22.31 kW	22.43 kW
SCOP	4.53	3.22

This information was generated by the HP KEYMARK database on 23 Jun 2022

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	19.72 kW	19.82 kW
COP Tj = -7°C	2.74	1.74
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	12.03 kW	11.89 kW
COP Tj = +2°C	4.41	3.32
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.97 kW
COP Tj = +7°C	6.29	4.66
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.79 kW	3.60 kW
COP Tj = 12°C	7.14	5.32
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	19.72 kW	19.82 kW
COP Tj = Tbiv	2.74	1.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	20.33 kW	13.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.08
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W

This information was generated by the HP KEYMARK database on 23 Jun 2022

PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.97 kW	8.60 kW
Annual energy consumption Q _{he}	10180 kWh	14390 kWh

Model: KHP-MO 26 DTR2

Configure model	
Model name	KHP-MO 26 DTR2
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	26.30 kW	26.06 kW
El input	6.50 kW	10.72 kW
COP	4.05	2.43

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	75 dB(A)	75 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	231 %	168 %
Prated	26.08 kW	26.22 kW
SCOP	5.85	4.26
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	25.50 kW	26.22 kW
COP Tj = +2°C	3.00	1.99
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	16.77 kW	16.86 kW
COP Tj = +7°C	5.02	3.47
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	7.65 kW	7.58 kW
COP Tj = 12°C	7.78	5.94
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	16.77 kW	16.86 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = Tbiv	5.02	3.47
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	25.50 kW	26.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.00	1.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	0.00 kW
Annual energy consumption Qhe	5959 kWh	8218 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	75 dB(A)	75 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	143 %	101 %

This information was generated by the HP KEYMARK database on 23 Jun 2022

Prated	25.75 kW	26.27 kW
SCOP	3.64	2.59
Tbiv	-12 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	15.91 kW	15.90 kW
COP Tj = -7°C	3.10	2.10
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	10.10 kW	10.17 kW
COP Tj = +2°C	4.45	3.58
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	6.30 kW	6.52 kW
COP Tj = +7°C	6.06	4.99
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.03 kW	3.63 kW
COP Tj = 12°C	7.13	5.68
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	18.97 kW	15.90 kW
COP Tj = Tbiv	2.36	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.07 kW	13.37 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.67	1.20
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 23 Jun 2022

Poff	20 W	20 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	12.68 kW	26.27 kW
Annual energy consumption Qhe	17421 kWh	24967 kWh
Pdh Tj = -15°C (if TOL<-20°C)	18.95	13.37
COP Tj = -15°C (if TOL<-20°C)	2.27	1.20
Cdh Tj = -15 °C	0.90	0.90

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	75 dB(A)	75 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	177 %	123 %
Prated	25.04 kW	26.15 kW
SCOP	4.50	3.14

This information was generated by the HP KEYMARK database on 23 Jun 2022

Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	22.12 kW	20.64 kW
COP Tj = -7°C	2.57	1.69
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	13.76 kW	14.26 kW
COP Tj = +2°C	4.44	3.12
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	9.36 kW	9.29 kW
COP Tj = +7°C	6.52	4.74
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.09 kW	3.89 kW
COP Tj = 12°C	7.35	5.48
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	22.12 kW	22.11 kW
COP Tj = Tbiv	2.57	1.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	20.33 kW	13.86 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.08
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W

This information was generated by the HP KEYMARK database on 23 Jun 2022

PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.68 kW	12.28 kW
Annual energy consumption Q _{he}	11489 kWh	17204 kWh

Model: KHP-MO 30 DTR2

Configure model	
Model name	KHP-MO 30 DTR2
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	29.93 kW	29.68 kW
El input	8.02 kW	12.97 kW
COP	3.73	2.29

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	77 dB(A)	77 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	213 %	163 %
Prated	30.44 kW	29.73 kW
SCOP	5.39	4.15
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	26.29 kW	26.41 kW
COP Tj = +2°C	2.94	1.99
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	19.57 kW	19.11 kW
COP Tj = +7°C	4.75	3.37
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	8.90 kW	8.92 kW
COP Tj = 12°C	7.53	6.09
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	19.57 kW	19.11 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP $T_j = T_{biv}$	4.75	3.37
P _{dh} $T_j = TOL$ or P _{dh} $T_j = T_{designh}$ if $TOL < T_{designh}$	26.29 kW	26.41 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.94	1.99
WTOL	60 °C	60 °C
P _{off}	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.15 kW	3.32 kW
Annual energy consumption Q _{he}	7540 kWh	9580 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	77 dB(A)	77 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	138 %	100 %
Prated	29.13 kW	30.41 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

SCOP	3.52	2.56
Tbiv	-10 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	18.49 kW	18.40 kW
COP Tj = -7°C	3.07	2.10
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	11.88 kW	11.22 kW
COP Tj = +2°C	4.42	3.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.53 kW	7.42 kW
COP Tj = +7°C	6.15	5.18
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.11 kW	3.64 kW
COP Tj = 12°C	6.87	5.73
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	19.93 kW	18.40 kW
COP Tj = Tbiv	2.44	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.17 kW	13.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.67	1.18
WTOL	60 °C	60 °C
Poff	18 W	18 W

This information was generated by the HP KEYMARK database on 23 Jun 2022

PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	15.96 kW	30.41 kW
Annual energy consumption Q _{he}	20390 kWh	29238 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	18.61	13.06
COP T _j = -15°C (if TOL<-20°C)	2.24	1.18
C _{dh} T _j = -15 °C	0.90	0.90

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	77 dB(A)	77 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	165 %	123 %
Prated	29.18 kW	29.69 kW
SCOP	4.19	3.14
T _{biv}	-5 °C	-5 °C

This information was generated by the HP KEYMARK database on 23 Jun 2022

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	21.90 kW	20.11 kW
COP Tj = -7°C	2.54	1.63
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	16.16 kW	16.49 kW
COP Tj = +2°C	4.16	3.09
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	10.64 kW	10.50 kW
COP Tj = +7°C	6.38	4.75
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.54 kW	4.64 kW
COP Tj = 12°C	7.72	5.91
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	23.51 kW	23.97 kW
COP Tj = Tbiv	2.71	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	20.37 kW	13.82 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.07
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W

This information was generated by the HP KEYMARK database on 23 Jun 2022

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	8.75 kW	15.86 kW
Annual energy consumption Q _{he}	14165 kWh	19316.17 kWh