

Page 1 of 4

This information was generated by the HP KEYMARK database on 21 Jun 2022

Login

Summary of	IDEAL HEATING Alféa Excellia A.I. 16 Tri	Reg. No.	012-SC0137-19
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	IDEAL HEATING Alféa Excellia A.I. 16 Tri		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	04.04.2020		



This information was generated by the HP KEYMARK database on 21 Jun 2022

Model: IDEAL HEATING Alféa Excellia A.I. Tri 16

Configure model			
Model name IDEAL HEATING Alféa Excellia A.I. Tri 16			
Application	Heating (medium temp)		
Units	Indoor + Outdoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply 3x400V 50Hz		

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	15.17 kW	12.24 kW	
El input	3.70 kW	4.93 kW	
СОР	4.10	2.48	

Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	149 %	117 %
Prated	14.00 kW	13.00 kW
SCOP	3.80	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	11.50 kW
COP Tj = -7°C	2.40	1.80
Pdh Tj = +2°C	7.30 kW	7.00 kW
COP Tj = +2°C	3.60	2.90
Pdh Tj = $+7^{\circ}$ C	6.30 kW	5.80 kW
COP Tj = +7°C	5.50	4.10
Pdh Tj = 12°C	7.40 kW	7.10 kW
COP Tj = 12°C	7.20	5.50
Pdh Tj = Tbiv	12.00 kW	11.50 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = Tbiv	2.40	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	10.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	14 W	14 W
РТО	88 W	32 W
PSB	17 W	17 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.90 kW	2.70 kW
Annual energy consumption Qhe	7408 kWh	9062 kWh