

Page 1 of 3

This information was generated by the HP KEYMARK database on 7 Jul 2022

Login

Summary of	VIESSMANN Vitocal 060-A (180 L) Typ T0E 060-A 180	Reg. No.	011-1W0317		
Certificate Holder					
Name Viessmann Faulquemont SAS					
Address	Avenue André Gouy	Zip	F-57380		
City	Faulquemont	Country	France		
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH				
Subtype title	VIESSMANN Vitocal 060-A (180 L) Typ T0E 060-A 180				
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)				
Refrigerant	R134a				
Mass of Refrigerant	1.15 kg				



Model: VIESSMANN Vitocal 060-A (180 L) Typ **TOE 060-A 180**

Configure model				
Model name VIESSMANN Vitocal 060-A (180 L) Typ T0E 060-A 180				
Units	Indoor			
Climate zone (for heating)	n/a			
Heat Source	n/a			
Any additional heat sources	n/a			

General Data			
Power supply	1x230V 50Hz		
Off-peak product	Yes		

Domestic Hot Water (DHW)

Average Climate

EN 12102-2		
Sound power level indoor	54 dB(A)	

EN 16147				
Declared load profile	L			
Efficiency ηDHW	122 %			
СОР	2.92			
Heating up time	8h34 h:min			
Standby power input	29.0 W			
Reference hot water temperature	52.9 °C			
Mixed water at 40°C	253 I			

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 7 Jul 2022