

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	Buderus Logatherm WPS 6K-1	Reg. No.	011-1W0177
Certificate Holder			
Name	Bosch Thermotechnik GmbH (Buderus)		
Address	Sophienstraße 30-32	Zip	35576
City	Wetzlar	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Buderus Logatherm WPS 6K-1		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.55 kg		

# Model: Buderus Logatherm WPS 6K-1

Configure model	
Model name	Buderus Logatherm WPS 6K-1
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Off-peak product	No

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.70 kW	5.19 kW
El input	1.32 kW	1.85 kW
COP	4.31	2.80

## Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	51 dB(A)	51 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	172 %	125 %
Prated	7.00 kW	6.00 kW
SCOP	4.50	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.80 kW	5.30 kW
COP Tj = -7°C	4.33	2.85
Pdh Tj = +2°C	5.80 kW	5.40 kW
COP Tj = +2°C	4.51	3.25
Pdh Tj = +7°C	5.90 kW	5.60 kW
COP Tj = +7°C	4.69	3.64
Pdh Tj = 12°C	5.90 kW	5.70 kW
COP Tj = 12°C	4.87	4.02
Pdh Tj = Tbiv	5.80 kW	5.30 kW
COP Tj = Tbiv	4.33	2.85

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.70 kW	5.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.23	2.67
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	62 °C	62 °C
Poff	6 W	6 W
PTO	6 W	6 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	0.70 kW
Annual energy consumption $Q_{he}$	2984 kWh	3769 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	84 %
COP	2.16
Heating up time	01:48 h:min
Standby power input	25.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	196 l