

This information was generated by the HP KEYMARK database on 21 Jun 2022

[Login](#)

Summary of	ESTIA HWS-805	Reg. No.	011-1W0342
Certificate Holder			
Name	TOSHIBA AIR CONDITIONING		
Address	Porsham Close, Belliver Industrial Estate	Zip	PL6 7DB
City	Plymouth	Country	United Kingdom
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	ESTIA HWS-805		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.8 kg		
Certification Date	26.11.2019		

## Model: HWS-805H-E/HWS-805XWHM3-E

Configure model	
Model name	HWS-805H-E/HWS-805XWHM3-E
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.51 kW	7.26 kW
El input	1.68 kW	2.65 kW
COP	4.46	2.74

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	161 %	127 %
Prated	6.00 kW	5.00 kW
SCOP	4.12	3.27
Tbiv	-7 °C	-7 °C
TOL	-7 °C	-7 °C
Pdh Tj = -7°C	5.30 kW	4.90 kW
COP Tj = -7°C	2.82	2.06
Pdh Tj = +2°C	4.30 kW	3.10 kW
COP Tj = +2°C	4.28	3.36
Pdh Tj = +7°C	2.10 kW	2.00 kW
COP Tj = +7°C	5.98	4.41
Pdh Tj = 12°C	1.40 kW	1.40 kW
COP Tj = 12°C	7.23	5.86
Pdh Tj = Tbiv	5.30 kW	4.90 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP $T_j = T_{biv}$	2.82	2.06
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.30 kW	4.90 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.82	2.06
Rated airflow rate	3140 m <sup>3</sup> /h	3140 m <sup>3</sup> /h
WTOL	55 °C	55 °C
P <sub>off</sub>	17 W	17 W
PTO	80 W	80 W
PSB	17 W	17 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	5.00 kW
Annual energy consumption Q <sub>he</sub>	3020 kWh	3490 kWh

## Model: HWS-805H-E/HWS-805XWHT6-E

Configure model	
Model name	HWS-805H-E/HWS-805XWHT6-E
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.51 kW	7.26 kW
El input	1.68 kW	2.65 kW
COP	4.46	2.74

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	161 %	127 %
Prated	6.00 kW	5.00 kW
SCOP	4.12	3.27
Tbiv	-7 °C	-7 °C
TOL	-7 °C	-7 °C
Pdh Tj = -7°C	5.30 kW	4.90 kW
COP Tj = -7°C	2.82	2.06
Pdh Tj = +2°C	4.30 kW	3.10 kW
COP Tj = +2°C	4.28	3.36
Pdh Tj = +7°C	2.10 kW	2.00 kW
COP Tj = +7°C	5.98	4.41
Pdh Tj = 12°C	1.40 kW	1.40 kW
COP Tj = 12°C	7.23	5.86
Pdh Tj = Tbiv	5.30 kW	4.90 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP $T_j = T_{biv}$	2.82	2.06
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.30 kW	4.90 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.82	2.06
Rated airflow rate	3140 m <sup>3</sup> /h	3140 m <sup>3</sup> /h
WTOL	55 °C	55 °C
P <sub>off</sub>	17 W	17 W
PTO	80 W	80 W
PSB	17 W	17 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	5.00 kW
Annual energy consumption Q <sub>he</sub>	3020 kWh	3490 kWh

## Model: HWS-805H-E/HWS-805XWHT9-E

Configure model	
Model name	HWS-805H-E/HWS-805XWHT9-E
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.51 kW	7.26 kW
El input	1.68 kW	2.65 kW
COP	4.46	2.74

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### Average Climate



This information was generated by the HP KEYMARK database on 21 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	161 %	127 %
Prated	6.00 kW	5.00 kW
SCOP	4.12	3.27
Tbiv	-7 °C	-7 °C
TOL	-7 °C	-7 °C
Pdh Tj = -7°C	5.30 kW	4.90 kW
COP Tj = -7°C	2.82	2.06
Pdh Tj = +2°C	4.30 kW	3.10 kW
COP Tj = +2°C	4.28	3.36
Pdh Tj = +7°C	2.10 kW	2.00 kW
COP Tj = +7°C	5.98	4.41
Pdh Tj = 12°C	1.40 kW	1.40 kW
COP Tj = 12°C	7.23	5.86
Pdh Tj = Tbiv	5.30 kW	4.90 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP $T_j = T_{biv}$	2.82	2.06
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.30 kW	4.90 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.82	2.06
Rated airflow rate	3140 m <sup>3</sup> /h	3140 m <sup>3</sup> /h
WTOL	55 °C	55 °C
P <sub>off</sub>	17 W	17 W
PTO	80 W	80 W
PSB	17 W	17 W
PCK	14 W	14 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.00 kW	5.00 kW
Annual energy consumption Q <sub>he</sub>	3020 kWh	3490 kWh