

Page 1 of 6

#### This information was generated by the HP KEYMARK database on 22 Jun 2022

#### **Login**

Summary of	S1155-25	Reg. No.	012-C700074		
Certificate Holder	Certificate Holder				
Name	Nibe AB				
Address	Box 14	Zip	S-28521		
City	Markaryd	Country	Sweden		
Certification Body	RISE CERT	RISE CERT			
Subtype title	S1155-25	S1155-25			
Heat Pump Type	Brine/Water and Wa	Brine/Water and Water/Water			
Refrigerant	R410A	R410A			
Mass of Refrigerant	2.1 kg				
Certification Date	09.06.2020				
Testing basis	HP Keymark Scheme Rules rev 7				



## Model: S1155-25

Configure model		
Model name	S1155-25	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional) n/a		

General Data		
Power supply	3x400V 50Hz	

Brine/Water Heat Pump

#### Heating

EN 14511-4		
Starting and operating test	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2			
Low temperature Medium temperature			
Heat output	12.68 kW	11.58 kW	
El input	2.71 kW	4.07 kW	
СОР	4.68	2.84	

#### Average Climate



 $$\operatorname{\textit{Page}}\xspace$  3 of 6 This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	200 %	150 %
Prated	25.00 kW	25.00 kW
SCOP	5.21	3.95
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	22.01 kW	21.71 kW
COP Tj = -7°C	4.24	2.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	13.77 kW	13.74 kW
COP Tj = +2°C	5.31	4.00
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.88 kW	8.44 kW
COP Tj = +7°C	5.77	4.55
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	7.52 kW	7.42 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	5.79	4.72
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	24.19 kW	23.86 kW
COP Tj = Tbiv	4.09	2.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.19 kW	23.86 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.09	2.76
WTOL	65 °C	65 °C
Poff	16 W	16 W
РТО	0 W	0 W
PSB	22 W	22 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	9913 kWh	13063 kWh

Water/Water Heat Pump

## Heating

EN 14511-2			
Low temperature Medium temperature			
Heat output	16.94 kW	15.19 kW	
El input	2.67 kW	4.12 kW	
СОР	6.34	3.69	

This information was generated by the HP KEYMARK database on 22 Jun 2022

#### Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	47 dB(A)	47 dB(A)	

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	285 %	197 %
Prated	34.00 kW	31.00 kW
SCOP	7.32	5.14
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	30.08 kW	27.60 kW
COP Tj = -7°C	5.40	3.60
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	18.30 kW	16.90 kW
COP Tj = +2°C	7.50	5.10
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	11.80 kW	10.90 kW
COP Tj = +7°C	8.50	6.36
Cdh Tj = +7 °C	0.98	0.99

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



# Page 6 of 6 This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	8.60 kW	8.30 kW
COP Tj = 12°C	8.70	6.60
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	34.00 kW	31.00 kW
COP Tj = Tbiv	5.10	3.42
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	34.00 kW	31.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.10	3.42
WTOL	65 °C	65 °C
Poff	16 W	16 W
РТО	30 W	20 W
PSB	22 W	22 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	9598 kWh	12469 kWh