

Page 1 of 4

This information was generated by the HP KEYMARK database on 22 Jun 2022

Login

Summary of	IDEAL HEATING Alféa extensa A.I. 10 R32	Reg. No.	012-C700103
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	IDEAL HEATING Alféa extensa A.I. 10 R32		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.63 kg		
Certification Date	27.04.2021		
Testing basis	HP Keymark Scheme Rules rev 8		

This information was generated by the HP KEYMARK database on 22 Jun 2022

Model: IDEAL HEATING Alféa extensa A.I. 10 R32

Configure model		
Model name	IDEAL HEATING Alféa extensa A.I. 10 R32	
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data			
Power supply 1x230V 50Hz			

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	9.50 kW	9.00 kW	
El input	2.10 kW	3.33 kW	
СОР	4.50	2.70	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	40 dB(A)	40 dB(A)	
Sound power level outdoor	62 dB(A)	62 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	178 %	130 %
Prated	8.50 kW	8.20 kW
SCOP	4.53	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	7.30 kW
COP Tj = -7°C	2.98	2.05
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = $+2^{\circ}$ C	4.60 kW	4.40 kW
COP Tj = +2°C	4.46	3.24
Cdh Tj = +2 °C	0.980	0.980
Pdh Tj = +7°C	3.90 kW	3.50 kW
COP Tj = +7°C	5.89	4.60
Cdh Tj = +7 °C	0.970	0.970

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	4.40 kW	4.30 kW
COP Tj = 12°C	7.14	5.97
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	7.50 kW	7.30 kW
COP Tj = Tbiv	2.98	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.30 kW	7.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	4 W	4 W
РТО	20 W	21 W
PSB	8 W	8 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.20 kW	1.10 kW
Annual energy consumption Qhe	3875 kWh	5083 kWh