

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	CTC EcoPart 430	Reg. No.	012-071
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	CTC EcoPart 430		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass Of Refrigerant	5 kg		

Model: CTC EcoPart 430 1x230V

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	28.62 kW	26.84 kW
El input	6.27 kW	8.74 kW
COP	4.58	3.08
Indoor water flow rate	4.93 m ³ /h	2.89 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	174 %	137 %
Prated	28.62 kW	26.84 kW
SCOP	4.60	3.60
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	29.20 kW	27.20 kW
COP Tj = -7°C	4.64	3.29
Pdh Tj = +2°C	29.40 kW	27.80 kW
COP Tj = +2°C	4.81	3.68
Pdh Tj = +7°C	29.60 kW	28.40 kW
COP Tj = +7°C	4.97	4.03
Pdh Tj = 12°C	29.80 kW	28.80 kW
COP Tj = 12°C	5.13	4.37
Pdh Tj = Tbiv	29.20 kW	27.20 kW
COP Tj = Tbiv	4.64	3.34

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	28.62 kW	26.84 kW
COP Tj = TOL	4.57	3.08
Cdh	0.96	0.99
WTOL	65 °C	65 °C
Poff	18 W	18 W
PTO	97 W	32 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.00 kW	5.40 kW
Annual energy consumption Qhe	14934 kWh	18316 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	53 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	176 %	140 %
Prated	28.62 kW	26.84 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	4.60	3.70
Tbiv	-18 °C	-18 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	29.40 kW	27.60 kW
COP Tj = -7°C	4.84	3.59
Pdh Tj = +2°C	29.60 kW	28.20 kW
COP Tj = +2°C	4.98	3.94
Pdh Tj = +7°C	29.80 kW	28.60 kW
COP Tj = +7°C	5.08	4.26
Pdh Tj = 12°C	29.80 kW	29.00 kW
COP Tj = 12°C	5.11	4.49
Pdh Tj = Tbiv	29.20 kW	27.20 kW
COP Tj = Tbiv	4.67	3.28
Pdh Tj = TOL	28.62 kW	26.84 kW
COP Tj = TOL	4.58	3.08
Cdh	0.96	0.99
WTOL	65 °C	65 °C
Poff	18 W	18 W
PTO	97 W	32 W
PSB	18 W	18 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	3.60 kW	3.40 kW
Annual energy consumption Q _{he}	15539 kWh	20278 kWh

Model: CTC EcoPart 430 3x400V

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	28.62 kW	26.84 kW
El input	6.27 kW	8.74 kW
COP	4.58	3.08
Indoor water flow rate	4.93 m ³ /h	2.89 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	174 %	137 %
Prated	28.62 kW	26.84 kW
SCOP	4.60	3.60
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	29.20 kW	27.20 kW
COP Tj = -7°C	4.64	3.29
Pdh Tj = +2°C	29.40 kW	27.80 kW
COP Tj = +2°C	4.81	3.68
Pdh Tj = +7°C	29.60 kW	28.40 kW
COP Tj = +7°C	4.97	4.03
Pdh Tj = 12°C	29.80 kW	28.80 kW
COP Tj = 12°C	5.13	4.37
Pdh Tj = Tbiv	29.20 kW	27.20 kW
COP Tj = Tbiv	4.64	3.34

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	28.62 kW	26.84 kW
COP Tj = TOL	4.57	3.08
Cdh	0.96	0.99
WTOL	65 °C	65 °C
Poff	18 W	18 W
PTO	97 W	32 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.00 kW	5.40 kW
Annual energy consumption Qhe	14934 kWh	18316 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	53 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	176 %	140 %
Prated	28.62 kW	26.84 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	4.60	3.70
Tbiv	-18 °C	-18 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	29.40 kW	27.60 kW
COP Tj = -7°C	4.84	3.59
Pdh Tj = +2°C	29.60 kW	28.20 kW
COP Tj = +2°C	4.98	3.94
Pdh Tj = +7°C	29.80 kW	28.60 kW
COP Tj = +7°C	5.08	4.26
Pdh Tj = 12°C	29.80 kW	29.00 kW
COP Tj = 12°C	5.11	4.49
Pdh Tj = Tbiv	29.20 kW	27.20 kW
COP Tj = Tbiv	4.67	3.28
Pdh Tj = TOL	28.62 kW	26.84 kW
COP Tj = TOL	4.58	3.08
Cdh	0.96	0.99
WTOL	65 °C	65 °C
Poff	18 W	18 W
PTO	97 W	32 W
PSB	18 W	18 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	3.60 kW	3.40 kW
Annual energy consumption Q _{he}	15539 kWh	20278 kWh