

Page 1 of 7

This information was generated by the HP KEYMARK database on 21 Jun 2022

Login

Summary of	WWC 100 H/X	Reg. No.	041-K001-31	
Certificate Holder				
Name	ait-deutschland Gmb	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359	
City	Kasendorf	Country	Germany	
Certification Body	BRE Global Limited	BRE Global Limited		
Subtype title	WWC 100 H/X	WWC 100 H/X		
Heat Pump Type	Water/Water	Water/Water		
Refrigerant	R407c	R407c		
Mass of Refrigerant	2.95 kg	2.95 kg		
Certification Date	06.09.2019			



This information was generated by the HP KEYMARK database on 21 Jun 2022

Model: WWC 100H/X

Configure model		
Model name	WWC 100H/X	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data	
Power supply 3x400V 50Hz	

Heating

EN 14511-2				
Low temperature Medium temperature				
Heat output	11.00 kW	9.00 kW		
El input	1.96 kW	2.92 kW		
СОР	5.60	3.08		

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate



This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1			
Low temperature Medium temperature			
Sound power level indoor	53 dB(A)	53 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	232 %	174 %
Prated	11.00 kW	9.93 kW
SCOP	5.99	4.56
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.02 kW	10.09 kW
COP Tj = -7°C	5.62	3.52
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	11.14 kW	10.63 kW
COP Tj = +2°C	6.01	4.51
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	11.25 kW	10.95 kW
COP Tj = +7°C	6.39	5.33
Cdh Tj = +7 °C	0.99	1.00
Pdh Tj = 12°C	11.35 kW	11.27 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	6.70	6.32
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	11.00 kW	9.93 kW
COP Tj = Tbiv	5.56	3.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	9.93 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.56	3.29
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	10 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3796 kWh	4499 kWh

Warmer Climate

EN 14825				
Low temperature Medium temperature				
η_{S}	233 %	176 %		
Prated	11.00 kW	9.93 kW		
SCOP	6.01	4.59		
	·			



Page 5 of 7 This information was generated by the HP KEYMARK database on 21 Jun 2022

Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.00 kW	9.93 kW
COP Tj = +2°C	5.56	3.29
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = $+7^{\circ}$ C	11.12 kW	10.41 kW
$COP Tj = +7^{\circ}C$	5.93	4.07
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	11.28 kW	11.05 kW
COP Tj = 12°C	6.52	5.65
Cdh Tj = +12 °C	0.99	1.00
Pdh Tj = Tbiv	11.00 kW	9.93 kW
COP Tj = Tbiv	5.56	3.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	9.93 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.56	3.29
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
РСК	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





inis information was genera	ted by the HP KEYMAR	KK database on 21 Jun 2022	
nentary Heater: PSUP	0.00 kW	0.00 kW	

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2443 kWh	2887 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_{s}	239 %	182 %
Prated	11.00 kW	9.93 kW
SCOP	6.18	4.74
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	11.16 kW	10.52 kW
COP Tj = -7°C	6.09	4.28
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	11.25 kW	10.89 kW
COP Tj = +2°C	6.42	5.18
Cdh Tj = +2 °C	0.99	1.00
Pdh Tj = +7°C	11.32 kW	11.16 kW
COP Tj = +7°C	6.66	6.00
Cdh Tj = +7 °C	0.99	1.00
Pdh Tj = 12°C	11.34 kW	11.37 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 7 of 7 This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	6.53	6.63
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	11.00 kW	9.93 kW
COP Tj = Tbiv	5.56	3.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	9.93 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.56	3.29
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4389 kWh	5165 kWh
Pdh Tj = -15°C (if TOL<-20°C)	0.01	0.01
COP Tj = -15°C (if TOL $<$ -20°C)	0.01	0.01
Cdh Tj = -15 °C	1.00	1.00