

Page 1 of 5

#### This information was generated by the HP KEYMARK database on 22 Jun 2022

#### <u>Login</u>

Summary of	Grant Aerona3 HPID6R32	Reg. No.	041-K005-01	
Certificate Holder	'	'		
Name	Grant Engineering (Ireland) ULC	Grant Engineering (Ireland) ULC		
Address	Barrack St	Zip	R42 D788	
City	Ballinree, Birr	Country	Ireland	
Certification Body	BRE Global Limited	·	·	
Subtype title	Grant Aerona3 HPID6R32			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R32	R32		
Mass of Refrigerant	0.8 kg	0.8 kg		
Certification Date	01.03.2022	01.03.2022		
Testing basis	Heat Pump Keymark Scheme Ru	Heat Pump Keymark Scheme Rules Rev 09		



## **Model: HPID6R32**

Configure model		
Model name	HPID6R32	
Application	Heating + DHW + low temp	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

### Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	6.92 kW	6.24 kW	
El input	1.41 kW	2.05 kW	
СОР	4.91	3.04	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

# Average Climate



 $$\operatorname{\textit{Page}}\ 3$$  of 5 This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65.2 dB(A)	65.2 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_s$	185 %	132 %
Prated	4.50 kW	4.50 kW
SCOP	4.70	3.38
Tbiv	-9 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.68 kW	5.03 kW
$COPTj = -7^{\circ}C$	3.13	2.11
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.24 kW	3.21 kW
COP Tj = +2°C	6.02	4.03
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	2.10 kW	2.20 kW
$COP Tj = +7^{\circ}C$	7.40	5.10
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	2.00 kW	1.78 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	9.20	6.15
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	4.50 kW	4.49 kW
COP Tj = Tbiv	3.02	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.87 kW	3.51 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.67	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	100 W	100 W
РТО	40 W	40 W
PSB	100 W	100 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.63 kW	0.99 kW
Annual energy consumption Qhe	1979 kWh	2754 kWh

Domestic Hot Water (DHW)

Average Climate





 $$\operatorname{\textit{Page}}\xspace\:5\:\:\text{of}\:5\:$  This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147		
Declared load profile	L	
Efficiency ηDHW	114 %	
СОР	2.75	
Heating up time	1:47 h:min	
Standby power input	26.3 W	
Reference hot water temperature	49.0 °C	
Mixed water at 40°C	278	