Login

Summary of	Bosch Compress 3000 AWS-4/6	Reg. No.	011-1W0133
Certificate Holder			
Name	Bosch Thermotechnik GmbH		
Address	Junkersstraße 20 - 24	Zip	73249
City	Wernau	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Bosch Compress 3000 AWS-4/6		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.6 kg		
Certification Date	18.07.2017		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Bosch Compress 3000 AWS-6 E

Configure model	
Model name	Bosch Compress 3000 AWS-6 E
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.47 kW	7.62 kW
El input	1.96 kW	3.46 kW
COP	1.77	2.20

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	215 %	148 %
Prated	6.39 kW	5.81 kW
SCOP	5.45	3.77
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.39 kW	5.81 kW
COP Tj = +2°C	3.10	2.02
Cdh Tj = +2 °C	0.992	0.994
Pdh Tj = +7°C	4.22 kW	3.72 kW
COP Tj = +7°C	5.21	3.36
Cdh Tj = +7 °C	0.979	0.985
Pdh Tj = 12°C	4.01 kW	3.72 kW
COP Tj = 12°C	6.57	4.84
Cdh Tj = +12 °C	0.972	0.978

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = Tbiv	6.39 kW	5.81 kW
COP Tj = Tbiv	3.10	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.39 kW	5.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.10	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1566 kWh	2058 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	141 %	109 %
Prated	7.30 kW	6.80 kW
SCOP	3.59	2.80
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	4.40 kW	4.12 kW
COP Tj = -7°C	3.29	2.37
Cdh Tj = -7 °C	0.987	0.990
Pdh Tj = +2°C	3.00 kW	2.73 kW
COP Tj = +2°C	4.74	3.55
Cdh Tj = +2 °C	0.973	0.978
Pdh Tj = +7°C	3.47 kW	3.26 kW
COP Tj = +7°C	5.56	4.38
Cdh Tj = +7 °C	0.973	0.977
Pdh Tj = 12°C	4.03 kW	3.87 kW
COP Tj = 12°C	6.74	5.47
Cdh Tj = +12 °C	0.972	0.976
Pdh Tj = Tbiv	6.00 kW	5.55 kW
COP Tj = Tbiv	2.43	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.55 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.43	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.30 kW	6.80 kW
Annual energy consumption Qhe	5007 kWh	5992 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.00	5.55
COP Tj = -15°C (if TOL<-20°C)	2.43	1.86
Cdh Tj = -15 °C	0.993	0.994

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	167 %	121 %
Prated	6.80 kW	5.31 kW
SCOP	4.24	3.10
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.92 kW	4.78 kW
COP Tj = -7°C	2.64	1.90
Cdh Tj = -7 °C	0.992	0.993
Pdh Tj = +2°C	3.58 kW	2.80 kW
COP Tj = +2°C	4.22	3.11
Cdh Tj = +2 °C	0.980	0.981
Pdh Tj = +7°C	3.49 kW	3.16 kW
COP Tj = +7°C	5.51	3.96
Cdh Tj = +7 °C	0.973	0.979
Pdh Tj = 12°C	3.91 kW	3.81 kW
COP Tj = 12°C	6.40	5.22
Cdh Tj = +12 °C	0.972	0.977
Pdh Tj = Tbiv	6.80 kW	5.31 kW
COP Tj = Tbiv	2.54	1.54
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	5.31 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.54	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3311 kWh	3535 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Bosch Compress 3000 AWS-6 B

Configure model	
Model name	Bosch Compress 3000 AWS-6 B
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.47 kW	7.62 kW
El input	1.96 kW	3.46 kW
COP	1.77	2.20

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	215 %	148 %
Prated	6.39 kW	5.81 kW
SCOP	5.45	3.77
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.39 kW	5.81 kW
COP Tj = +2°C	3.10	2.02
Cdh Tj = +2 °C	0.992	0.994
Pdh Tj = +7°C	4.22 kW	3.72 kW
COP Tj = +7°C	5.21	3.36
Cdh Tj = +7 °C	0.979	0.985
Pdh Tj = 12°C	4.01 kW	3.72 kW
COP Tj = 12°C	6.57	4.84
Cdh Tj = +12 °C	0.972	0.978

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = Tbiv	6.39 kW	5.81 kW
COP Tj = Tbiv	3.10	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.39 kW	5.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.10	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	n/a	
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1566 kWh	2058 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	141 %	109 %
Prated	7.30 kW	6.80 kW
SCOP	3.59	2.80
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	4.40 kW	4.12 kW
COP Tj = -7°C	3.29	2.37
Cdh Tj = -7 °C	0.987	0.990
Pdh Tj = +2°C	3.00 kW	2.73 kW
COP Tj = +2°C	4.74	3.55
Cdh Tj = +2 °C	0.973	0.978
Pdh Tj = +7°C	3.47 kW	3.26 kW
COP Tj = +7°C	5.56	4.38
Cdh Tj = +7 °C	0.973	0.977
Pdh Tj = 12°C	4.03 kW	3.87 kW
COP Tj = 12°C	6.74	5.47
Cdh Tj = +12 °C	0.972	0.976
Pdh Tj = Tbiv	6.00 kW	5.55 kW
COP Tj = Tbiv	2.43	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.55 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.43	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	n/a	
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5007 kWh	5992 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.00	5.55
COP Tj = -15°C (if TOL<-20°C)	2.43	1.86
Cdh Tj = -15 °C	0.993	0.994

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	167 %	121 %
Prated	6.80 kW	5.31 kW
SCOP	4.24	3.10
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.92 kW	4.78 kW
COP Tj = -7°C	2.64	1.90
Cdh Tj = -7 °C	0.992	0.993
Pdh Tj = +2°C	3.58 kW	2.80 kW
COP Tj = +2°C	4.22	3.11
Cdh Tj = +2 °C	0.980	0.981
Pdh Tj = +7°C	3.49 kW	3.16 kW
COP Tj = +7°C	5.51	3.96
Cdh Tj = +7 °C	0.973	0.979
Pdh Tj = 12°C	3.91 kW	3.81 kW
COP Tj = 12°C	6.40	5.22
Cdh Tj = +12 °C	0.972	0.977
Pdh Tj = Tbiv	6.80 kW	5.31 kW
COP Tj = Tbiv	2.54	1.54
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	5.31 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.54	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	n/a	
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3311 kWh	3535 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Bosch Compress 3000 AWS-6 M

Configure model	
Model name	Bosch Compress 3000 AWS-6 M
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.47 kW	7.62 kW
El input	1.96 kW	3.46 kW
COP	1.77	2.20

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	215 %	148 %
Prated	6.39 kW	5.81 kW
SCOP	5.45	3.77
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.39 kW	5.81 kW
COP Tj = +2°C	3.10	2.02
Cdh Tj = +2 °C	0.992	0.994
Pdh Tj = +7°C	4.22 kW	3.72 kW
COP Tj = +7°C	5.21	3.36
Cdh Tj = +7 °C	0.979	0.985
Pdh Tj = 12°C	4.01 kW	3.72 kW
COP Tj = 12°C	6.57	4.84
Cdh Tj = +12 °C	0.972	0.978

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = Tbiv	6.39 kW	5.81 kW
COP Tj = Tbiv	3.10	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.39 kW	5.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.10	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1566 kWh	2058 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	141 %	109 %
Prated	7.30 kW	6.80 kW
SCOP	3.59	2.80
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	4.40 kW	4.12 kW
COP Tj = -7°C	3.29	2.37
Cdh Tj = -7 °C	0.987	0.990
Pdh Tj = +2°C	3.00 kW	2.73 kW
COP Tj = +2°C	4.74	3.55
Cdh Tj = +2 °C	0.973	0.978
Pdh Tj = +7°C	3.47 kW	3.26 kW
COP Tj = +7°C	5.56	4.38
Cdh Tj = +7 °C	0.973	0.977
Pdh Tj = 12°C	4.03 kW	3.87 kW
COP Tj = 12°C	6.74	5.47
Cdh Tj = +12 °C	0.972	0.976
Pdh Tj = Tbiv	6.00 kW	5.55 kW
COP Tj = Tbiv	2.43	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.55 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.43	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.30 kW	6.80 kW
Annual energy consumption Qhe	5007 kWh	5992 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.00	1.86
COP Tj = -15°C (if TOL<-20°C)	2.43	1.86
Cdh Tj = -15 °C	0.993	0.994

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	167 %	121 %
Prated	6.80 kW	5.31 kW
SCOP	4.24	3.10
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.92 kW	4.78 kW
COP Tj = -7°C	2.64	1.90
Cdh Tj = -7 °C	0.992	0.993
Pdh Tj = +2°C	3.58 kW	2.80 kW
COP Tj = +2°C	4.22	3.11
Cdh Tj = +2 °C	0.980	0.981
Pdh Tj = +7°C	3.49 kW	3.16 kW
COP Tj = +7°C	5.51	3.96
Cdh Tj = +7 °C	0.973	0.979
Pdh Tj = 12°C	3.91 kW	3.81 kW
COP Tj = 12°C	6.40	5.22
Cdh Tj = +12 °C	0.972	0.977
Pdh Tj = Tbiv	6.80 kW	5.31 kW
COP Tj = Tbiv	2.54	1.54
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	5.31 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.54	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3311 kWh	3535 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	113 %
COP	2.65
Heating up time	01:44 h:min
Standby power input	51.0 W
Reference hot water temperature	51.9 °C
Mixed water at 40°C	252 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	72 %
COP	1.64
Heating up time	02:43 h:min
Standby power input	109.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	250 l

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	94 %
COP	2.22
Heating up time	02:11 h:min
Standby power input	58.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	254 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Bosch Compress 3000 AWS-6 MS

Configure model	
Model name	Bosch Compress 3000 AWS-6 MS
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.47 kW	7.62 kW
El input	1.96 kW	3.46 kW
COP	1.77	2.20

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	215 %	148 %
Prated	6.39 kW	5.81 kW
SCOP	5.45	3.77
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.39 kW	5.81 kW
COP Tj = +2°C	3.10	2.02
Cdh Tj = +2 °C	0.992	0.994
Pdh Tj = +7°C	4.22 kW	3.72 kW
COP Tj = +7°C	5.21	3.36
Cdh Tj = +7 °C	0.979	0.985
Pdh Tj = 12°C	4.01 kW	3.72 kW
COP Tj = 12°C	6.57	4.84
Cdh Tj = +12 °C	0.972	0.978

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = Tbiv	6.39 kW	5.81 kW
COP Tj = Tbiv	3.10	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.39 kW	5.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.10	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1566 kWh	2058 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	141 %	109 %
Prated	7.30 kW	6.80 kW
SCOP	3.59	2.80
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	4.40 kW	4.12 kW
COP Tj = -7°C	3.29	2.37
Cdh Tj = -7 °C	0.987	0.990
Pdh Tj = +2°C	3.00 kW	2.73 kW
COP Tj = +2°C	4.74	3.55
Cdh Tj = +2 °C	0.973	0.978
Pdh Tj = +7°C	3.47 kW	3.26 kW
COP Tj = +7°C	5.56	4.38
Cdh Tj = +7 °C	0.973	0.977
Pdh Tj = 12°C	4.03 kW	3.87 kW
COP Tj = 12°C	6.74	5.47
Cdh Tj = +12 °C	0.972	0.976
Pdh Tj = Tbiv	6.00 kW	5.55 kW
COP Tj = Tbiv	2.43	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	5.55 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.43	1.86
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.30 kW	6.80 kW
Annual energy consumption Qhe	5007 kWh	5992 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.00	5.55
COP Tj = -15°C (if TOL<-20°C)	2.43	1.86
Cdh Tj = -15 °C	0.993	0.994

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	167 %	121 %
Prated	6.80 kW	5.31 kW
SCOP	4.24	3.10
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.92 kW	4.78 kW
COP Tj = -7°C	2.64	1.90
Cdh Tj = -7 °C	0.992	0.993
Pdh Tj = +2°C	3.58 kW	2.80 kW
COP Tj = +2°C	4.22	3.11
Cdh Tj = +2 °C	0.980	0.981
Pdh Tj = +7°C	3.49 kW	3.16 kW
COP Tj = +7°C	5.51	3.96
Cdh Tj = +7 °C	0.973	0.979
Pdh Tj = 12°C	3.91 kW	3.81 kW
COP Tj = 12°C	6.40	5.22
Cdh Tj = +12 °C	0.972	0.977
Pdh Tj = Tbiv	6.80 kW	5.31 kW
COP Tj = Tbiv	2.54	1.54
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	5.31 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.54	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.995
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3311 kWh	3535 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	100 %
COP	2.34
Heating up time	01:42 h:min
Standby power input	63.0 W
Reference hot water temperature	50.9 °C
Mixed water at 40°C	247 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	70 %
COP	1.61
Heating up time	01:56 h:min
Standby power input	111.2 W
Reference hot water temperature	50.5 °C
Mixed water at 40°C	244 l

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	87 %
COP	2.04
Heating up time	02:08 h:min
Standby power input	62.2 W
Reference hot water temperature	51.1 °C
Mixed water at 40°C	238 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Bosch Compress 3000 AWS-4 E

Configure model	
Model name	Bosch Compress 3000 AWS-4 E
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.47 kW	6.80 kW
El input	1.96 kW	2.99 kW
COP	1.77	2.27

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	215 %	149 %
Prated	6.17 kW	4.95 kW
SCOP	5.46	3.81
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.17 kW	4.94 kW
COP Tj = +2°C	3.53	2.07
Cdh Tj = +2 °C	0.990	0.993
Pdh Tj = +7°C	3.96 kW	3.16 kW
COP Tj = +7°C	5.11	3.36
Cdh Tj = +7 °C	0.978	0.982
Pdh Tj = 12°C	3.99 kW	3.73 kW
COP Tj = 12°C	6.59	4.99
Cdh Tj = +12 °C	0.972	0.977

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = Tbiv	6.17 kW	4.94 kW
COP Tj = Tbiv	3.53	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.17 kW	4.94 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.53	2.07
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.993
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1510 kWh	1737 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	145 %	106 %
Prated	6.74 kW	5.44 kW
SCOP	3.69	2.72
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	4.08 kW	3.27 kW
COP Tj = -7°C	3.44	2.28
Cdh Tj = -7 °C	0.986	0.988
Pdh Tj = +2°C	3.08 kW	2.81 kW
COP Tj = +2°C	4.79	3.40
Cdh Tj = +2 °C	0.974	0.979
Pdh Tj = +7°C	3.51 kW	3.29 kW
COP Tj = +7°C	5.72	4.35
Cdh Tj = +7 °C	0.972	0.978
Pdh Tj = 12°C	4.01 kW	3.83 kW
COP Tj = 12°C	6.62	5.61
Cdh Tj = +12 °C	0.972	0.975
Pdh Tj = Tbiv	5.50 kW	4.44 kW
COP Tj = Tbiv	2.81	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.50 kW	4.43 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.81	1.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.992
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.74 kW	5.44 kW
Annual energy consumption Qhe	4500 kWh	4933 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.50	4.43
COP Tj = -15°C (if TOL<-20°C)	2.81	1.99
Cdh Tj = -15 °C	0.991	0.992

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	175 %	122 %
Prated	5.84 kW	4.78 kW
SCOP	4.46	3.12
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.19 kW	4.20 kW
COP Tj = -7°C	3.04	1.91
Cdh Tj = -7 °C	0.990	0.992
Pdh Tj = +2°C	3.01 kW	2.52 kW
COP Tj = +2°C	4.53	3.09
Cdh Tj = +2 °C	0.974	0.979
Pdh Tj = +7°C	3.49 kW	3.16 kW
COP Tj = +7°C	5.57	4.08
Cdh Tj = +7 °C	0.973	0.978
Pdh Tj = 12°C	3.49 kW	3.81 kW
COP Tj = 12°C	5.57	5.35
Cdh Tj = +12 °C	0.973	0.976
Pdh Tj = Tbiv	5.84 kW	4.77 kW
COP Tj = Tbiv	2.68	1.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.84 kW	4.77 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.68	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2708 kWh	3163 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Bosch Compress 3000 AWS-4 B

Configure model	
Model name	Bosch Compress 3000 AWS-4 B
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.47 kW	6.80 kW
El input	1.96 kW	2.99 kW
COP	1.77	2.27

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	215 %	149 %
Prated	6.17 kW	4.95 kW
SCOP	5.46	3.81
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.17 kW	4.94 kW
COP Tj = +2°C	3.53	2.07
Cdh Tj = +2 °C	0.990	0.993
Pdh Tj = +7°C	3.96 kW	3.16 kW
COP Tj = +7°C	5.11	3.36
Cdh Tj = +7 °C	0.978	0.982
Pdh Tj = 12°C	3.99 kW	3.73 kW
COP Tj = 12°C	6.59	4.99
Cdh Tj = +12 °C	0.972	0.977

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = Tbiv	6.17 kW	4.94 kW
COP Tj = Tbiv	3.53	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.17 kW	4.94 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.53	2.07
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.993
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	n/a	
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1510 kWh	1737 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	145 %	106 %
Prated	6.74 kW	5.44 kW
SCOP	3.69	2.72
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	4.08 kW	3.27 kW
COP Tj = -7°C	3.44	2.28
Cdh Tj = -7 °C	0.986	0.988
Pdh Tj = +2°C	3.08 kW	2.81 kW
COP Tj = +2°C	4.79	3.40
Cdh Tj = +2 °C	0.974	0.979
Pdh Tj = +7°C	3.51 kW	3.29 kW
COP Tj = +7°C	5.72	4.35
Cdh Tj = +7 °C	0.972	0.978
Pdh Tj = 12°C	4.01 kW	3.83 kW
COP Tj = 12°C	6.62	5.61
Cdh Tj = +12 °C	0.972	0.975
Pdh Tj = Tbiv	5.50 kW	4.44 kW
COP Tj = Tbiv	2.81	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.50 kW	4.43 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.81	1.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.992
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	n/a	
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4500 kWh	4933 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.50	4.43
COP Tj = -15°C (if TOL<-20°C)	2.81	1.99
Cdh Tj = -15 °C	0.991	0.992

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	29 dB(A)	29 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	175 %	122 %
Prated	5.84 kW	4.78 kW
SCOP	4.46	3.12
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.19 kW	4.20 kW
COP Tj = -7°C	3.04	1.91
Cdh Tj = -7 °C	0.990	0.992
Pdh Tj = +2°C	3.01 kW	2.52 kW
COP Tj = +2°C	4.53	3.09
Cdh Tj = +2 °C	0.974	0.979
Pdh Tj = +7°C	3.49 kW	3.16 kW
COP Tj = +7°C	5.57	4.08
Cdh Tj = +7 °C	0.973	0.978
Pdh Tj = 12°C	3.49 kW	3.81 kW
COP Tj = 12°C	5.57	5.35
Cdh Tj = +12 °C	0.973	0.976
Pdh Tj = Tbiv	5.84 kW	4.77 kW
COP Tj = Tbiv	2.68	1.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.84 kW	4.77 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.68	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	n/a	
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2708 kWh	3163 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Bosch Compress 3000 AWS-4 M

Configure model	
Model name	Bosch Compress 3000 AWS-4 M
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.47 kW	6.80 kW
El input	1.96 kW	2.99 kW
COP	1.77	2.27

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	215 %	149 %
Prated	6.17 kW	4.95 kW
SCOP	5.46	3.81
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.17 kW	4.94 kW
COP Tj = +2°C	3.53	2.07
Cdh Tj = +2 °C	0.990	0.993
Pdh Tj = +7°C	3.96 kW	3.16 kW
COP Tj = +7°C	5.11	3.36
Cdh Tj = +7 °C	0.978	0.982
Pdh Tj = 12°C	3.99 kW	3.73 kW
COP Tj = 12°C	6.59	4.99
Cdh Tj = +12 °C	0.972	0.977

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = Tbiv	6.17 kW	4.94 kW
COP Tj = Tbiv	3.53	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.17 kW	4.94 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.53	2.07
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.993
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1510 kWh	1737 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	145 %	106 %
Prated	6.74 kW	5.44 kW
SCOP	3.69	2.72
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	4.08 kW	3.27 kW
COP Tj = -7°C	3.44	2.28
Cdh Tj = -7 °C	0.986	0.988
Pdh Tj = +2°C	3.08 kW	2.81 kW
COP Tj = +2°C	4.79	3.40
Cdh Tj = +2 °C	0.974	0.979
Pdh Tj = +7°C	3.51 kW	3.29 kW
COP Tj = +7°C	5.72	4.35
Cdh Tj = +7 °C	0.972	0.978
Pdh Tj = 12°C	4.01 kW	3.83 kW
COP Tj = 12°C	6.62	5.61
Cdh Tj = +12 °C	0.972	0.975
Pdh Tj = Tbiv	5.50 kW	4.44 kW
COP Tj = Tbiv	2.81	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.50 kW	4.43 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.81	1.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.992
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.74 kW	5.44 kW
Annual energy consumption Qhe	4500 kWh	4933 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.50	1.99
COP Tj = -15°C (if TOL<-20°C)	2.81	1.99
Cdh Tj = -15 °C	0.991	0.992

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	175 %	122 %
Prated	5.84 kW	4.78 kW
SCOP	4.46	3.12
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.19 kW	4.20 kW
COP Tj = -7°C	3.04	1.91
Cdh Tj = -7 °C	0.990	0.992
Pdh Tj = +2°C	3.01 kW	2.52 kW
COP Tj = +2°C	4.53	3.09
Cdh Tj = +2 °C	0.974	0.979
Pdh Tj = +7°C	3.49 kW	3.16 kW
COP Tj = +7°C	5.57	4.08
Cdh Tj = +7 °C	0.973	0.978
Pdh Tj = 12°C	3.49 kW	3.81 kW
COP Tj = 12°C	5.57	5.35
Cdh Tj = +12 °C	0.973	0.976
Pdh Tj = Tbiv	5.84 kW	4.77 kW
COP Tj = Tbiv	2.68	1.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.84 kW	4.77 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.68	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2708 kWh	3163 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	113 %
COP	2.65
Heating up time	01:44 h:min
Standby power input	51.0 W
Reference hot water temperature	51.9 °C
Mixed water at 40°C	252 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	72 %
COP	1.64
Heating up time	02:43 h:min
Standby power input	109.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	250 l

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	94 %
COP	2.22
Heating up time	02:11 h:min
Standby power input	58.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	254 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: Bosch Compress 3000 AWS-4 MS

Configure model	
Model name	Bosch Compress 3000 AWS-4 MS
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	3.47 kW	6.80 kW
El input	1.96 kW	2.99 kW
COP	1.77	2.27

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	215 %	149 %
Prated	6.17 kW	4.95 kW
SCOP	5.46	3.81
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.17 kW	4.94 kW
COP Tj = +2°C	3.53	2.07
Cdh Tj = +2 °C	0.990	0.993
Pdh Tj = +7°C	3.96 kW	3.16 kW
COP Tj = +7°C	5.11	3.36
Cdh Tj = +7 °C	0.978	0.982
Pdh Tj = 12°C	3.99 kW	3.73 kW
COP Tj = 12°C	6.59	4.99
Cdh Tj = +12 °C	0.972	0.977

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = Tbiv	6.17 kW	4.94 kW
COP Tj = Tbiv	3.53	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.17 kW	4.94 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.53	2.07
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.993
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1510 kWh	1737 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	145 %	106 %
Prated	6.74 kW	5.44 kW
SCOP	3.69	2.72
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	4.08 kW	3.27 kW
COP Tj = -7°C	3.44	2.28
Cdh Tj = -7 °C	0.986	0.988
Pdh Tj = +2°C	3.08 kW	2.81 kW
COP Tj = +2°C	4.79	3.40
Cdh Tj = +2 °C	0.974	0.979
Pdh Tj = +7°C	3.51 kW	3.29 kW
COP Tj = +7°C	5.72	4.35
Cdh Tj = +7 °C	0.972	0.978
Pdh Tj = 12°C	4.01 kW	3.83 kW
COP Tj = 12°C	6.62	5.61
Cdh Tj = +12 °C	0.972	0.975
Pdh Tj = Tbiv	5.50 kW	4.44 kW
COP Tj = Tbiv	2.81	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.50 kW	4.43 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.81	1.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.992
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.74 kW	5.44 kW
Annual energy consumption Qhe	4500 kWh	4933 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.50	4.43
COP Tj = -15°C (if TOL<-20°C)	2.81	1.99
Cdh Tj = -15 °C	0.991	0.992

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	38 dB(A)	38 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	175 %	122 %
Prated	5.84 kW	4.78 kW
SCOP	4.46	3.12
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.19 kW	4.20 kW
COP Tj = -7°C	3.04	1.91
Cdh Tj = -7 °C	0.990	0.992
Pdh Tj = +2°C	3.01 kW	2.52 kW
COP Tj = +2°C	4.53	3.09
Cdh Tj = +2 °C	0.974	0.979
Pdh Tj = +7°C	3.49 kW	3.16 kW
COP Tj = +7°C	5.57	4.08
Cdh Tj = +7 °C	0.973	0.978
Pdh Tj = 12°C	3.49 kW	3.81 kW
COP Tj = 12°C	5.57	5.35
Cdh Tj = +12 °C	0.973	0.976
Pdh Tj = Tbiv	5.84 kW	4.77 kW
COP Tj = Tbiv	2.68	1.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.84 kW	4.77 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.68	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	57 °C	57 °C
Poff	17 W	17 W
PTO	17 W	17 W
PSB	17 W	17 W
PCK	16 W	16 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2708 kWh	3163 kWh

Domestic Hot Water (DHW)

Warmer Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	100 %
COP	2.34
Heating up time	01:42 h:min
Standby power input	63.0 W
Reference hot water temperature	50.9 °C
Mixed water at 40°C	247 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Colder Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	70 %
COP	1.61
Heating up time	01:56 h:min
Standby power input	111.2 W
Reference hot water temperature	50.5 °C
Mixed water at 40°C	244 l

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	87 %
COP	2.04
Heating up time	02:08 h:min
Standby power input	62.2 W
Reference hot water temperature	51.1 °C
Mixed water at 40°C	238 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.