This information was generated by the HP KEYMARK database on 7 Jul 2022

Login

Summary of	DAIKIN ALTHERMA LT MONOBLOC / ROTEX HPSU MONOBLOC 5 KW	Reg. No.	011-1W0079
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA LT MONOBLOC / ROTEX HPSU MONOBLOC 5 KW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.3 kg		

Model: RBLQ05C*V3

Configure model	
Model name	RBLQ05C*V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.36 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

Model: RDLQ05C*V3

Configure model	
Model name	RDLQ05C*V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.34 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.36 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

Model: EDLQ05C*V3

Configure model	
Model name	EDLQ05C*V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.34 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.36 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

Model: EBLQ05C*V3

Configure model	
Model name	EBLQ05C*V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.36 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.04 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh