

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	WPL 25 AS	Reg. No.	011-1W0003
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPL 25 AS		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	4.7 kg		
Certification Date	11.08.2016		

Model: WPL 25 AS

Configure model

Model name	WPL 25 AS
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	8.00 kW	7.52 kW
El input	1.66 kW	2.33 kW
COP	4.82	3.23

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	173 %	136 %
Prated	15.00 kW	15.00 kW
SCOP	4.39	3.47
Tbiv	-5 °C	-5 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.00 kW	13.80 kW
COP Tj = -7°C	3.02	2.43
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.00 kW	7.70 kW
COP Tj = +2°C	4.40	3.37
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.10 kW	7.90 kW
COP Tj = +7°C	5.64	4.45
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	8.11	6.66
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.80 kW	12.40 kW
COP Tj = Tbiv	3.18	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.60 kW	13.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	2.28
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	7055 kWh	8940 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	206 %	155 %
Prated	8.00 kW	7.00 kW
SCOP	5.21	3.95

This information was generated by the HP KEYMARK database on 23 Jun 2022

Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.90 kW	7.40 kW
COP Tj = +2°C	3.89	2.59
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.10 kW	7.70 kW
COP Tj = +7°C	5.10	3.60
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.90 kW	7.40 kW
COP Tj = Tbiv	3.89	2.59
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.60 kW	19.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.72	2.29
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 23 Jun 2022

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2050 kWh	2367 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	153 %	126 %
Prated	21.00 kW	22.00 kW
SCOP	3.89	3.23
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	12.80 kW	13.50 kW
COP T _j = -7°C	3.21	2.65
C _{dh} T _j = -7 °C	0.90	0.90
P _{dh} T _j = +2°C	8.10 kW	7.90 kW
COP T _j = +2°C	4.75	3.75
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	8.20 kW	8.00 kW
COP T _j = +7°C	5.95	4.86
C _{dh} T _j = +7 °C	0.90	0.90
P _{dh} T _j = 12°C	9.10 kW	9.00 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.80 kW	13.50 kW
COP Tj = Tbiv	3.21	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.40 kW	19.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.38
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	21.17 kW	22.26 kW
Annual energy consumption Qhe	13312 kWh	16814 kWh
Pdh Tj = -15°C (if TOL<-20°C)	17.40	19.30
COP Tj = -15°C (if TOL<-20°C)	2.80	2.38
Cdh Tj = -15 °C	0.90	0.90