

Page 1 of 3

This information was generated by the HP KEYMARK database on 18 Mar 2022

<u>Login</u>			
Summary of	COMBO RSJA-23/300	Reg. No.	ICIM-PDC-000037-00
Certificate Holder			
Name	GD Midea Heating & Ventilating Equipment Co., Ltd.		
Address	Penglai Industry Road	Zip	528311
City	Beijiao, Shunde, Foshan	Country	China
Certification Body	ICIM S.p.A.		
Subtype title	COMBO RSJA-23/300		
Heat Pump Type	Heat Pump for Domestic Hot	Heat Pump for Domestic Hot Water (DHW)	
Refrigerant	R134a		
Mass of Refrigerant	1.5 kg		
Certification Date	25.06.2019		



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: COMBO RSJA-23/300

Configure model				
Model name	COMBO RSJA-23/300			
Units	Indoor			
Climate zone (for heating)	n/a			
Heat Source	n/a			
Any additional heat sources	n/a			

General Data		
Power supply	1x230V 50Hz	
Off-peak product	No	



This information was generated by the HP KEYMARK database on 18 Mar 2022

Domestic Hot Water (DHW)

Average Climate

EN 12102-2	
Sound power level indoor	53 dB(A)

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	123 %	
СОР	3.01	
Heating up time	7:49 h:min	
Standby power input	30.6 W	
Reference hot water temperature	53.1 °C	
Mixed water at 40°C	354 l	

Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed