

	9			
Summary of	Thermia Atlas 18	Reg. No.	012-C700008	
Certificate Holder			-	
Name	Thermia			
Address	Snickaregatan 1	Zip		
City	Arvika	Country	Sweden	
Certification Body	RISE CERT	RISE CERT		
Name of testing laboratory	RISE	RISE		
Subtype title	Thermia Atlas 18	Thermia Atlas 18		
Heat Pump Type	Brine/Water and Water	er/Water		
Refrigerant	R410a	R410a		
Mass Of Refrigerant	1.95 kg			
Certification Date	02.03.2020	02.03.2020		
Testing basis	HP Keymark Scheme	Rules rev 7		



## **Model: ATLAS 18 400V**

General Data	
Power supply	3x400V 50Hz

Brine/Water Heat Pump

## Heating

EN 14511-4		
Starting and operating test	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.82 kW	15.68 kW
El input	1.57 kW	5.19 kW
СОР	4.98	3.02
Indoor water flow rate	1.36 m³/h	1.74 m³/h

## **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	228 %	168 %
Prated	15.05 kW	15.68 kW
SCOP	5.90	4.40
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.31 kW	13.87 kW
COP Tj = -7°C	5.04	3.38
Cdh	0.99	1.00
Pdh Tj = +2°C	8.10 kW	8.44 kW
COP Tj = +2°C	5.91	4.42
Cdh	0.99	0.99
Pdh Tj = +7°C	5.21 kW	5.43 kW
COP Tj = +7°C	6.65	5.10
Cdh	0.98	0.99
Pdh Tj = 12°C	4.41 kW	4.34 kW





I I I I I I I I I I I I I I I I I I I		
COP Tj = 12°C	6.49	5.25
Cdh	0.98	0.98
Pdh Tj = Tbiv	15.05 kW	15.68 kW
COP Tj = Tbiv	4.69	3.02
Pdh Tj = TOL	15.05 kW	15.68 kW
COP Tj = TOL	4.69	3.02
WTOL	65 °C	65 °C
Poff	15 W	15 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5270 kWh	7367 kWh

## Colder Climate


EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	36 dB(A)	36 dB(A)	

EN 14825		
	Low temperature	Medium temperature





$\eta_{s}$	238 %	174 %
Prated	15.05 kW	15.68 kW
SCOP	6.15	4.55
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	9.11 kW	9.49 kW
COP Tj = -7°C	5.93	4.22
Cdh	0.99	0.99
Pdh Tj = +2°C	5.54 kW	5.78 kW
COP Tj = +2°C	6.61	4.97
Cdh	0.98	0.99
Pdh Tj = +7°C	4.42 kW	4.35 kW
COP Tj = +7°C	6.58	5.32
Cdh	0.98	0.98
Pdh Tj = 12°C	4.39 kW	4.36 kW
COP Tj = 12°C	6.30	5.36
Cdh	0.98	0.98
Pdh Tj = Tbiv	15.05 kW	15.68 kW
COP Tj = Tbiv	4.69	3.02
Pdh Tj = TOL	15.05 kW	15.68 kW





The internation was generated by the international and account of the contract			
COP Tj = TOL	4.69	3.02	
WTOL	65 °C	65 °C	
Poff	15 W	15 W	
РТО	16 W	16 W	
PSB	16 W	16 W	
PCK	0 W	o w	
Supplementary Heater: Type of energy input	Electricity	Electricity	
Supplementary Heater: PSUP	0.00 kW	0.00 kW	
Annual energy consumption Qhe	6027 kWh	8487 kWh	

Water/Water Heat Pump

## Heating

EN 14511-4		
Starting and operating test	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	



EN 14511-2			
Low temperature Medium temperature			
Heat output	12.52 kW	17.55 kW	
El input	1.87 kW	4.59 kW	
СОР	6.68	3.82	
Indoor water flow rate	2.20 m³/h	1.94 m³/h	

## Average Climate


EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	319 %	223 %
Prated	12.52 kW	17.55 kW
SCOP	8.18	5.78
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.07 kW	15.53 kW
COP Tj = -7°C	7.10	4.23





9		milit database on 17 Dec 202
Cdh	0.99	1.00
Pdh Tj = +2°C	6.74 kW	9.45 kW
COP Tj = +2°C	8.44	5.84
Cdh	0.98	0.99
Pdh Tj = +7°C	5.85 kW	6.08 kW
$COPTj = +7^{\circ}C$	8.98	6.90
Cdh	0.98	0.98
Pdh Tj = 12°C	5.89 kW	5.72 kW
COP Tj = 12°C	9.30	7.07
Cdh	0.97	0.98
Pdh Tj = Tbiv	12.52 kW	17.55 kW
COP Tj = Tbiv	6.68	3.82
Pdh Tj = TOL	12.52 kW	17.55 kW
COP Tj = TOL	6.68	3.82
WTOL	65 °C	65 °C
Poff	15 W	15 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW





Annual energy consumption Qhe	3160 kWh	6273 kWh
-------------------------------	----------	----------

## Colder Climate

EN 12102-1			
Low temperature Medium temperature			
Sound power level indoor	36 dB(A)	36 dB(A)	

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	332 %	232 %
Prated	12.52 kW	17.55 kW
SCOP	8.49	6.01
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.58 kW	10.62 kW
COP Tj = -7°C	8.34	5.49
Cdh	0.98	0.99
Pdh Tj = +2°C	5.86 kW	6.47 kW
COP Tj = +2°C	9.06	6.68
Cdh	0.97	0.98
Pdh Tj = +7°C	5.88 kW	5.72 kW



# $$\operatorname{\textit{Page}}\ 10$$ of 19 This information was generated by the HP KEYMARK database on 17 Dec 2020

$COP Tj = +7^{\circ}C$	9.26	7.08
Cdh	0.97	0.98
Pdh Tj = 12°C	5.87 kW	5.75 kW
COP Tj = 12°C	9.12	7.29
Cdh	0.97	0.98
Pdh Tj = Tbiv	12.52 kW	17.55 kW
COP Tj = Tbiv	6.68	3.82
Pdh Tj = TOL	12.52 kW	17.55 kW
COP Tj = TOL	6.68	3.82
WTOL	65 °C	65 °C
Poff	15 W	15 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3633 kWh	7199 kWh



## **Model: ATLAS 18 DUO 400V**

General Data	
Power supply	3x400V 50Hz

Brine/Water Heat Pump

## Heating

EN 14511-4	
Starting and operating test	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.82 kW	15.68 kW
El input	1.57 kW	5.19 kW
СОР	4.98	3.02
Indoor water flow rate	1.36 m³/h	1.74 m³/h

## **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	228 %	168 %
Prated	15.05 kW	15.68 kW
SCOP	5.90	4.40
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.31 kW	13.87 kW
COP Tj = -7°C	5.04	3.38
Cdh	0.99	1.00
Pdh Tj = +2°C	8.10 kW	8.44 kW
COP Tj = +2°C	5.91	4.42
Cdh	0.99	0.99
Pdh Tj = +7°C	5.21 kW	5.43 kW
COP Tj = +7°C	6.65	5.10
Cdh	0.98	0.99
Pdh Tj = 12°C	4.41 kW	4.34 kW





ge.		
COP Tj = 12°C	6.49	5.25
Cdh	0.98	0.98
Pdh Tj = Tbiv	15.05 kW	15.68 kW
COP Tj = Tbiv	4.69	3.02
Pdh Tj = TOL	15.05 kW	15.68 kW
COP Tj = TOL	4.69	3.02
WTOL	65 °C	65 °C
Poff	15 W	15 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5270 kWh	7367 kWh

## Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)

EN 14825		
	Low temperature	Medium temperature





$\eta_{s}$	238 %	174 %
Prated	15.05 kW	15.68 kW
SCOP	6.15	4.55
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	9.11 kW	9.49 kW
COP Tj = -7°C	5.93	4.22
Cdh	0.99	0.99
Pdh Tj = +2°C	5.54 kW	5.78 kW
COP Tj = +2°C	6.61	4.97
Cdh	0.98	0.99
Pdh Tj = +7°C	4.42 kW	4.35 kW
COP Tj = +7°C	6.58	5.32
Cdh	0.98	0.98
Pdh Tj = 12°C	4.39 kW	4.36 kW
COP Tj = 12°C	6.30	5.36
Cdh	0.98	0.98
Pdh Tj = Tbiv	15.05 kW	15.68 kW
COP Tj = Tbiv	4.69	3.02
Pdh Tj = TOL	15.05 kW	15.68 kW





This information was generated by the HP KEYMARK database on 17 Dec 202			
COP Tj = TOL	4.69	3.02	
WTOL	65 °C	65 °C	
Poff	15 W	15 W	
РТО	16 W	16 W	
PSB	16 W	16 W	
PCK	0 W	0 W	
Supplementary Heater: Type of energy input	Electricity	Electricity	
Supplementary Heater: PSUP	0.00 kW	0.00 kW	
Annual energy consumption Qhe	6027 kWh	8487 kWh	

Water/Water Heat Pump

## Heating

EN 14511-4		
Starting and operating test	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	



EN 14511-2			
	Low temperature	Medium temperature	
Heat output	12.52 kW	17.55 kW	
El input	1.87 kW	4.59 kW	
СОР	6.68	3.82	
Indoor water flow rate	2.20 m³/h	1.94 m³/h	

## Average Climate


EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	319 %	223 %
Prated	12.52 kW	17.55 kW
SCOP	8.18	5.78
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.07 kW	15.53 kW
COP Tj = -7°C	7.10	4.23





This information was generated by the HP KEYMARK database on 17 Dec 2020				
Cdh	0.99	1.00		
Pdh Tj = +2°C	6.74 kW	9.45 kW		
$COP Tj = +2^{\circ}C$	8.44	5.84		
Cdh	0.98	0.99		
Pdh Tj = +7°C	5.85 kW	6.08 kW		
$COP Tj = +7^{\circ}C$	8.98	6.90		
Cdh	0.98	0.98		
Pdh Tj = 12°C	5.89 kW	5.72 kW		
COP Tj = 12°C	9.30	7.07		
Cdh	0.97	0.98		
Pdh Tj = Tbiv	12.52 kW	17.55 kW		
COP Tj = Tbiv	6.68	3.82		
Pdh Tj = TOL	12.52 kW	17.55 kW		
COP Tj = TOL	6.68	3.82		
WTOL	65 °C	65 °C		
Poff	15 W	15 W		
РТО	16 W	16 W		
PSB	16 W	16 W		
PCK	0 W	0 W		
Supplementary Heater: Type of energy input	Electricity	Electricity		
Supplementary Heater: PSUP	0.00 kW	0.00 kW		





Annual energy consumption Qhe	3160 kWh	6273 kWh

## Colder Climate

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	37 dB(A)	37 dB(A)		

EN 14825				
	Low temperature	Medium temperature		
$\eta_{s}$	332 %	232 %		
Prated	12.52 kW	17.55 kW		
SCOP	8.49	6.01		
Tbiv	-22 °C	-22 °C		
TOL	-22 °C	-22 °C		
Pdh Tj = -7°C	7.58 kW	10.62 kW		
COP Tj = -7°C	8.34	5.49		
Cdh	0.98	0.99		
Pdh Tj = +2°C	5.86 kW	6.47 kW		
COP Tj = +2°C	9.06	6.68		
Cdh	0.97	0.98		
Pdh Tj = +7°C	5.88 kW	5.72 kW		



# $$\operatorname{\textit{Page}}\ 19$$ of 19 This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = +7°C	9.26	7.08
Cdh	0.97	0.98
Pdh Tj = 12°C	5.87 kW	5.75 kW
COP Tj = 12°C	9.12	7.29
Cdh	0.97	0.98
Pdh Tj = Tbiv	12.52 kW	17.55 kW
COP Tj = Tbiv	6.68	3.82
Pdh Tj = TOL	12.52 kW	17.55 kW
COP Tj = TOL	6.68	3.82
WTOL	65 °C	65 °C
Poff	15 W	15 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3633 kWh	7199 kWh