

Page 1 of 8

This information was generated by the HP KEYMARK database on 22 Jun 2022

Login

Summary of	WPF 35	Reg. No.	011-1W0029
Certificate Holder		<u> </u>	
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPF 35		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	10 kg		
Certification Date	19.09.2016		
Testing basis	Heat pump scheme rules KEYMARK Rev 1.1		



Model: WPF 35

Configure model			
Model name	WPF 35		
Application	Heating (medium temp)		
Units	Indoor + Outdoor		
Climate Zone	Colder Climate + Warmer Climate		
Reversibility	No		
Cooling mode application (optional) n/a			

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	37.70 kW	34.49 kW	
El input	7.98 kW	11.47 kW	
СОР	4.72	3.01	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Shatting on the heat transfer medium now	passeu	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Warmer Climate



This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	60 dB(A)	60 dB(A)	
Sound power level outdoor	60 dB(A)	60 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	199 %	132 %	
Prated	38.00 kW	34.00 kW	
SCOP	5.17	3.50	
Tbiv	2 °C	2 °C	
TOL	2 °C	2 °C	
Pdh Tj = -7°C	0.00 kW	0.00 kW	
COP Tj = -7°C	0.00	0.00	
Pdh Tj = +2°C	38.00 kW	34.10 kW	
COP Tj = +2°C	4.78	2.82	
Pdh Tj = $+7^{\circ}$ C	38.50 kW	35.20 kW	
COP Tj = +7°C	5.12	3.24	
Pdh Tj = 12°C	39.10 kW	37.00 kW	
COP Tj = 12°C	5.69	4.08	
Pdh Tj = Tbiv	38.00 kW	34.10 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was gener	ated by the HP KEYMA	RK database on 22 Jun 2022
COP Tj = Tbiv	4.78	2.82
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	38.00 kW	34.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.78	2.82
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
РТО	7 W	7 W
PSB	7 W	7 W
PCK	7 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Colder Climate

Annual energy consumption Qhe

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	60 dB(A)	60 dB(A)	
Sound power level outdoor	60 dB(A)	60 dB(A)	

9834 kWh

13033 kWh

EN 14825			
	Low temperature	Medium temperature	





This information was generated by the HP KEYMARK database on 22 Jun 2022

3	•	TIMANN database on 22 jui
η_{s}	208 %	139 %
Prated	47.00 kW	43.00 kW
SCOP	5.41	3.66
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	38.80 kW	35.80 kW
COP Tj = -7°C	5.38	3.48
Pdh Tj = $+2^{\circ}$ C	39.10 kW	36.70 kW
COP Tj = +2°C	5.67	3.91
Pdh Tj = +7°C	39.30 kW	37.40 kW
COP Tj = +7°C	5.90	4.32
Pdh Tj = 12°C	39.30 kW	37.90 kW
COP Tj = 12°C	5.94	4.66
Pdh Tj = Tbiv	38.60 kW	35.30 kW
COP Tj = Tbiv	5.26	3.25
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	38.60 kW	34.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.26	2.82
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C





Poff	o w	o w
РТО	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	9.32 kW	9.15 kW
Annual energy consumption Qhe	21594 kWh	28986 kWh

Average Climate

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	60 dB(A)	60 dB(A)		
Sound power level outdoor	60 dB(A)	60 dB(A)		

EN 14825			
	Low temperature	Medium temperature	
η_{s}	200 %	133 %	
Prated	38.00 kW	34.00 kW	
SCOP	5.19	3.52	
Tbiv	-10 °C	-10 °C	
TOL	-10 °C	-10 °C	
TOL	-10 ·C	-10 °C	





This information was generated by the HP KEYMARK database on 22 Jun 2022

This information was generated by the HF KETMAKK database on 22 Juli 2022				
Pdh Tj = -7° C	38.10 kW	34.50 kW		
$COP Tj = -7^{\circ}C$	4.84	2.95		
Pdh Tj = +2°C	38.60 kW	35.80 kW		
COP Tj = +2°C	5.20	3.50		
Pdh Tj = $+7^{\circ}$ C	39.00 kW	36.70 kW		
$COP Tj = +7^{\circ}C$	5.56	2.92		
Pdh Tj = 12°C	39.30 kW	37.50 kW		
COP Tj = 12°C	5.96	4.42		
Pdh Tj = Tbiv	38.00 kW	34.10 kW		
COP Tj = Tbiv	4.75	2.82		
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	38.00 kW	34.10 kW		
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.78	2.82		
Rated airflow rate	0 m³/h	0 m³/h		
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90		
WTOL	60 °C	60 °C		
Poff	0 W	o w		
РТО	7 W	7 W		
PSB	7 W	7 W		
РСК	74 W	74 W		
Supplementary Heater: Type of energy input	Electricity	Electricity		
Supplementary Heater: PSUP	0.00 kW	0.00 kW		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}8 of 8 This information was generated by the HP KEYMARK database on 22 Jun 2022

Annual energy consumption Qhe	15136 kWh	20029 kWh
-------------------------------	-----------	-----------