

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	LWD 50A/SX	Reg. No.	041-K001-43
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Global Limited		
Subtype title	LWD 50A/SX		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	0.95 kg		
Certification Date	24.11.2020		
Testing basis	HP Keymark Scheme Rules Rev 08		

Model: LWD 50A/SX-HMD

Configure model	
Model name	LWD 50A/SX-HMD
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.85 kW	6.04 kW
El input	1.53 kW	2.01 kW
COP	4.46	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	152 %	127 %
Prated	6.37 kW	5.91 kW
SCOP	3.88	3.25
Tbiv	-4 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.57 kW	4.11 kW
COP Tj = -7°C	3.04	2.28
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	5.52 kW	5.36 kW
COP Tj = +2°C	3.94	3.23
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	7.03 kW	6.81 kW
COP Tj = +7°C	4.87	4.32
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	7.54 kW	7.51 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	5.54	5.36
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	4.90 kW	4.55 kW
COP Tj = Tbiv	3.35	2.57
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.18 kW	3.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.81	2.05
WTOL	62 °C	1 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.19 kW	2.19 kW
Annual energy consumption Qhe	3388 kWh	3762 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 18 Mar 2022

η_s	189 %	155 %
Prated	7.07 kW	6.54 kW
SCOP	4.79	3.95
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.47 kW	5.16 kW
COP Tj = +2°C	3.70	2.62
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	6.94 kW	6.40 kW
COP Tj = +7°C	4.69	3.56
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	7.51 kW	7.41 kW
COP Tj = 12°C	5.53	5.01
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	6.06 kW	5.60 kW
COP Tj = Tbiv	4.15	2.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.47 kW	5.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.70	2.62
WTOL	62 °C	62 °C
Poff	10 W	10 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.38 kW
Annual energy consumption Q _{he}	1971 kWh	2211 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	135 %	114 %
Prated	5.43 kW	4.98 kW
SCOP	3.44	2.93
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	4.64 kW	4.31 kW
COP T _j = -7°C	3.19	2.58

This information was generated by the HP KEYMARK database on 18 Mar 2022

Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.55 kW	5.44 kW
COP Tj = +2°C	4.07	3.51
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	7.08 kW	6.97 kW
COP Tj = +7°C	4.93	4.63
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	7.54 kW	7.56 kW
COP Tj = 12°C	5.29	5.39
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	4.00 kW	3.67 kW
COP Tj = Tbiv	2.84	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.94 kW	2.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.18	1.61
WTOL	62 °C	62 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.43 kW	4.98 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

Annual energy consumption Q_{he}	3888 kWh	4185 kWh
$P_{dh} T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	3.61	3.30
$COP T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	2.60	1.97
$C_{dh} T_j = -15^{\circ}\text{C}$	1.00	1.00

Model: LWD 50A/SX-HTD S

Configure model	
Model name	LWD 50A/SX-HTD S
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.85 kW	6.04 kW
El input	1.53 kW	2.01 kW
COP	4.46	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	152 %	127 %
Prated	6.37 kW	5.91 kW
SCOP	3.88	3.25
Tbiv	-4 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.57 kW	4.11 kW
COP Tj = -7°C	3.04	2.28
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	5.52 kW	5.36 kW
COP Tj = +2°C	3.94	3.23
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	7.03 kW	6.81 kW
COP Tj = +7°C	4.87	4.32
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	7.54 kW	7.51 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	5.54	5.36
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	4.90 kW	4.55 kW
COP Tj = Tbiv	3.35	2.57
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.18 kW	3.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.81	2.05
WTOL	62 °C	1 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.19 kW	2.19 kW
Annual energy consumption Qhe	3388 kWh	3762 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 18 Mar 2022

η_s	189 %	155 %
Prated	7.07 kW	6.54 kW
SCOP	4.79	3.95
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.47 kW	5.16 kW
COP Tj = +2°C	3.70	2.62
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	6.94 kW	6.40 kW
COP Tj = +7°C	4.69	3.56
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	7.51 kW	7.41 kW
COP Tj = 12°C	5.53	5.01
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	6.06 kW	5.60 kW
COP Tj = Tbiv	4.15	2.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.47 kW	5.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.70	2.62
WTOL	62 °C	62 °C
Poff	10 W	10 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.38 kW
Annual energy consumption Q _{he}	1971 kWh	2211 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	135 %	114 %
Prated	5.43 kW	4.98 kW
SCOP	3.44	2.93
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	4.64 kW	4.31 kW
COP T _j = -7°C	3.19	2.58

This information was generated by the HP KEYMARK database on 18 Mar 2022

Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.55 kW	5.44 kW
COP Tj = +2°C	4.07	3.51
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	7.08 kW	6.97 kW
COP Tj = +7°C	4.93	4.63
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	7.54 kW	7.56 kW
COP Tj = 12°C	5.29	5.39
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	4.00 kW	3.67 kW
COP Tj = Tbiv	2.84	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.94 kW	2.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.18	1.61
WTOL	62 °C	62 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.43 kW	4.98 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

Annual energy consumption Q_{he}	3888 kWh	4185 kWh
$P_{dh} T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	3.61	3.30
$COP T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	2.60	1.97
$C_{dh} T_j = -15^{\circ}\text{C}$	1.00	1.00