

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	AW-TDF300-H31	Reg. No.	ICIM-PDC-000035-00
Certificate Holder			
Name	Airwell Residential		
Address	10, rue du Fort de Saint Cyr	Zip	78180
City	Montigny le Bretonneux	Country	France
Certification Body	ICIM S.p.A.		
Name of testing laboratory	-- TRANSITION RULES --		
Subtype title	AW-TDF300-H31		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass Of Refrigerant	1.5 kg		
Certification Date	20.06.2019		

Model: AW-TDF300-H31

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

EN 12102-2

Sound power level indoor	53 dB(A)
--------------------------	----------

EN 16147

Declared load profile	XL
Efficiency η_{DHW}	123 %
COP	3.01
Heating up time	7:49 h:min
Standby power input	30.6 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	354 l

Operating test

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed