

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Jäspi Inverter M8	Reg. No.	012-SC0651-18
Certificate Holder			
Name	Kaukora		
Address	Tuotekatu 11	Zip	FI-21200
City	Raisio	Country	Finland
Certification Body	RISE CERT		
Name of testing laboratory	AIT		
Subtype title	Jäspi Inverter M8		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.6 kg		

Model: Jäspi Inverter M8

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.86 kW	3.50 kW
El input	0.83 kW	1.17 kW
COP	4.65	2.99
Indoor water flow rate	0.66 m ³ /h	0.38 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	127 %
Prated	8.20 kW	7.00 kW
SCOP	4.37	3.25
Tbiv	-8 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.40 kW	6.30 kW
COP Tj = -7°C	2.92	1.94
Pdh Tj = +2°C	4.50 kW	3.90 kW
COP Tj = +2°C	4.30	3.11
Pdh Tj = +7°C	2.90 kW	2.60 kW
COP Tj = +7°C	5.41	4.42
Pdh Tj = 12°C	3.50 kW	3.70 kW
COP Tj = 12°C	6.51	5.93
Pdh Tj = Tbiv	7.40 kW	6.60 kW
COP Tj = Tbiv	2.86	1.83

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	6.80 kW	5.90 kW
COP Tj = TOL	2.67	1.86
Cdh	0.96	0.97
WTOL	58 °C	58 °C
Poff	2 W	2 W
PTO	15 W	10 W
PSB	15 W	15 W
PCK	20 W	20 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.40 kW	1.10 kW
Annual energy consumption Qhe	3882 kWh	4447 kWh