

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	EDGE EVO 61 71 81 1Ph	Reg. No.	ICIM-PDC-000045-00
Certificate Holder			
Name	Clivet s.p.a.		
Address	Via camp lonc 25 c.ap.	Zip	I-32032
City	z.i. Villapaiera - Feltre (BL)	Country	Italy
Certification Body	ICIM S.p.A.		
Subtype title	EDGE EVO 61 71 81 1Ph		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2.8 kg		
Certification Date	07.11.2019		
Testing basis	HP KEYMARK certification scheme rules rev. no. 7		

# Model: ELFOEnergy Edge EVO 61 (230V/1Ph/50Hz)

Configure model	
Model name	ELFOEnergy Edge EVO 61 (230V/1Ph/50Hz)
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.30 kW	11.90 kW
EI input	2.56 kW	4.28 kW
COP	4.81	2.78

## Average Climate

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	169 %	126 %
Prated	12.00 kW	13.00 kW
SCOP	4.29	3.23
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.52 kW	11.29 kW
COP Tj = -7°C	2.88	2.05
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.50 kW	7.31 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.12 kW	4.96 kW
COP Tj = +7°C	5.74	4.25
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.23 kW	2.37 kW
COP Tj = 12°C	5.40	4.94
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.52 kW	11.29 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.88	2.05
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	12.01 kW	11.88 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.60	1.79
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	15 W	15 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption $Q_{he}$	5726 kWh	8164 kWh

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

# Model: ELFOEnergy Edge EVO 71 (230V/1Ph/50Hz)

Configure model	
Model name	ELFOEnergy Edge EVO 71 (230V/1Ph/50Hz)
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.10 kW	14.20 kW
El input	3.07 kW	5.16 kW
COP	4.60	2.75

## Average Climate

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	168 %	128 %
Prated	14.00 kW	14.00 kW
SCOP	4.27	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.47 kW	12.18 kW
COP Tj = -7°C	2.84	2.05
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.48 kW	7.84 kW
COP Tj = +2°C	4.19	3.18
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.04 kW	5.21 kW
COP Tj = +7°C	5.99	4.29
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.23 kW	2.57 kW
COP Tj = 12°C	5.30	5.14
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.47 kW	12.18 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = Tbiv	2.84	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.72 kW	11.68 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	1.74
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	26 W	26 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	2.10 kW
Annual energy consumption Qhe	6819 kWh	8724 kWh

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	71 dB(A)	71 dB(A)

# Model: ELFOEnergy Edge EVO 81 (230V/1Ph/50Hz)

Configure model	
Model name	ELFOEnergy Edge EVO 81 (230V/1Ph/50Hz)
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.30 kW	16.10 kW
El input	3.66 kW	5.90 kW
COP	4.45	2.73



## Average Climate

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	169 %	128 %
Prated	16.00 kW	15.00 kW
SCOP	4.30	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.15 kW	12.90 kW
COP Tj = -7°C	2.72	2.04
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.92 kW	8.25 kW
COP Tj = +2°C	4.17	3.21
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.64 kW	5.45 kW
COP Tj = +7°C	5.86	4.32
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.47 kW	2.57 kW
COP Tj = 12°C	6.28	5.12
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.15 kW	12.90 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.72	2.04
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	12.93 kW	11.16 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.41	1.65
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	41 W	41 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.10 kW	3.40 kW
Annual energy consumption $Q_{he}$	7687 kWh	9216 kWh

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	71 dB(A)	71 dB(A)