

This information was generated by the HP KEYMARK database on 6 Apr 2022

[Login](#)

Summary of	Austria Email LWPM 14	Reg. No.	012-C700119
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Austria Email LWPM 14		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R452B		
Mass of Refrigerant	2.75 kg		
Certification Date	22.09.2021		
Testing basis	EN 14511:2018, EN 14825:2018, EN 12102:2017		

Model: Austria Email LWPM 14

Configure model	
Model name	Austria Email LWPM 14
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.50 kW	12.90 kW
El input	1.77 kW	4.31 kW
COP	4.79	2.99

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 6 Apr 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	131 %
Prated	13.50 kW	13.30 kW
SCOP	4.51	3.36
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.90 kW	11.80 kW
COP Tj = -7°C	3.04	2.24
Cdh Tj = -7 °C	0.970	0.980
Pdh Tj = +2°C	7.30 kW	7.20 kW
COP Tj = +2°C	4.70	3.38
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = +7°C	8.60 kW	8.30 kW
COP Tj = +7°C	5.55	4.24
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	10.10 kW	9.80 kW

This information was generated by the HP KEYMARK database on 6 Apr 2022

COP Tj = 12°C	6.53	5.06
Cdh Tj = +12 °C	0.970	0.980
Pdh Tj = Tbiv	11.90 kW	11.80 kW
COP Tj = Tbiv	3.09	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.10 kW	11.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.07
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.970	0.980
WTOL	60 °C	60 °C
Poff	17 W	18 W
PTO	48 W	32 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	2.10 kW
Annual energy consumption Qhe	6187 kWh	8179 kWh