

Page 1 of 11

This information was generated by the HP KEYMARK database on 21 Jun 2022

Login

Summary of	WPF 10 basic	Reg. No.	011-1W0018
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPF 10 basic		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.6 kg		
Certification Date	25.08.2016		



Model: WPF 10 basic, all climates

Configure model		
Model name	WPF 10 basic, all climates	
Application	Heating (low temp)	
Units	Indoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	
Heat output	9.70 kW	
El input	2.22 kW	
СОР	4.37	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	failed
Starting and operating test	passed

Warmer Climate



EN 12102-1	
	Low temperature
Sound power level indoor	58 dB(A)

EN 14825	
	Low temperature
η_{s}	190 %
Prated	10.00 kW
SCOP	4.95
Tbiv	2 °C
TOL	0 °C
Pdh Tj = +2°C	9.70 kW
COP Tj = +2°C	4.37
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	9.80 kW
COP Tj = +7°C	4.76
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	10.00 kW
COP Tj = 12°C	5.44
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	9.70 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = Tbiv	4.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.37
WTOL	60 °C
Poff	0 W
PTO	78 W
PSB	3 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2617 kWh

Colder Climate

EN 12102-1	
	Low temperature
Sound power level indoor	58 dB(A)

EN 14825		
Low temperature		
199 %		
12.00 kW		
_		





<u> </u>	HE HE KLIMAKK database on 21 juli 202
SCOP	5.17
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	9.90 kW
$COP Tj = -7^{\circ}C$	5.07
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	10.00 kW
$COP Tj = +2^{\circ}C$	5.41
Cdh Tj = +2 °C	0.90
Pdh Tj = $+7^{\circ}$ C	10.10 kW
$COP Tj = +7^{\circ}C$	5.70
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	10.10 kW
COP Tj = 12°C	5.75
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	9.90 kW
COP Tj = Tbiv	4.93
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.93
WTOL	60 °C
Poff	o w





PTO	78 W
PSB	3 W
PCK	o w
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	2.40 kW
Annual energy consumption Qhe	5768 kWh
Pdh Tj = -15°C (if TOL<-20°C)	9.90
COP Tj = -15°C (if TOL<-20°C)	4.93
Cdh Tj = -15 °C	0.90

Average Climate

EN 12102-1		
	Low temperature	
Sound power level indoor	58 dB(A)	

EN 14825		
	Low temperature	
η_{s}	190 %	
Prated	10.00 kW	
SCOP	4.94	
Tbiv	-10 °C	





TOL	-20 °C
Pdh Tj = -7 °C	9.70 kW
$COPTj = -7^{\circ}C$	4.44
Cdh Tj = -7 °C	0.90
Pdh Tj = $+2^{\circ}$ C	9.80 kW
COP Tj = +2°C	4.85
Cdh Tj = +2 °C	0.90
Pdh Tj = $+7^{\circ}$ C	10.00 kW
COP Tj = +7°C	5.28
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	10.10 kW
COP Tj = 12°C	5.78
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	9.70 kW
COP Tj = Tbiv	4.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.37
WTOL	60 °C
Poff	o w
РТО	78 W
PSB	3 W



Page 8 of 11

PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	4053 kWh



Model: WPF 10 basic, average climates

Configure model			
Model name	WPF 10 basic, average climates		
Application	Heating (medium temp)		
Units	Indoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2			
Low temperature Medium temperature			
Heat output	9.70 kW	8.57 kW	
El input	2.22 kW	3.67 kW	
СОР	4.37	2.34	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	failed	
Starting and operating test	passed	

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	190 %	114 %
Prated	10.00 kW	9.00 kW
SCOP	4.94	3.06
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	8.70 kW
COP Tj = -7°C	4.44	2.46
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	9.80 kW	9.10 kW
COP Tj = +2°C	4.85	2.99
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	10.00 kW	9.30 kW
COP Tj = +7°C	5.28	3.42
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	10.10 kW	9.50 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 11 of 11

COP Tj = 12°C	5.78	3.95
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.70 kW	8.60 kW
COP Tj = Tbiv	4.37	2.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.70 kW	8.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.37	2.34
WTOL	60 °C	60 °C
Poff	o w	0 W
РТО	78 W	78 W
PSB	3 W	3 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4053 kWh	5788 kWh