

Page 1 of 7

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	TTL 25 A	Reg. No.	011-1W0049
Certificate Holder			
Name	tecalor GmbH		
Address	Fürstenbergerstr. 77	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TTL 25 A		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	4.7 kg		
Certification Date	01.11.2016		



Model: TTL 25 A

Configure model		
Model name	TTL 25 A	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.84 kW	7.36 kW
El input	1.54 kW	2.33 kW
СОР	5.09	3.16

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Shutting on the heat transfer medium now	passeu
Complete power supply failure	passed
Starting and operating test	passed

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	182 %	141 %
Prated	15.00 kW	15.00 kW
SCOP	4.63	3.59
Tbiv	-5 °C	-5 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	12.80 kW	13.80 kW
COP Tj = -7°C	2.98	2.48
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.72	3.51
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.00 kW	7.80 kW
COP Tj = +7°C	6.16	4.61
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	9.10 kW	9.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Cdh Tj = +12 °C $Pdh Tj = Tbiv$ 1	8.11 1.00 11.80 kW 3.16	6.66 1.00 12.50 kW 2.59
Pdh Tj = Tbiv	11.80 kW	12.50 kW
COP Tj = Tbiv	3.16	2.59
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.60 kW	13.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	2.28
WTOL 6	65 °C	65 °C
Poff 1	10 W	10 W
PTO 1	10 W	10 W
PSB 1	10 W	10 W
PCK 3	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP 0	0.21 kW	0.00 kW
Annual energy consumption Qhe 6	6689 kWh	8620 kWh

Warmer Climate

Low temperature	Medium temperature
219 %	163 %
8.00 kW	8.00 kW
5.54	4.14
	219 % 8.00 kW



 $$\operatorname{\textit{Page}}\xspace\:5\:\:\text{of}\:7\:$ This information was generated by the HP KEYMARK database on 18 Mar 2022

Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = $+2$ °C	8.30 kW	8.40 kW
$COP Tj = +2^{\circ}C$	4.14	2.74
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = $+7^{\circ}$ C	7.90 kW	7.50 kW
$COP Tj = +7^{\circ}C$	5.47	3.64
Cdh Tj = $+7$ °C	1.00	1.00
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	8.30 kW	8.40 kW
COP Tj = Tbiv	4.14	2.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.90 kW	18.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.61	2.31
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
РСК	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity





Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1930 kWh	2581 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_{s}	159 %	130 %
Prated	21.00 kW	22.00 kW
SCOP	4.05	3.33
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	12.60 kW	13.30 kW
COP Tj = -7°C	3.13	2.67
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.30 kW	8.30 kW
COP Tj = +2°C	5.15	3.92
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.00 kW	7.90 kW
COP Tj = +7°C	6.57	5.12
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	9.10 kW	9.00 kW



 $$\operatorname{\textsc{Page}}\ 7$$ of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

in a management		
COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	14.10 kW	15.20 kW
COP Tj = Tbiv	2.90	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.70 kW	18.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.66	2.37
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	20.59 kW	22.15 kW
Annual energy consumption Qhe	12796 kWh	16285 kWh
Pdh Tj = -15°C (if TOL<-20°C)	16.70	18.30
COP Tj = -15 °C (if TOL< -20 °C)	2.66	2.37
Cdh Tj = -15 °C	1.00	1.00
I .		