

$$\operatorname{\textit{Page}}\ 1$$ of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	LWC 60	Reg. No.	041-K001-27
Certificate Holder		· ·	
Name	ait-deutschland Gn	nbH	
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Energy & Communications Division		
Name of testing laboratory	WPZ		
Subtype title	LWC 60		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass Of Refrigerant	2.95 kg		
Certification Date	06.09.2019		



Model: LWC 60

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Starting and operating test	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	7.00 kW	6.30 kW	
El input	1.67 kW	2.74 kW	
СОР	4.20	2.30	
Indoor water flow rate	1.30 m³/h	1.30 m³/h	

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)





This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_{s}	148 %	120 %
Prated	6.29 kW	5.90 kW
SCOP	3.78	3.08
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.74 kW	4.42 kW
COP Tj = -7°C	2.91	2.02
Cdh	1.00	1.00
Pdh Tj = +2°C	6.23 kW	6.02 kW
COP Tj = +2°C	3.79	3.07
Cdh	0.99	1.00
Pdh Tj = +7°C	7.11 kW	6.99 kW
COP Tj = +7°C	4.78	4.16
Cdh	0.99	0.99
Pdh Tj = 12°C	8.09 kW	8.08 kW
COP Tj = 12°C	5.09	4.96
Cdh	0.99	0.99
Pdh Tj = Tbiv	5.08 kW	4.77 kW
COP Tj = Tbiv	3.14	2.23

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com






 $$\operatorname{\textit{Page}}4 of 7$ This information was generated by the HP KEYMARK database on 17 Dec 2020$

Pdh Tj = TOL	4.27 kW	3.92 kW
COP Tj = TOL	2.63	1.76
WTOL	60 °C	60 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.02 kW	1.98 kW
Annual energy consumption Qhe	3435 kWh	3957 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_{s}	180 %	146 %
Prated	7.63 kW	7.18 kW
SCOP	4.57	3.72
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.17 kW	5.74 kW
COP Tj = +2°C	3.57	2.44





Cdh	1.00	1.00
Pdh Tj = +7°C	7.06 kW	6.77 kW
$COP Tj = +7^{\circ}C$	4.59	3.37
Cdh	0.99	1.00
Pdh Tj = 12°C	8.07 kW	8.00 kW
COP Tj = 12°C	5.10	4.64
Cdh	0.99	0.99
Pdh Tj = Tbiv	6.54 kW	6.15 kW
COP Tj = Tbiv	4.00	2.77
Pdh Tj = TOL	6.17 kW	5.74 kW
COP Tj = TOL	3.57	2.44
WTOL	60 °C	60 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.46 kW	1.44 kW
Annual energy consumption Qhe	2229 kWh	2579 kWh

Colder Climate





$$\operatorname{\textit{Page}}$ 6 of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_{s}	130 %	106 %
Prated	5.46 kW	5.09 kW
SCOP	3.32	2.73
Tbiv	-12 °C	-12 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	4.79 kW	4.56 kW
COP Tj = -7°C	3.11	2.35
Cdh	0.99	1.00
Pdh Tj = +2°C	6.28 kW	6.13 kW
COP Tj = +2°C	3.93	3.38
Cdh	0.99	0.99
Pdh Tj = +7°C	7.14 kW	7.08 kW
COP Tj = +7°C	4.88	4.52
Cdh	0.99	0.99
Pdh Tj = 12°C	8.09 kW	8.12 kW
COP Tj = 12°C	4.88	5.01
Cdh	0.99	0.99
Pdh Tj = Tbiv	4.03 kW	3.75 kW
COP Tj = Tbiv	2.68	1.89

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}\ 7$$ of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	2.78 kW	2.63 kW
COP Tj = TOL	1.86	1.29
WTOL	60 °C	60 °C
Poff	10 W	10 W
РТО	10 W	10 W
PSB	10 W	10 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	5.46 kW	5.09 kW
Annual energy consumption Qhe	4060 kWh	4592 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.56	3.27
COP Tj = -15°C (if TOL<-20°C)	2.37	1.63
Cdh	1.00	1.00