Login

Summary of	DAIKIN ALTHERMA 3 H HT 16kW (300L)	Reg. No.	011-1W0359
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA 3 H HT 16kW (300L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	4.2 kg		
Certification Date	07.02.2020		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EPRA16DV3 / ETSH16P30D

Configure model	
Model name	EPRA16DV3 / ETSH16P30D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 14511-2

	+7°C/+12°C
El input	2.93 kW
Cooling capacity	7.88
EER	2.69

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	+7°C/+12°C
Pdesignc	7.9 kW
SEER	4.08
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	0.99
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	0.98
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	0.98
Poff	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Qce	1158 kWh

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45.6 dB(A)	45.6 dB(A)
Sound power level outdoor	54.0 dB(A)	54.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	140 %
Prated	12.5 kW	12.5 kW
SCOP	4.51	3.58
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.1 kW	11.2 kW
COP Tj = -7°C	3.12	2.47
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	6.7 kW	6.9 kW
COP Tj = +2°C	4.44	3.56
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	5.7 kW	6.9 kW
COP Tj = +7°C	5.84	4.44
Cdh Tj = +7 °C	1.0	1.0

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	6.0 kW	6.2 kW
COP Tj = 12°C	7.40	5.72
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.1 kW	12.2 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.1 kW	12.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	0.0 kW
Annual energy consumption Qhe	5726 kWh	7211 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	L
Efficiency ηDHW	101 %
COP	2.38
Heating up time	1:25 h:min
Standby power input	49.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	149.0 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EPRA16DW1 / ETSH16P30D

Configure model	
Model name	EPRA16DW1 / ETSH16P30D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.47 kW
COP	5.00	2.93

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 14511-2

	+7°C/+12°C
El input	2.93 kW
Cooling capacity	7.88
EER	2.69

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	+7°C/+12°C
Pdesignc	7.9 kW
SEER	3.98
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	0.98
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	0.97
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	0.97
Poff	31 W
PTO	33 W
PSB	42 W
PCK	0 W
Annual energy consumption Qce	1188 kWh

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45.6 dB(A)	45.6 dB(A)
Sound power level outdoor	54.0 dB(A)	54.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	140 %
Prated	12.5 kW	12.5 kW
SCOP	4.71	3.57
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.7 kW	11.1 kW
COP Tj = -7°C	2.97	2.43
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	6.9 kW	6.7 kW
COP Tj = +2°C	4.94	3.52
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	6.2 kW	6.5 kW
COP Tj = +7°C	5.95	4.54
Cdh Tj = +7 °C	1.0	1.0

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	5.6 kW	5.2 kW
COP Tj = 12°C	7.07	5.97
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	10.7 kW	12.5 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.1 kW	12.5 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.88	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.4 kW	0.0 kW
Annual energy consumption Qhe	5479 kWh	7236 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	L
Efficiency ηDHW	101 %
COP	2.38
Heating up time	1:25 h:min
Standby power input	49.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	149.0 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EPRA16DV3 / ETSHB16P30D

Configure model	
Model name	EPRA16DV3 / ETSHB16P30D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 14511-2

	+7°C/+12°C
El input	2.93 kW
Cooling capacity	7.88
EER	2.69

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	+7°C/+12°C
Pdesignc	7.9 kW
SEER	4.08
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	0.99
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	0.98
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	0.98
Poff	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Qce	1158 kWh

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	45.6 dB(A)	45.6 dB(A)
Sound power level outdoor	54.0 dB(A)	54.0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	177 %	140 %
Prated	12.5 kW	12.5 kW
SCOP	4.51	3.58
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.1 kW	11.2 kW
COP Tj = -7°C	3.12	2.47
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	6.7 kW	6.9 kW
COP Tj = +2°C	4.44	3.56
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	5.7 kW	6.9 kW
COP Tj = +7°C	5.84	4.44
Cdh Tj = +7 °C	1.0	1.0

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	6.0 kW	6.2 kW
COP Tj = 12°C	7.40	5.72
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.1 kW	12.2 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.1 kW	12.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	0.0 kW
Annual energy consumption Qhe	5726 kWh	7211 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	L
Efficiency ηDHW	101 %
COP	2.38
Heating up time	1:25 h:min
Standby power input	49.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	149.0 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EPRA16DW1 / ETSHB16P30D

Configure model	
Model name	EPRA16DW1 / ETSHB16P30D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.47 kW
COP	5.00	2.93

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 14511-2

	+7°C/+12°C
El input	2.93 kW
Cooling capacity	7.88
EER	2.69

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	+7°C/+12°C
Pdesignc	7.9 kW
SEER	3.98
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	0.98
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	0.97
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	0.97
Poff	31 W
PTO	33 W
PSB	42 W
PCK	0 W
Annual energy consumption Qce	1188 kWh

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45.6 dB(A)	45.6 dB(A)
Sound power level outdoor	54.0 dB(A)	54.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	140 %
Prated	12.5 kW	12.5 kW
SCOP	4.71	3.57
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.7 kW	11.1 kW
COP Tj = -7°C	2.97	2.43
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	6.9 kW	6.7 kW
COP Tj = +2°C	4.94	3.52
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	6.2 kW	6.5 kW
COP Tj = +7°C	5.95	4.54
Cdh Tj = +7 °C	1.0	1.0

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	5.6 kW	5.2 kW
COP Tj = 12°C	7.07	5.97
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	10.7 kW	12.5 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.1 kW	12.5 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.88	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.4 kW	0.0 kW
Annual energy consumption Qhe	5479 kWh	7236 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	L
Efficiency ηDHW	101 %
COP	2.38
Heating up time	1:25 h:min
Standby power input	49.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	149.0 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EPRA16DV3 / ETSX16P30D

Configure model	
Model name	EPRA16DV3 / ETSX16P30D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 14511-2

	+7°C/+12°C
El input	2.93 kW
Cooling capacity	7.88
EER	2.69

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	+7°C/+12°C
Pdesignc	7.9 kW
SEER	4.08
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	0.99
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	0.98
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	0.98
Poff	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Qce	1158 kWh

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45.6 dB(A)	45.6 dB(A)
Sound power level outdoor	54.0 dB(A)	54.0 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	180 %	142 %
Prated	12.5 kW	12.5 kW
SCOP	4.57	3.62
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.1 kW	11.2 kW
COP Tj = -7°C	3.12	2.47
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	6.7 kW	6.9 kW
COP Tj = +2°C	4.44	3.56
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	5.7 kW	6.9 kW
COP Tj = +7°C	5.84	4.44
Cdh Tj = +7 °C	1.0	1.0

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	6.0 kW	6.2 kW
COP Tj = 12°C	7.40	5.72
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.1 kW	12.2 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.1 kW	12.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	0.0 kW
Annual energy consumption Qhe	5649 kWh	7134 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	L
Efficiency ηDHW	101 %
COP	2.38
Heating up time	1:25 h:min
Standby power input	49.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	149.0 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EPRA16DW1 / ETSX16P30D

Configure model	
Model name	EPRA16DW1 / ETSX16P30D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.47 kW
COP	5.00	2.93

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 14511-2

	+7°C/+12°C
El input	2.93 kW
Cooling capacity	7.88
EER	2.69

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	+7°C/+12°C
Pdesignc	7.9 kW
SEER	3.98
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	0.98
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	0.97
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	0.97
Poff	31 W
PTO	33 W
PSB	42 W
PCK	0 W
Annual energy consumption Qce	1188 kWh

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	45.6 dB(A)	45.6 dB(A)
Sound power level outdoor	54.0 dB(A)	54.0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	190 %	142 %
Prated	12.5 kW	12.5 kW
SCOP	4.81	3.63
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.7 kW	11.1 kW
COP Tj = -7°C	2.97	2.43
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	6.9 kW	6.7 kW
COP Tj = +2°C	4.94	3.52
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	6.2 kW	6.5 kW
COP Tj = +7°C	5.95	4.54
Cdh Tj = +7 °C	1.0	1.0

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	5.6 kW	5.2 kW
COP Tj = 12°C	7.07	5.97
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	10.7 kW	12.5 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.1 kW	12.5 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.88	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.4 kW	0.0 kW
Annual energy consumption Qhe	5366 kWh	7122 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	L
Efficiency ηDHW	101 %
COP	2.38
Heating up time	1:25 h:min
Standby power input	49.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	149.0 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EPRA16DV3 / ETSXB16P30D

Configure model	
Model name	EPRA16DV3 / ETSXB16P30D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 14511-2

	+7°C/+12°C
El input	2.93 kW
Cooling capacity	7.88
EER	2.69

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	+7°C/+12°C
Pdesignc	7.9 kW
SEER	4.08
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	0.99
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	0.98
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	0.98
Poff	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Qce	1158 kWh

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	45.6 dB(A)	45.6 dB(A)
Sound power level outdoor	54.0 dB(A)	54.0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	180 %	142 %
Prated	12.5 kW	12.5 kW
SCOP	4.57	3.62
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.1 kW	11.2 kW
COP Tj = -7°C	3.12	2.47
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	6.7 kW	6.9 kW
COP Tj = +2°C	4.44	3.56
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	5.7 kW	6.9 kW
COP Tj = +7°C	5.84	4.44
Cdh Tj = +7 °C	1.0	1.0

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	6.0 kW	6.2 kW
COP Tj = 12°C	7.40	5.72
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.1 kW	12.2 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.1 kW	12.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	0.0 kW
Annual energy consumption Qhe	5649 kWh	7134 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	L
Efficiency ηDHW	101 %
COP	2.38
Heating up time	1:25 h:min
Standby power input	49.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	149.0 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: EPRA16DW1 / ETSXB16P30D

Configure model	
Model name	EPRA16DW1 / ETSXB16P30D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.47 kW
COP	5.00	2.93

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 14511-2

	+7°C/+12°C
El input	2.93 kW
Cooling capacity	7.88
EER	2.69

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	+7°C/+12°C
Pdesignc	7.9 kW
SEER	3.98
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	0.98
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	0.97
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	0.97
Poff	31 W
PTO	33 W
PSB	42 W
PCK	0 W
Annual energy consumption Qce	1188 kWh

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	45.6 dB(A)	45.6 dB(A)
Sound power level outdoor	54.0 dB(A)	54.0 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	190 %	142 %
Prated	12.5 kW	12.5 kW
SCOP	4.81	3.63
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.7 kW	11.1 kW
COP Tj = -7°C	2.97	2.43
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	6.9 kW	6.7 kW
COP Tj = +2°C	4.94	3.52
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	6.2 kW	6.5 kW
COP Tj = +7°C	5.95	4.54
Cdh Tj = +7 °C	1.0	1.0

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = 12°C	5.6 kW	5.2 kW
COP Tj = 12°C	7.07	5.97
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	10.7 kW	12.5 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.1 kW	12.5 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.88	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.4 kW	0.0 kW
Annual energy consumption Qhe	5366 kWh	7122 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	L
Efficiency ηDHW	101 %
COP	2.38
Heating up time	1:25 h:min
Standby power input	49.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	149.0 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.