

Page 1 of 11

This information was generated by the HP KEYMARK database on 22 Jun 2022

<u>Login</u>

Summary of	VITOCAL 100 A- (AF) 16/18	Reg. No.	ICIM-PDC-000088-00		
Certificate Holder					
Name	Viessmann Werke Allendorf Gmb	Viessmann Werke Allendorf GmbH			
Address	Viessmannstraße 1	Viessmannstraße 1 Zip 35107			
City	Allendorf/Eder	Country	Germany		
Certification Body	ICIM S.p.A.				
Subtype title	VITOCAL 100 A- (AF) 16/18				
Heat Pump Type	Outdoor Air/Water				
Refrigerant	R32				
Mass of Refrigerant	4 kg				
Certification Date	25.06.2020				
Testing basis	HP KEYMARK certification schem	e rules rev. no. 7	7		



Model: AWO-M-AC (AF) 101.A16

Configure model		
Model name	AWO-M-AC (AF) 101.A16	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.30 kW	14.89 kW
El input	3.49 kW	5.07 kW
СОР	4.67	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling





EN 14511-2	
	+7°C/+12°C
El input	4.38 kW
Cooling capacity	13.80
EER	3.15

EN 14825





	+7°C/+12°C
Pdesignc	13.80 kW
SEER	4.80
Pdc Tj = 35°C	13.80 kW
EER Tj = 35°C	3.15
Pdc Tj = 30°C	10.17 kW
EER Tj = 30°C	4.36
Cdc	1.0
Pdc Tj = 25°C	6.47 kW
EER Tj = 25°C	5.30
Cdc	1.0
Pdc Tj = 20°C	5.53 kW
EER Tj = 20°C	6.53
Cdc	1.0
Poff	19 W
РТО	o w
PSB	19 W
PCK	30 W
Annual energy consumption Qce	1726 kWh

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	177 %	126 %
Prated	14.00 kW	13.00 kW
SCOP	4.49	3.22
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	12.00 kW	11.50 kW
COP Tj = -7°C	2.88	2.09
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.30 kW	6.90 kW
COP Tj = +2°C	4.33	3.06
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	5.70 kW	5.50 kW
COP Tj = +7°C	5.83	4.11
Cdh Tj = +7 °C	0.98	0.97

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



	<u> </u>	· · · · · · · · · · · · · · · · · · ·
Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.12	6.30
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.00 kW	11.50 kW
COP Tj = Tbiv	2.88	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	11.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.94
WTOL	60 °C	60 °C
Poff	19 W	19 W
РТО	19 W	19 W
PSB	19 W	19 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6210 kWh	8359 kWh



Model: AWO-AC (AF) 101.A16

Configure model		
Model name	AWO-AC (AF) 101.A16	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2				
	Low temperature	Medium temperature		
Heat output	16.30 kW	14.89 kW		
El input	3.49 kW	5.07 kW		
СОР	4.67	2.94		

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Cooling





EN 14511-2		
	+7°C/+12°C	
El input	4.38 kW	
Cooling capacity	13.80	
EER	3.15	

EN 14825





+7°C/+12°C 13.80 kW **Pdesignc SEER** 4.80 $Pdc Tj = 35^{\circ}C$ 13.80 kW 3.15 EER Tj = 35°C $Pdc Tj = 30^{\circ}C$ 10.17 kW EER Tj = 30°C 4.36 Cdc 1.0 $Pdc Tj = 25^{\circ}C$ 6.47 kW 5.30 EER Tj = 25°C Cdc 1.0 $Pdc Tj = 20^{\circ}C$ 5.53 kW EER Tj = 20°C 6.53 Cdc 1.0 Poff 19 W PTO 0 W **PSB** 19 W **PCK** 30 W Annual energy consumption Qce 1726 kWh

Average Climate





EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	dB(A)	dB(A)		
Sound power level outdoor	68 dB(A)	68 dB(A)		

EN 14825				
	Low temperature	Medium temperature		
η_{s}	177 %	126 %		
Prated	14.00 kW	13.00 kW		
SCOP	4.49	3.22		
Tbiv	-7 °C	-7 °C		
TOL	-20 °C	-15 °C		
Pdh Tj = -7°C	12.00 kW	11.50 kW		
COP Tj = -7°C	2.88	2.09		
Cdh Tj = -7 °C	1.00	1.00		
Pdh Tj = +2°C	7.30 kW	6.90 kW		
$COP Tj = +2^{\circ}C$	4.33	3.06		
Cdh Tj = +2 °C	1.00	1.00		
Pdh Tj = +7°C	5.70 kW	5.50 kW		
COP Tj = +7°C	5.83	4.11		
Cdh Tj = +7 °C	0.98	0.97		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.12	6.30
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	12.00 kW	11.50 kW
COP Tj = Tbiv	2.88	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.70 kW	11.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.94
WTOL	60 °C	60 °C
Poff	19 W	19 W
PTO	19 W	19 W
PSB	19 W	19 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6210 kWh	8359 kWh