

#### Page 1 of 3

#### This information was generated by the HP KEYMARK database on 18 Mar 2022

#### Login

Summary of	VIESSMANN Vitocal 060-A (100 L) Typ T0P 060-A	Reg. No.	011-1W0318		
Certificate Holder					
Name	Viessmann Faulquemont SAS				
Address	Avenue André Gouy	Zip	F-57380		
City	Faulquemont	Country	France		
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH				
Subtype title	VIESSMANN Vitocal 060-A (100 L) Typ T0P 060-A				
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)				
Refrigerant	R134a				
Mass of Refrigerant	1.35 kg				
Certification Date	19.11.2019				



This information was generated by the HP KEYMARK database on 18 Mar 2022

# **Model: Vitocal 060-A TOP**

Configure model			
Model name	Vitocal 060-A T0P		
Units	Indoor		
Climate zone (for heating)	n/a		
Heat Source	Outdoor Air		
Any additional heat sources	n/a		

General Data		
Power supply	1x230V 50Hz	
Off-peak product	Yes	



## This information was generated by the HP KEYMARK database on 18 Mar 2022

### Domestic Hot Water (DHW)

## Average Climate

EN 12102-2		
Sound power level indoor	57 dB(A)	

EN 16147		
Declared load profile	S	
Efficiency ηDHW	103 %	
СОР	2.22	
Heating up time	4:20 h:min	
Standby power input	23.0 W	
Reference hot water temperature	53.5 °C	
Mixed water at 40°C	63 I	

# Operating test

EN 16147			
Temperature operating range	passed		
Safety devices checking test	passed		
Condensate draining	passed		