

Summary of	DAIKIN ALTHERMA GEO	Reg. No.	011-1W0067
Certificate Holder			-
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA GEO		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.8 kg		
Certification Date	17.02.2017		
Testing basis	HP KEYMARK certification scheme rules V8		



Model: EGSQH10S18A9W

General Data		
Power supply	3x400V 50Hz	
Off-peak product	No	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	10.30 kW	8.92 kW	
El input	2.38 kW	3.35 kW	
СОР	4.33	2.66	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)



EN 14825			
	Low temperature	Medium temperature	
η_{s}	194 %	139 %	
Prated	10.40 kW	8.72 kW	
SCOP	5.06	3.68	
Tbiv	-9 °C	-9 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	9.12 kW	7.76 kW	
COP Tj = -7°C	4.40	2.91	
Cdh	1.00	1.00	
Pdh Tj = +2°C	5.77 kW	4.73 kW	
COP Tj = +2°C	5.22	3.73	
Cdh	1.00	1.00	
Pdh Tj = +7°C	3.82 kW	3.04 kW	
COP Tj = +7°C	5.55	4.18	
Cdh	1.00	1.00	
Pdh Tj = 12°C	2.71 kW	2.61 kW	
COP Tj = 12°C	5.55	4.73	
Cdh	0.93	0.94	
Pdh Tj = Tbiv	10.20 kW	8.46 kW	
COP Tj = Tbiv	4.17	2.87	





Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.10 kW	8.41 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.16	2.80
WTOL	35 °C	55 °C
Poff	20 W	20 W
РТО	37 W	37 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	0.30 kW	0.31 kW
Annual energy consumption Qhe	4260 kWh	4900 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147		
Declared load profile	L	
Standby power input	42.0 W	
Reference hot water temperature	52.0 °C	
Mixed water at 40°C	199	
СОР	2.28	
Efficiency ηDHW	93 %	
Heating up time	1:25 h:min	



