

Page 1 of 4 This information was generated by the HP KEYMARK database on 7 Jul 2022

Login

Summary of	Buderus Logatherm WPS 10-1	Reg. No.	011-1W0182	
Certificate Holder				
Name	Bosch Thermotechnik GmbH (Buderus)			
Address	Sophienstraße 30-32	Zip	35576	
City	Wetzlar	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für Konfori	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Buderus Logatherm WPS 10-1	Buderus Logatherm WPS 10-1		
Heat Pump Type	Brine/Water			
Refrigerant	R410A			
Mass of Refrigerant	2.4 kg			

This information was generated by the HP KEYMARK database on 7 Jul 2022

Model: Buderus Logatherm WPS 10-1

Configure model			
Model name	Buderus Logatherm WPS 10-1		
Application	Heating (medium temp)		
Units	Indoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	10.15 kW	9.33 kW	
El input	2.17 kW	3.22 kW	
СОР	4.68	2.90	

Average Climate



This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	51 dB(A)	51 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	190 %	136 %	
Prated	11.00 kW	11.00 kW	
SCOP	4.95	3.60	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	9.90 kW	9.30 kW	
COP Tj = -7°C	4.74	3.09	
Pdh Tj = +2°C	10.00 kW	9.50 kW	
COP Tj = +2°C	4.95	3.55	
Pdh Tj = +7°C	10.00 kW	9.60 kW	
$COP Tj = +7^{\circ}C$	5.14	3.98	
Pdh Tj = 12°C	10.10 kW	9.80 kW	
COP Tj = 12°C	5.34	4.41	
Pdh Tj = Tbiv	9.90 kW	9.30 kW	
COP Tj = Tbiv	4.74	3.09	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.90 kW	9.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.63	2.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	62 °C	62 °C
Poff	6 W	6 W
РТО	6 W	6 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.30 kW	1.30 kW
Annual energy consumption Qhe	4672 kWh	6022 kWh