

Summary of	Vitocal 2xx-G B06	Reg. No.	011-1W0285
Certificate Holder			
Name	Viessmann Wärmepumpe	en GmbH	
Address	Viessmannstr. 1	Zip	35107
City	Allendorf/Eder	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	Heat Pump Test Center WPZ		
Subtype title	Vitocal 2xx-G B06		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.4 kg		
Certification Date	11.07.2019		



## Model: VITOCAL 200-G BWC 201.B06

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	5.73 kW	5.11 kW	
El input	1.25 kW	1.94 kW	
СОР	4.60	1.63	
Indoor water flow rate	1.13 m³/h	0.61 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

## **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825			
		Low temperature	Medium temperature
Pdesignh	6.59 kW		
$\eta_{s}$	186 %	134 %	
Prated	6.59 kW	5.94 kW	-
SCOP	4.86	3.56	-
Tbiv	-7 °C	-7 °C	_
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	5.80 kW	5.23 kW	-
COP Tj = -7°C	4.61	3.01	
Cdh	0.99	0.99	-
Pdh Tj = +2°C	5.84 kW	5.43 kW	
COP Tj = +2°C	4.85	3.54	
Cdh	0.99	0.99	
Pdh Tj = +7°C	5.93 kW	5.59 kW	
COP Tj = +7°C	5.18	3.96	
Cdh	0.99	0.99	_





This information w	as generate		C database of	/	DCC 20
Pdh Tj = 12°C	5.98 kW	5.70 kW			
COP Tj = 12°C	5.45	4.41			
Cdh	0.99	0.99			
Pdh Tj = Tbiv	5.80 kW	5.23 kW			
COP Tj = Tbiv	4.61	3.01			
Pdh Tj = TOL	5.80 kW	5.21 kW			
COP Tj = TOL	4.55	2.85			
Cdh	0.99	0.99			
WTOL	65 °C	65 °C			
Poff	0 W	o w			
РТО	0 W	o w			
PSB	12 W	12 W			
PCK	o w	o w			
Supplementary Heater: Type of energy input	electric	electric			
Supplementary Heater: PSUP	0.80 kW	0.73 kW			
Backup Heater	0 kW		•		
Annual energy consumption Qhe	2802 kWh	3452 kWh			

## Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)



#### EN 14825

	Low temperature	Medium temperature
η <sub>s</sub>	189 %	141 %
Prated	5.70 kW	5.19 kW
SCOP	4.92	3.73
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.70 kW	5.20 kW
COP Tj = +2°C	5.18	2.80
Cdh	0.99	0.99
Pdh Tj = +7°C	5.84 kW	5.29 kW
COP Tj = +7°C	4.75	3.20
Cdh	0.99	0.99
Pdh Tj = 12°C	5.94 kW	5.61 kW
COP Tj = 12°C	5.18	4.06
Cdh	0.99	0.99
Pdh Tj = Tbiv	5.70 kW	5.19 kW
COP Tj = Tbiv	5.18	2.83
Pdh Tj = TOL	5.70 kW	5.19 kW
COP Tj = TOL	5.20	2.83
Cdh	0.99	0.99





WTOL	65 °C	65 °C
Poff	o w	o w
РТО	o w	0 W
PSB	12 W	12 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1574 kWh	1857 kWh

#### Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	184 %	133 %
Prated	9.63 kW	8.97 kW
SCOP	4.80	3.52
Tbiv	-7 °C	-7 °C
TOL	-22 °C	-22 °C





ins institution ras get		THE GOLDON SECTION
Pdh Tj = -7°C	5.88 kW	5.38 kW
COP Tj = -7°C	5.24	3.52
Cdh	0.99	0.99
Pdh Tj = +2°C	5.97 kW	5.60 kW
$COPTj = +2^{\circ}C$	5.53	4.04
Cdh	0.99	0.99
Pdh Tj = $+7^{\circ}$ C	5.99 kW	5.71 kW
$COPTj = +7^{\circ}C$	5.73	4.48
Cdh	0.99	0.99
Pdh Tj = 12°C	5.98 kW	5.78 kW
COP Tj = 12°C	5.76	4.82
Cdh	0.99	0.99
Pdh Tj = Tbiv	5.88 kW	5.38 kW
COP Tj = Tbiv	5.24	3.52
Pdh Tj = TOL	5.81 kW	5.20 kW
COP Tj = TOL	4.80	2.92
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	o w	o w
РТО	o w	o w
PSB	12 W	12 W
	1	



# $$\operatorname{\textit{Page}}\xspace$ 8 of 33 This information was generated by the HP KEYMARK database on 17 Dec 2020

PCK	o w	o w
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	3.82 kW	3.47 kW
Annual energy consumption Qhe	4939 kWh	6069 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.88	5.29
COP Tj = -15°C (if TOL $<$ -20°C)	5.11	2.92
Cdh	0.99	0.99



## Model: VITOCAL 200-G BWC 201.B06 SC

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.73 kW	5.11 kW
El input	1.25 kW	1.94 kW
СОР	4.60	1.63
Indoor water flow rate	1.13 m³/h	0.61 m³/h


EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825			
		Low temperature	Medium temperature
Pdesignh	6.59 kW		
$\eta_{s}$	186 %	134 %	
Prated	6.59 kW	5.94 kW	-
SCOP	4.86	3.56	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	-
Pdh Tj = -7°C	5.80 kW	5.23 kW	-
COP Tj = -7°C	4.61	3.01	
Cdh	0.99	0.99	
Pdh Tj = +2°C	5.84 kW	5.43 kW	
COP Tj = +2°C	4.85	3.54	
Cdh	0.99	0.99	
Pdh Tj = +7°C	5.93 kW	5.59 kW	
COP Tj = +7°C	5.18	3.96	
Cdh	0.99	0.99	





 $$\operatorname{\textit{Page}}\ 11$$  of 33 This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	5.98 kW	5.70 kW
COP Tj = 12°C	5.45	4.41
Cdh	0.99	0.99
Pdh Tj = Tbiv	5.80 kW	5.23 kW
COP Tj = Tbiv	4.61	3.01
Pdh Tj = TOL	5.80 kW	5.21 kW
COP Tj = TOL	4.55	2.85
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	0 W	o w
РТО	0 W	o w
PSB	12 W	12 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.80 kW	0.73 kW
Backup Heater	0 kW	
Annual energy consumption Qhe	2802 kWh	3452 kWh

#### Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)



#### EN 14825 Low temperature **Medium temperature** 189 % 141 % $\eta_s$ Prated 5.70 kW 5.19 kW **SCOP** 4.92 3.73 Tbiv 2°C 2°C TOL 2°C 2°C Pdh Tj = +2°C 5.70 kW 5.20 kW $COPTj = +2^{\circ}C$ 5.18 2.80 Cdh 0.99 0.99 Pdh Tj = $+7^{\circ}$ C 5.84 kW 5.29 kW $COP Tj = +7^{\circ}C$ 4.75 3.20 Cdh 0.99 0.99 Pdh Tj = 12°C 5.94 kW 5.61 kW $COP Tj = 12^{\circ}C$ 5.18 4.06 Cdh 0.99 0.99 5.70 kW Pdh Tj = Tbiv5.19 kW COP Tj = Tbiv 2.83 5.18 Pdh Tj = TOL5.70 kW 5.19 kW COPTj = TOL5.20 2.83 Cdh 0.99 0.99





 $$\operatorname{\textit{Page}}\ 13$$  of 33 This information was generated by the HP KEYMARK database on 17 Dec 2020

WTOL	65 °C	65 °C
Poff	o w	o w
РТО	o w	o w
PSB	12 W	12 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1574 kWh	1857 kWh

#### Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	184 %	133 %
Prated	9.63 kW	8.97 kW
SCOP	4.80	3.52
Tbiv	-7 °C	-7 °C
TOL	-22 °C	-22 °C





		ARK database on 17 Dec 2020
Pdh Tj = -7°C	5.88 kW	5.38 kW
COP Tj = -7°C	5.24	3.52
Cdh	0.99	0.99
Pdh Tj = +2°C	5.97 kW	5.60 kW
COP Tj = +2°C	5.53	4.04
Cdh	0.99	0.99
Pdh Tj = $+7$ °C	5.99 kW	5.71 kW
COP Tj = +7°C	5.73	4.48
Cdh	0.99	0.99
Pdh Tj = 12°C	5.98 kW	5.78 kW
COP Tj = 12°C	5.76	4.82
Cdh	0.99	0.99
Pdh Tj = Tbiv	5.88 kW	5.38 kW
COP Tj = Tbiv	5.24	3.52
Pdh Tj = TOL	5.81 kW	5.20 kW
COP Tj = TOL	4.80	2.92
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	o w	o w
РТО	o w	o w
PSB	12 W	12 W
	1	



# $$\operatorname{\textit{Page}}\ 15$$ of 33 This information was generated by the HP KEYMARK database on 17 Dec 2020

PCK	o w	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	3.82 kW	3.47 kW
Annual energy consumption Qhe	4939 kWh	6069 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.88	5.29
COP Tj = -15°C (if TOL $<$ -20°C)	5.11	2.92
Cdh	0.99	0.99



## Model: VITOCAL 222-G BWT 221.B06

General Data		
Power supply	3x400V 50Hz	
Off-peak product	Yes	

### Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	5.73 kW	5.11 kW	
El input	1.25 kW	1.94 kW	
СОР	4.60	1.63	
Indoor water flow rate	1.13 m³/h	0.61 m³/h	


EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

#### **Average Climate**



EN 12102-1		
Low temperature Medium temperature		
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825			
		Low temperature	Medium temperature
Pdesignh	6.59 kW		
$\eta_{s}$	186 %	134 %	
Prated	6.59 kW	5.94 kW	
SCOP	4.86	3.56	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	5.80 kW	5.23 kW	
COP Tj = -7°C	4.61	3.01	
Cdh	0.99	0.99	
Pdh Tj = +2°C	5.84 kW	5.43 kW	
COP Tj = +2°C	4.85	3.54	
Cdh	0.99	0.99	
Pdh Tj = +7°C	5.93 kW	5.59 kW	
COP Tj = +7°C	5.18	3.96	
Cdh	0.99	0.99	





		<u> </u>
Pdh Tj = 12°C	5.98 kW	5.70 kW
COP Tj = 12°C	5.45	4.41
Cdh	0.99	0.99
Pdh Tj = Tbiv	5.80 kW	5.23 kW
COP Tj = Tbiv	4.61	3.01
Pdh Tj = TOL	5.80 kW	5.21 kW
COP Tj = TOL	4.55	2.85
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	o w	0 W
РТО	o w	0 W
PSB	12 W	12 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.80 kW	0.73 kW
Backup Heater	0 kW	
Annual energy consumption Qhe	2802 kWh	3452 kWh

#### Warmer Climate



EN 12102-1			
Low temperature Medium temperature			
Sound power level indoor	40 dB(A)	40 dB(A)	

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	189 %	141 %
Prated	5.70 kW	5.19 kW
SCOP	4.92	3.73
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.70 kW	5.20 kW
COP Tj = +2°C	5.18	2.80
Cdh	0.99	0.99
Pdh Tj = +7°C	5.84 kW	5.29 kW
COP Tj = +7°C	4.75	3.20
Cdh	0.99	0.99
Pdh Tj = 12°C	5.94 kW	5.61 kW
COP Tj = 12°C	5.18	4.06
Cdh	0.99	0.99
Pdh Tj = Tbiv	5.70 kW	5.19 kW





COP Tj = Tbiv	5.18	2.83
Pdh Tj = TOL	5.70 kW	5.19 kW
COP Tj = TOL	5.20	2.83
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	o w	o w
РТО	o w	o w
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1574 kWh	1857 kWh

#### Colder Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	40 dB(A)	40 dB(A)	

	EN 14825	
	Low temperature	Medium temperature
$\eta_{S}$	184 %	133 %





 $$\operatorname{\textit{Page}}\xspace$  21 of 33 This information was generated by the HP KEYMARK database on 17 Dec 2020

I his information was g	enerated by the HP KEYM	IARK database on 17 Dec 2020
Prated	9.63 kW	8.97 kW
SCOP	4.80	3.52
Tbiv	-7 °C	-7 °C
TOL	-22 °C	-22 °C
Pdh Tj = $-7$ °C	5.88 kW	5.38 kW
$COP Tj = -7^{\circ}C$	5.24	3.52
Cdh	0.99	0.99
Pdh Tj = +2°C	5.97 kW	5.60 kW
$COPTj = +2^{\circ}C$	5.53	4.04
Cdh	0.99	0.99
Pdh Tj = +7°C	5.99 kW	5.71 kW
$COPTj = +7^{\circ}C$	5.73	4.48
Cdh	0.99	0.99
Pdh Tj = 12°C	5.98 kW	5.78 kW
COP Tj = 12°C	5.76	4.82
Cdh	0.99	0.99
Pdh Tj = Tbiv	5.88 kW	5.38 kW
COP Tj = Tbiv	5.24	3.52
Pdh Tj = TOL	5.81 kW	5.20 kW
COP Tj = TOL	4.80	2.92
Cdh	0.99	0.99
	<del>.</del>	





WTOL	65 °C	65 °C
Poff	0 W	o w
РТО	0 W	o w
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	3.82 kW	3.47 kW
Annual energy consumption Qhe	4939 kWh	6069 kWh
Pdh Tj = -15°C (if TOL $<$ -20°C)	5.88	5.29
COP Tj = $-15$ °C (if TOL< $-20$ °C)	5.11	2.92
Cdh	0.99	0.99

Domestic Hot Water (DHW)

Average Climate




EN 16147	
Declared load profile	XL
Efficiency ηDHW	130 %
СОР	3.14
Heating up time	2.10 h:min
Standby power input	63.0 W
Reference hot water temperature	54.1 °C
Mixed water at 40°C	293 I

#### Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	130 %
СОР	3.14
Heating up time	2.10 h:min
Standby power input	63.0 W
Reference hot water temperature	54.1 °C
Mixed water at 40°C	293 I

#### Colder Climate





 $$\operatorname{\textit{Page}}\xspace$  24 of 33 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency ηDHW	130 %
СОР	3.14
Heating up time	2.10 h:min
Standby power input	63.0 W
Reference hot water temperature	54.1 °C
Mixed water at 40°C	293 I



## Model: VITOCAL 222-G BWT 221.B06 SC

General Da	nta
Power supply	3x400V 50Hz
Off-peak product	Yes

#### Heating

	EN 14511-2	
	Low temperature	Medium temperature
Heat output	5.73 kW	5.11 kW
El input	1.25 kW	1.94 kW
СОР	4.60	1.63
Indoor water flow rate	1.13 m³/h	0.61 m³/h

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

#### **Average Climate**



	EN 12102-1	
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)

	EN 1482	5	
		Low temperature	Medium temperature
Pdesignh	6.59 kW		
$\eta_{s}$	186 %	134 %	
Prated	6.59 kW	5.94 kW	
SCOP	4.86	3.56	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	5.80 kW	5.23 kW	
COP Tj = -7°C	4.61	3.01	
Cdh	0.99	0.99	
Pdh Tj = +2°C	5.84 kW	5.43 kW	
COP Tj = +2°C	4.85	3.54	
Cdh	0.99	0.99	
Pdh Tj = +7°C	5.93 kW	5.59 kW	
COP Tj = +7°C	5.18	3.96	
Cdh	0.99	0.99	





COP Tj = 12°C  Cdh  0.99  0.99  Pdh Tj = Tbiv  5.80 kW  5.23 kW  COP Tj = Tbiv  4.61  3.01  Pdh Tj = TOL  5.80 kW  5.21 kW  COP Tj = TOL  4.55  2.85  Cdh  0.99  0.99  WTOL  65 °C  65 °C  Poff  0 W  0 W  PTO  0 W  0 W  PSB  12 W  12 W  PCK  0 W  0 W  Supplementary Heater: Type of energy input  Supplementary Heater: PSUP  0.80 kW  0.73 kW  Backup Heater		-	-
Cdh       0.99       0.99         Pdh Tj = Tbiv       5.80 kW       5.23 kW         COP Tj = Tbiv       4.61       3.01         Pdh Tj = TOL       5.80 kW       5.21 kW         COP Tj = TOL       4.55       2.85         Cdh       0.99       0.99         WTOL       65 °C       65 °C         Poff       0 W       0 W         PTO       0 W       0 W         PCK       0 W       0 W         Supplementary Heater: Type of energy input       electric       electric         Supplementary Heater: PSUP       0.80 kW       0.73 kW         Backup Heater       0 kW       0 kW	Pdh Tj = 12°C	5.98 kW	5.70 kW
Pdh Tj = Tbiv       5.80 kW       5.23 kW         COP Tj = Tbiv       4.61       3.01         Pdh Tj = TOL       5.80 kW       5.21 kW         COP Tj = TOL       4.55       2.85         Cdh       0.99       0.99         WTOL       65 °C       65 °C         Poff       0 W       0 W         PTO       0 W       0 W         PSB       12 W       12 W         PCK       0 W       0 W         Supplementary Heater: Type of energy input       electric         Supplementary Heater: PSUP       0.80 kW       0.73 kW         Backup Heater       0 kW	COP Tj = 12°C	5.45	4.41
COP Tj = Tbiv       4.61       3.01         Pdh Tj = TOL       5.80 kW       5.21 kW         COP Tj = TOL       4.55       2.85         Cdh       0.99       0.99         WTOL       65 °C       65 °C         Poff       0 W       0 W         PTO       0 W       0 W         PSB       12 W       12 W         PCK       0 W       0 W         Supplementary Heater: Type of energy input       electric         Supplementary Heater: PSUP       0.80 kW       0.73 kW         Backup Heater       0 kW	Cdh	0.99	0.99
Pdh Tj = TOL       5.80 kW       5.21 kW         COP Tj = TOL       4.55       2.85         Cdh       0.99       0.99         WTOL       65 °C       65 °C         Poff       0 W       0 W         PTO       0 W       0 W         PSB       12 W       12 W         PCK       0 W       0 W         Supplementary Heater: Type of energy input       electric         Supplementary Heater: PSUP       0.80 kW       0.73 kW         Backup Heater       0 kW	Pdh Tj = Tbiv	5.80 kW	5.23 kW
COP Tj = TOL  4.55  2.85  Cdh  0.99  0.99  WTOL  65 °C  65 °C  Poff  0 W  0 W  PTO  0 W  12 W  PCK  0 W  0 W  Supplementary Heater: Type of energy input  electric  Supplementary Heater: PSUP  0.80 kW  0 kW	COP Tj = Tbiv	4.61	3.01
Cdh       0.99       0.99         WTOL       65 °C       65 °C         Poff       0 W       0 W         PTO       0 W       0 W         PSB       12 W       12 W         PCK       0 W       0 W         Supplementary Heater: Type of energy input       electric         Supplementary Heater: PSUP       0.80 kW       0.73 kW         Backup Heater       0 kW	Pdh Tj = TOL	5.80 kW	5.21 kW
WTOL 65 °C 65 °C Poff 0 W 0 W PTO 0 W 0 W PSB 12 W 12 W PCK 0 W 0 W Supplementary Heater: Type of energy input electric Supplementary Heater: PSUP 0.80 kW 0.73 kW Backup Heater	COP Tj = TOL	4.55	2.85
Poff 0 W 0 W  PTO 0 W 0 W  PSB 12 W 12 W  PCK 0 W 0 W  Supplementary Heater: Type of energy input electric electric  Supplementary Heater: PSUP 0.80 kW 0.73 kW  Backup Heater 0 kW	Cdh	0.99	0.99
PTO 0 W 0 W  PSB 12 W 12 W  PCK 0 W 0 W  Supplementary Heater: Type of energy input electric electric  Supplementary Heater: PSUP 0.80 kW 0.73 kW  Backup Heater 0 kW	WTOL	65 °C	65 °C
PSB 12 W 12 W  PCK 0 W 0 W  Supplementary Heater: Type of energy input electric electric  Supplementary Heater: PSUP 0.80 kW 0.73 kW  Backup Heater 0 kW	Poff	0 W	0 W
PCK 0 W 0 W  Supplementary Heater: Type of energy input electric electric  Supplementary Heater: PSUP 0.80 kW 0.73 kW  Backup Heater 0 kW	РТО	0 W	0 W
Supplementary Heater: Type of energy input electric electric  Supplementary Heater: PSUP 0.80 kW 0.73 kW  Backup Heater 0 kW	PSB	12 W	12 W
Supplementary Heater: PSUP 0.80 kW 0.73 kW  Backup Heater 0 kW	PCK	0 W	0 W
Backup Heater 0 kW	Supplementary Heater: Type of energy input	electric	electric
	Supplementary Heater: PSUP	0.80 kW	0.73 kW
Annual energy consumption Qhe 2802 kWh 3452 kWh	Backup Heater	0 kW	
	Annual energy consumption Qhe	2802 kWh	3452 kWh

#### Warmer Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	189 %	141 %
Prated	5.70 kW	5.19 kW
SCOP	4.92	3.73
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.70 kW	5.20 kW
COP Tj = +2°C	5.18	2.80
Cdh	0.99	0.99
Pdh Tj = +7°C	5.84 kW	5.29 kW
COP Tj = +7°C	4.75	3.20
Cdh	0.99	0.99
Pdh Tj = 12°C	5.94 kW	5.61 kW
COP Tj = 12°C	5.18	4.06
Cdh	0.99	0.99
Pdh Tj = Tbiv	5.70 kW	5.19 kW





COP Tj = Tbiv	5.18	2.83
Pdh Tj = TOL	5.70 kW	5.19 kW
COP Tj = TOL	5.20	2.83
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	o w	o w
РТО	o w	o w
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1574 kWh	1857 kWh

#### Colder Climate


EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{S}$	184 %	133 %





Inis information was generated by the HP KEYMARK database on 17 Dec 2020			
Prated	9.63 kW	8.97 kW	
SCOP	4.80	3.52	
Tbiv	-7 °C	-7 °C	
TOL	-22 °C	-22 °C	
Pdh Tj = -7°C	5.88 kW	5.38 kW	
$COP Tj = -7^{\circ}C$	5.24	3.52	
Cdh	0.99	0.99	
Pdh Tj = $+2$ °C	5.97 kW	5.60 kW	
COP Tj = +2°C	5.53	4.04	
Cdh	0.99	0.99	
Pdh Tj = +7°C	5.99 kW	5.71 kW	
COP Tj = +7°C	5.73	4.48	
Cdh	0.99	0.99	
Pdh Tj = 12°C	5.98 kW	5.78 kW	
COP Tj = 12°C	5.76	4.82	
Cdh	0.99	0.99	
Pdh Tj = Tbiv	5.88 kW	5.38 kW	
COP Tj = Tbiv	5.24	3.52	
Pdh Tj = TOL	5.81 kW	5.20 kW	
COP Tj = TOL	4.80	2.92	
Cdh	0.99	0.99	





The state of the s	· · · · · · · · · · · · · · · · · · ·	
WTOL	65 °C	65 °C
Poff	0 W	0 W
РТО	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	3.82 kW	3.47 kW
Annual energy consumption Qhe	4939 kWh	6069 kWh
Pdh Tj = -15°C (if TOL<-20°C)	5.88	5.29
COP Tj = -15°C (if TOL $<$ -20°C)	5.11	2.92

0.99

0.99

Domestic Hot Water (DHW)

**Average Climate** 

Cdh




EN 16147		
Declared load profile	XL	
Efficiency ηDHW	130 %	
СОР	3.14	
Heating up time	2.10 h:min	
Standby power input	63.0 W	
Reference hot water temperature	54.1 °C	
Mixed water at 40°C	293 I	

#### Warmer Climate

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	130 %	
СОР	3.14	
Heating up time	2.10 h:min	
Standby power input	63.0 W	
Reference hot water temperature	54.1 °C	
Mixed water at 40°C	293 I	

#### Colder Climate





 $$\operatorname{\textit{Page}}\xspace$  33 of 33 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	130 %	
СОР	3.14	
Heating up time	2.10 h:min	
Standby power input	63.0 W	
Reference hot water temperature	54.1 °C	
Mixed water at 40°C	293 I	