

Page 1 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

<u>Login</u>

Summary of	CTC GSi 612 1x230V	Reg. No.	012-C700086	
Certificate Holder				
Name	Enertech CTC AB	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26	
City	Ljungby	Country	Sweden	
Certification Body	RISE CERT			
Subtype title	CTC GSi 612 1x230V			
Heat Pump Type	Brine/Water			
Refrigerant	R407c			
Mass of Refrigerant	2.3 kg			
Certification Date	30.11.2020			
Testing basis	HP Keymark Scheme 2017			



This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: CTC GSi 612 1x230V

Configure model		
Model name	CTC GSi 612 1x230V	
Application	Heating + DHW + low temp	
Units	Indoor	
Climate Zone	Colder Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	
Off-peak product	No	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	5.55 kW	6.20 kW	
El input	1.29 kW	2.34 kW	
СОР	4.31	2.65	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate




 $$\operatorname{\textit{Page}}\xspace$ 3 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	43 dB(A)	43 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	196 %	148 %
Prated	10.00 kW	12.00 kW
SCOP	5.10	3.90
Tbiv	-15 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	10.60 kW
COP Tj = -7°C	4.37	2.96
Pdh Tj = +2°C	5.40 kW	6.50 kW
COP Tj = +2°C	5.25	3.90
Pdh Tj = +7°C	3.40 kW	4.20 kW
COP Tj = +7°C	5.75	4.55
Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	6.10	5.24
Pdh Tj = Tbiv	11.80 kW	11.60 kW
COP Tj = Tbiv	3.68	2.73

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





general		
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	11.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.03	2.64
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.97	0.98
WTOL	65 °C	65 °C
Poff	23 W	23 W
РТО	o w	o w
PSB	23 W	23 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.40 kW
Annual energy consumption Qhe	4041 kWh	6369 kWh

Colder Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	43 dB(A)	43 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{S}	204 %	152 %
Prated	9.50 kW	11.80 kW



Page 5 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	5.30	4.00
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.70 kW	7.13 kW
COP Tj = -7°C	5.15	3.66
Pdh Tj = +2°C	3.50 kW	4.30 kW
$COPTj = +2^{\circ}C$	5.65	4.38
Pdh Tj = +7°C	2.40 kW	2.70 kW
$COPTj = +7^{\circ}C$	6.06	5.04
Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	6.06	5.33
Pdh Tj = Tbiv	9.50 kW	11.60 kW
COP Tj = Tbiv	4.21	2.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.50 kW	11.71 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.23	2.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	65 °C	65 °C
Poff	23 W	23 W
РТО	0 W	0 W
PSB	23 W	23 W
PCK	o w	o w



Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.10 kW
Annual energy consumption Qhe	4425 kWh	7225 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	96 %
СОР	2.40
Heating up time	1:49 h:min
Standby power input	23.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	232 I

Colder Climate





 $$\operatorname{\textit{Page}}\ 7$$ of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147		
Declared load profile	XL	
СОР	2.40	
Heating up time	1:49 h:min	
Standby power input	70.0 W	
Reference hot water temperature	54.0 °C	
Mixed water at 40°C	232 I	
Efficiency ηDHW	96 %	