

### Page 1 of 7

### This information was generated by the HP KEYMARK database on 18 Mar 2022

#### **Login**

Summary of	Assure Mono 12 16	Reg. No.	ICIM-PDC-000084-00	
Certificate Holder	Certificate Holder			
Name	BAXI Potterton Myson			
Address	Unit F 5&6, Calmount Park, Ballymount	Zip	Dublin 12	
City	Dublin	Country	Ireland	
Certification Body	ICIM S.p.A.			
Subtype title	Assure Mono 12 16			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R32			
Mass of Refrigerant	2.8 kg			
Certification Date	25.06.2020			
Testing basis	HP KEYMARK certification scheme rules rev. 7			



This information was generated by the HP KEYMARK database on 18 Mar 2022

# **Model: Assure Mono 12**

Configure model		
Model name	Assure Mono 12	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply 1x230V 50Hz		

## Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure pass	
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.30 kW	11.90 kW
El input	2.56 kW	4.28 kW
СОР	4.81	2.78

## **Average Climate**

#### EN 14825



 $$\operatorname{\textsc{Page}}\xspace$  3 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

	Low temperature	Medium temperature
$\eta_{s}$	169 %	126 %
Prated	12.00 kW	13.00 kW
SCOP	4.29	3.23
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.52 kW	11.29 kW
$COP Tj = -7^{\circ}C$	2.88	2.05
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = $+2$ °C	6.50 kW	7.31 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	4.12 kW	4.96 kW
$COP Tj = +7^{\circ}C$	5.74	4.25
Cdh Tj = $+7$ °C	0.90	0.90
Pdh Tj = 12°C	2.23 kW	2.37 kW
COP Tj = 12°C	5.40	4.94
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.52 kW	11.29 kW
COP Tj = Tbiv	2.88	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.01 kW	11.88 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}$4$  of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.79
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	15 W	15 W
PSB	9 W	9 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	5726 kWh	8164 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)



This information was generated by the HP KEYMARK database on 18 Mar 2022

# **Model: Assure Mono 16**

Configure model		
Model name	Assure Mono 16	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

## Heating

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test passed		

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.30 kW	16.10 kW
El input	3.66 kW	5.90 kW
СОР	4.45	2.73

## **Average Climate**

#### EN 14825





	Low temperature	Medium temperature
$\eta_{s}$	169 %	128 %
Prated	16.00 kW	15.00 kW
SCOP	4.30	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = $-7$ °C	14.15 kW	12.90 kW
COP Tj = $-7$ °C	2.72	2.04
Cdh Tj = -7 $^{\circ}$ C	0.90	0.90
Pdh Tj = $+2$ °C	8.92 kW	8.25 kW
$COP Tj = +2^{\circ}C$	4.17	3.21
Cdh Tj = $+2$ °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	5.64 kW	5.45 kW
$COP Tj = +7^{\circ}C$	5.86	4.32
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.47 kW	2.57 kW
COP Tj = 12°C	6.28	5.12
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.15 kW	12.90 kW
COP Tj = Tbiv	2.72	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL $<$ Tdesignh	12.93 kW	11.16 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 7 of 7 This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
РТО	41 W	41 W
PSB	9 W	9 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.10 kW	3.40 kW
Annual energy consumption Qhe	7687 kWh	9216 kWh

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	dB(A)	dB(A)	
Sound power level outdoor	71 dB(A)	71 dB(A)	