

## Page 1 of 4 This information was generated by the HP KEYMARK database on 27 Jan 2021

Summary of	BoxAir Inverter BA26IS-1	Reg. No.	037-0069-21
Certificate Holder			
Name	Master Therm tepelna cerpadla s.r.o.		
Address	Vaclavske namesti 819/43	Zip	110 00
City	Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	BoxAir Inverter BA26IS-1		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.3 kg		
Certification Date	26.01.2021		
Testing basis	HP Keymark scheme rules rev. no. 7		



This information was generated by the HP KEYMARK database on 27 Jan 2021

## **Model: BoxAir Inverter BA26IS-1**

General Data		
Power supply	1x230V 50Hz	

## Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	8.10 kW	7.28 kW	
El input	1.75 kW	2.46 kW	
СОР	4.63	2.96	
Indoor water flow rate	1.40 m³/h	0.78 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	naccod	
Shutting on the heat transfer medium now	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

## Average Climate



This information was generated by the HP KEYMARK database on 27 Jan 2021

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	48 dB(A)	48 dB(A)	
Sound power level outdoor	55 dB(A)	55 dB(A)	

EN 14825		
	Low temperature	e Medium temperature
$\eta_{s}$	168 %	126 %
Prated	6.51 kW	6.33 kW
SCOP	4.29	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.76 kW	5.60 kW
COP Tj = -7°C	2.59	1.94
Cdh	0.90	0.90
Pdh Tj = $+2$ °C	3.72 kW	3.50 kW
$COP Tj = +2^{\circ}C$	3.92	3.02
Cdh	0.90	0.90
Pdh Tj = +7°C	2.42 kW	2.33 kW
COP Tj = +7°C	6.53	4.69
Cdh	0.90	0.90

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 27 Jan 2021

Pdh Tj = 12°C	2.74 kW	2.78 kW
COP Tj = 12°C	7.82	5.93
Cdh	0.95	0.96
Pdh Tj = Tbiv	5.76 kW	5.60 kW
COP Tj = Tbiv	2.59	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.88 kW	5.66 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	1.82
WTOL	60 °C	60 °C
Poff	18 W	18 W
РТО	17 W	17 W
PSB	18 W	18 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.64 kW	0.67 kW
Annual energy consumption Qhe	3139 kWh	4039 kWh