

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	R32 monobloc 12 14 16 kW 1 phase & 3 phases	Reg. No.	011-1W0244
Certificate Holder			
Name	LG Electronics Inc.		
Address	84, Wanam-ro, seongsan-gu	Zip	51554
City	Changwon-si	Country	South Korea
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	TÜV Rheinland Energy GmbH		
Subtype title	R32 monobloc 12 14 16 kW 1 phase & 3 phases		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	2.4 kg		
Certification Date	04.04.2018		

Model: HM163M U33

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	16.00 kW	12.00 kW
El input	3.64 kW	4.29 kW
COP	4.40	2.80
Indoor water flow rate	2.76 m ³ /h	1.30 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	124 %
Prated	11.00 kW	12.00 kW
SCOP	4.45	3.18
Tbiv	-10 °C	-7 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	9.70 kW	10.60 kW
COP Tj = -7°C	2.90	1.93
Cdh	0.90	0.90
Pdh Tj = +2°C	5.90 kW	6.50 kW
COP Tj = +2°C	4.38	3.00
Cdh	0.90	0.90
Pdh Tj = +7°C	6.70 kW	6.30 kW
COP Tj = +7°C	6.24	4.80
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	8.10 kW	7.70 kW
COP Tj = 12°C	8.30	7.00
Cdh	0.90	0.90
Pdh Tj = Tbiv	11.00 kW	10.60 kW
COP Tj = Tbiv	2.50	1.93
Pdh Tj = TOL	11.00 kW	10.00 kW
COP Tj = TOL	2.50	1.65
Cdh	0.90	0.90
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	50 W	50 W
Supplementary Heater: Type of energy input	No	electric
Supplementary Heater: PSUP	0.00 kW	2.00 kW
Annual energy consumption Qhe	5103 kWh	7795 kWh

Model: HM143M U33

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	14.00 kW	12.00 kW
El input	3.11 kW	4.29 kW
COP	4.50	2.80
Indoor water flow rate	2.42 m ³ /h	1.30 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	124 %
Prated	11.00 kW	12.00 kW
SCOP	4.45	3.18
Tbiv	-10 °C	-7 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	9.30 kW	10.60 kW
COP Tj = -7°C	2.90	1.93
Cdh	0.90	0.90
Pdh Tj = +2°C	5.70 kW	6.50 kW
COP Tj = +2°C	4.38	3.00
Cdh	0.90	0.90
Pdh Tj = +7°C	6.50 kW	6.30 kW
COP Tj = +7°C	6.24	4.80
Cdh	0.90	0.90
Pdh Tj = 12°C	7.70 kW	7.70 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	8.30	7.00
Cdh	0.90	0.90
Pdh Tj = Tbiv	10.50 kW	10.60 kW
COP Tj = Tbiv	2.50	1.93
Pdh Tj = TOL	10.50 kW	10.00 kW
COP Tj = TOL	2.50	1.65
Cdh	0.90	0.90
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	50 W	50 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.50 kW	2.00 kW
Annual energy consumption Qhe	4875 kWh	7795 kWh

Model: HM123M U33

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.61 kW	4.29 kW
COP	4.60	2.80
Indoor water flow rate	2.07 m ³ /h	1.30 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	124 %
Prated	10.00 kW	12.00 kW
SCOP	4.45	3.18
Tbiv	-10 °C	-7 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	8.80 kW	10.60 kW
COP Tj = -7°C	2.90	1.93
Cdh	0.90	0.90
Pdh Tj = +2°C	5.40 kW	6.50 kW
COP Tj = +2°C	4.38	3.00
Cdh	0.90	0.90
Pdh Tj = +7°C	6.10 kW	6.30 kW
COP Tj = +7°C	6.24	4.80
Cdh	0.90	0.90
Pdh Tj = 12°C	7.40 kW	7.70 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	8.30	7.00
Cdh	0.90	0.90
Pdh Tj = Tbiv	10.00 kW	10.60 kW
COP Tj = Tbiv	2.50	1.93
Pdh Tj = TOL	10.00 kW	10.00 kW
COP Tj = TOL	2.50	1.65
Cdh	0.90	0.90
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	50 W	50 W
Supplementary Heater: Type of energy input	NO	electric
Supplementary Heater: PSUP	0.00 kW	2.00 kW
Annual energy consumption Qhe	4642 kWh	7795 kWh

Model: HM161M U33

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	16.00 kW	12.00 kW
El input	3.64 kW	4.29 kW
COP	4.40	2.80
Indoor water flow rate	2.76 m ³ /h	1.30 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	124 %
Prated	11.00 kW	12.00 kW
SCOP	4.45	3.18
Tbiv	-10 °C	-7 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	9.70 kW	10.60 kW
COP Tj = -7°C	2.90	1.93
Cdh	0.90	0.90
Pdh Tj = +2°C	5.90 kW	6.50 kW
COP Tj = +2°C	4.38	3.00
Cdh	0.90	0.90
Pdh Tj = +7°C	6.70 kW	6.30 kW
COP Tj = +7°C	6.24	4.80
Cdh	0.90	0.90
Pdh Tj = 12°C	8.10 kW	7.70 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	8.30	7.00
Cdh	0.90	0.90
Pdh Tj = Tbiv	11.00 kW	10.60 kW
COP Tj = Tbiv	2.50	1.93
Pdh Tj = TOL	11.00 kW	10.00 kW
COP Tj = TOL	2.50	1.65
Cdh	0.90	0.90
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	50 W	50 W
Supplementary Heater: Type of energy input	no	electric
Supplementary Heater: PSUP	0.00 kW	2.00 kW
Annual energy consumption Qhe	5103 kWh	7795 kWh

Model: HM141M U33

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	14.00 kW	12.00 kW
El input	3.11 kW	4.29 kW
COP	4.50	2.80
Indoor water flow rate	2.42 m ³ /h	1.30 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	124 %
Prated	11.00 kW	12.00 kW
SCOP	4.45	3.18
Tbiv	-10 °C	-7 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	9.30 kW	10.60 kW
COP Tj = -7°C	2.90	1.93
Cdh	0.90	0.90
Pdh Tj = +2°C	5.70 kW	6.50 kW
COP Tj = +2°C	4.38	3.00
Cdh	0.90	0.90
Pdh Tj = +7°C	6.50 kW	6.30 kW
COP Tj = +7°C	6.24	4.80
Cdh	0.90	0.90
Pdh Tj = 12°C	7.70 kW	7.70 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	8.30	7.00
Cdh	0.90	0.90
Pdh Tj = Tbiv	10.50 kW	10.60 kW
COP Tj = Tbiv	2.50	1.93
Pdh Tj = TOL	10.50 kW	10.00 kW
COP Tj = TOL	2.50	1.65
Cdh	0.90	0.90
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	50 W	50 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.50 kW	2.00 kW
Annual energy consumption Qhe	4875 kWh	7795 kWh

Model: HM121M U33

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.61 kW	4.29 kW
COP	4.60	2.80
Indoor water flow rate	2.07 m ³ /h	1.30 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	124 %
Prated	10.00 kW	12.00 kW
SCOP	4.45	3.18
Tbiv	-10 °C	-7 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	8.80 kW	10.60 kW
COP Tj = -7°C	2.90	1.93
Cdh	0.90	0.90
Pdh Tj = +2°C	5.40 kW	6.50 kW
COP Tj = +2°C	4.38	3.00
Cdh	0.90	0.90
Pdh Tj = +7°C	6.10 kW	6.30 kW
COP Tj = +7°C	6.24	4.80
Cdh	0.90	0.90
Pdh Tj = 12°C	7.40 kW	7.70 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	8.30	7.00
Cdh	0.90	0.90
Pdh Tj = Tbiv	10.00 kW	10.60 kW
COP Tj = Tbiv	2.50	1.93
Pdh Tj = TOL	10.00 kW	10.00 kW
COP Tj = TOL	2.50	1.65
Cdh	0.90	0.90
WTOL	65 °C	65 °C
Poff	60 W	60 W
PTO	60 W	60 W
PSB	60 W	60 W
PCK	50 W	50 W
Supplementary Heater: Type of energy input	N/A	electric
Supplementary Heater: PSUP	0.00 kW	2.00 kW
Annual energy consumption Qhe	4642 kWh	7795 kWh