Login

Summary of	MAM 18-22-26-30 v10	Reg. No.	041-K012-09
Certificate Holder			
Name	Salvador Escoda S.A.		
Address	Carrer Nàpols 249 Pl.1	Zip	08013
City	Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	MAM 18-22-26-30 v10		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	5 kg		
Certification Date	21.05.2021		
Testing basis	HP Keymark Scheme Rules Rev 08		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: MAM-18-V10T

Configure model	
Model name	MAM-18-V10T
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	18.32 kW	18.10 kW
El input	3.96 kW	6.63 kW
COP	4.63	2.73

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	181 %	125 %
Prated	17.99 kW	17.67 kW
SCOP	4.60	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	15.90 kW	15.61 kW
COP Tj = -7°C	2.85	1.72
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	9.66 kW	9.59 kW
COP Tj = +2°C	4.59	3.32
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.56 kW	6.37 kW
COP Tj = +7°C	5.99	4.48
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.76 kW	3.57 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = 12°C	7.08	5.27
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	15.90 kW	15.61 kW
COP Tj = Tbiv	2.85	1.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.99 kW	15.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.17
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	2.64 kW
Annual energy consumption Qhe	8086 kWh	11375 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	Low temperature	**Medium temperature**
η_s	226 %	157 %
Prated	17.67 kW	18.07 kW
SCOP	5.74	4.00
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	17.67 kW	18.07 kW
COP Tj = +2°C	3.53	2.12
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	11.36 kW	11.62 kW
COP Tj = +7°C	5.16	3.49
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.45 kW	5.35 kW
COP Tj = 12°C	7.01	5.09
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.36 kW	11.62 kW
COP Tj = Tbiv	5.16	3.49
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.67 kW	18.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.53	2.12
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4116 kWh	6041 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	71 dB(A)	71 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	146 %	97 %
Prated	17.76 kW	18.38 kW
SCOP	3.73	2.50
Tbiv	-15 °C	-7 °C
TOL	-22 °C	-15 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = -7°C	11.21 kW	11.13 kW
COP Tj = -7°C	3.09	1.98
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.64 kW	6.65 kW
COP Tj = +2°C	4.50	3.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.77 kW	4.66 kW
COP Tj = +7°C	5.85	4.35
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.95 kW	3.74 kW
COP Tj = 12°C	7.18	5.68
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	14.49 kW	11.13 kW
COP Tj = Tbiv	2.42	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.14 kW	13.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.67	1.21
WTOL	60 °C	60 °C
Poff	20 W	20 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.62 kW	18.38 kW
Annual energy consumption Qhe	11740 kWh	18156 kWh
Pdh Tj = -15°C (if TOL<-20°C)	14.49	13.56
COP Tj = -15°C (if TOL<-20°C)	2.42	1.21
Cdh Tj = -15 °C	0.90	0.90

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: MAM-22-V10T

Configure model	
Model name	MAM-22-V10T
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	22.30 kW	22.10 kW
El input	5.13 kW	8.33 kW
COP	4.35	2.65

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	178 %	126 %
Prated	22.31 kW	22.43 kW
SCOP	4.53	3.22
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	19.72 kW	19.82 kW
COP Tj = -7°C	2.74	1.74
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	12.03 kW	11.89 kW
COP Tj = +2°C	4.41	3.32
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.97 kW
COP Tj = +7°C	6.29	4.66
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.79 kW	3.60 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = 12°C	7.14	5.32
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	19.72 kW	19.82 kW
COP Tj = Tbiv	2.74	1.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	20.33 kW	13.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.08
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.97 kW	8.60 kW
Annual energy consumption Qhe	10180 kWh	14390 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

η_s	234 %	161 %
Prated	21.90 kW	22.01 kW
SCOP	5.85	4.09
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	21.81 kW	22.01 kW
COP Tj = +2°C	3.31	2.12
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	14.08 kW	14.15 kW
COP Tj = +7°C	5.20	3.50
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	6.44 kW	6.38 kW
COP Tj = 12°C	7.50	5.34
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	14.08 kW	14.15 kW
COP Tj = Tbiv	5.20	3.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	21.81 kW	22.01 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.31	2.12
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.09 kW	0.00 kW
Annual energy consumption Qhe	4945 kWh	7180 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	73 dB(A)	73 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	146 %	102 %
Prated	21.40 kW	22.36 kW
SCOP	3.72	2.62
Tbiv	-15 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	13.30 kW	13.53 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = -7°C	3.12	2.07
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.25 kW	8.61 kW
COP Tj = +2°C	4.42	3.70
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.45 kW	5.21 kW
COP Tj = +7°C	5.87	4.49
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.98 kW	3.74 kW
COP Tj = 12°C	7.19	5.76
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	17.46 kW	13.53 kW
COP Tj = Tbiv	2.36	2.07
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.27 kW	13.78 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.69	1.24
WTOL	60 °C	60 °C
Poff	20 W	20 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Supplementary Heater: PSUP	8.13 kW	22.36 kW
Annual energy consumption Qhe	14179 kWh	21067 kWh
Pdh Tj = -15°C (if TOL<-20°C)	17.46	13.78
COP Tj = -15°C (if TOL<-20°C)	2.36	1.24
Cdh Tj = -15 °C	0.90	0.90

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: MAM-26-V10T

Configure model	
Model name	MAM-26-V10T
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	26.30 kW	26.06 kW
El input	6.50 kW	10.72 kW
COP	4.05	2.43

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	75 dB(A)	75 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	177 %	123 %
Prated	25.04 kW	26.15 kW
SCOP	4.50	3.14
Tbiv	-7 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	22.12 kW	20.64 kW
COP Tj = -7°C	2.57	1.69
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	13.76 kW	14.26 kW
COP Tj = +2°C	4.44	3.12
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	9.36 kW	9.29 kW
COP Tj = +7°C	6.52	4.74
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.09 kW	3.89 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = 12°C	7.35	5.48
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	22.12 kW	22.11 kW
COP Tj = Tbiv	2.57	1.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	20.33 kW	13.86 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.08
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.68 kW	12.28 kW
Annual energy consumption Qhe	11489 kWh	17204 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	75 dB(A)	75 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

η_s	231 %	168 %
Prated	26.08 kW	26.22 kW
SCOP	5.85	4.26
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	25.50 kW	26.22 kW
COP Tj = +2°C	3.00	1.99
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	16.77 kW	16.86 kW
COP Tj = +7°C	5.02	3.47
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	7.65 kW	7.58 kW
COP Tj = 12°C	7.78	5.94
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	16.77 kW	16.86 kW
COP Tj = Tbiv	5.02	3.47
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	25.50 kW	26.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.00	1.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	0.00 kW
Annual energy consumption Qhe	5959 kWh	8218 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	75 dB(A)	75 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	143 %	101 %
Prated	25.75 kW	26.27 kW
SCOP	3.64	2.59
Tbiv	-12 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	15.91 kW	15.90 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = -7°C	3.10	2.10
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	10.10 kW	10.17 kW
COP Tj = +2°C	4.45	3.58
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	6.30 kW	6.52 kW
COP Tj = +7°C	6.06	4.99
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.03 kW	3.63 kW
COP Tj = 12°C	7.13	5.68
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	18.97 kW	15.90 kW
COP Tj = Tbiv	2.36	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.07 kW	13.37 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.67	1.20
WTOL	60 °C	60 °C
Poff	20 W	20 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Supplementary Heater: PSUP	12.68 kW	26.27 kW
Annual energy consumption Qhe	17421 kWh	24967 kWh
Pdh Tj = -15°C (if TOL<-20°C)	18.95	13.37
COP Tj = -15°C (if TOL<-20°C)	2.27	1.20
Cdh Tj = -15 °C	0.90	0.90

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: MAM-30-V10T

Configure model	
Model name	MAM-30-V10T
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	29.93 kW	29.68 kW
El input	8.02 kW	12.97 kW
COP	3.73	2.29

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	77 dB(A)	77 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	165 %	123 %
Prated	29.18 kW	29.69 kW
SCOP	4.19	3.14
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	21.90 kW	20.11 kW
COP Tj = -7°C	2.54	1.63
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	16.16 kW	16.49 kW
COP Tj = +2°C	4.16	3.09
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	10.64 kW	10.50 kW
COP Tj = +7°C	6.38	4.75
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.54 kW	4.64 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = 12°C	7.72	5.91
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	23.51 kW	23.97 kW
COP Tj = Tbiv	2.71	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	20.37 kW	13.82 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.07
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	8.75 kW	15.86 kW
Annual energy consumption Qhe	14165 kWh	19316.17 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	77 dB(A)	77 dB(A)

EN 14825		
	Low temperature	**Medium temperature**

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

η_s	213 %	163 %
Prated	30.44 kW	29.73 kW
SCOP	5.39	4.15
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	26.29 kW	26.41 kW
COP Tj = +2°C	2.94	1.99
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	19.57 kW	19.11 kW
COP Tj = +7°C	4.75	3.37
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	8.90 kW	8.92 kW
COP Tj = 12°C	7.53	6.09
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	19.57 kW	19.11 kW
COP Tj = Tbiv	4.75	3.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	26.29 kW	26.41 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.94	1.99
WTOL	60 °C	60 °C
Poff	18 W	18 W

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.15 kW	3.32 kW
Annual energy consumption Qhe	7540 kWh	9580 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	77 dB(A)	77 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	138 %	100 %
Prated	29.13 kW	30.41 kW
SCOP	3.52	2.56
Tbiv	-10 °C	-7 °C
TOL	-22 °C	-15 °C
Pdh Tj = -7°C	18.49 kW	18.40 kW
COP Tj = -7°C	3.07	2.10

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	11.88 kW	11.22 kW
COP Tj = +2°C	4.42	3.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.53 kW	7.42 kW
COP Tj = +7°C	6.15	5.18
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.11 kW	3.64 kW
COP Tj = 12°C	6.87	5.73
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	19.93 kW	18.40 kW
COP Tj = Tbiv	2.44	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.17 kW	13.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.67	1.18
WTOL	60 °C	60 °C
Poff	18 W	18 W
PTO	96 W	96 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	15.96 kW	30.41 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	20390 kWh	29238 kWh
Pdh Tj = -15°C (if TOL<-20°C)	18.61	13.06
COP Tj = -15°C (if TOL<-20°C)	2.24	1.18
Cdh Tj = -15 °C	0.90	0.90

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.