

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

| | | | |
|---------------------|--|----------|-----------------|
| Summary of | AQUA PLUS SWAN-2 300S | Reg. No. | ICIM-PDC-000031 |
| Certificate Holder | | | |
| Name | Clivet s.p.a. | | |
| Address | Via camp lonc 25 c.ap. | Zip | I-32032 |
| City | z.i. Villapaiera - Feltre (BL) | Country | Italy |
| Certification Body | ICIM S.p.A. | | |
| Subtype title | AQUA PLUS SWAN-2 300S | | |
| Heat Pump Type | Heat Pump for Domestic Hot Water (DHW) | | |
| Refrigerant | R134a | | |
| Mass of Refrigerant | 1.5 kg | | |
| Certification Date | 02.05.2019 | | |
| Testing basis | HP KEYMARK certification scheme rules rev. no. 4 | | |

Model: SWAN-2 300S

| Configure model | |
|-----------------------------|-------------|
| Model name | SWAN-2 300S |
| Units | Indoor |
| Climate zone (for heating) | n/a |
| Heat Source | n/a |
| Any additional heat sources | n/a |

| General Data | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | No |

Domestic Hot Water (DHW)

Average Climate

| EN 12102-2 | |
|--------------------------|----------|
| | |
| Sound power level indoor | 53 dB(A) |

| EN 16147 | |
|---------------------------------|------------|
| | |
| Declared load profile | XL |
| Efficiency η_{DHW} | 123 % |
| COP | 3.01 |
| Heating up time | 7:49 h:min |
| Standby power input | 30.6 W |
| Reference hot water temperature | 53.1 °C |
| Mixed water at 40°C | 354 l |

Operating test

| EN 16147 | |
|------------------------------|--------|
| | |
| Temperature operating range | passed |
| Safety devices checking test | passed |
| Condensate draining | passed |