

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	DAIKIN ALTHERMA 3 H F 14kW (230L)	Reg. No.	011-1W0322
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA 3 H F 14kW (230L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3.5 kg		
Certification Date	06.03.2019		
Testing basis	HP KEYMARK certification scheme rules rev. 9		

# Model: EPGA14DV / EAVH16S23D(6V/9W)(G)

## Configure model

Model name	EPGA14DV / EAVH16S23D(6V/9W)(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

## General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	175 %	130 %
Prated	13.00 kW	14.00 kW
SCOP	4.45	3.34
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5797 kWh	8669 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

# Model: EPGA14DV / EAVX16S23D(6V/9W)(G)

Configure model	
Model name	EPGA14DV / EAVX16S23D(6V/9W)(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling



**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	178 %	132 %
Prated	13.00 kW	14.00 kW
SCOP	4.51	3.37
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5720 kWh	8592 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

## Model: EPGA14DV / EAVZ16S23D(6V/9W)

Configure model	
Model name	EPGA14DV / EAVZ16S23D(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### Cooling

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate



### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	175 %	130 %
Prated	13.00 kW	14.00 kW
SCOP	4.45	3.34
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5797 kWh	8669 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

# Model: EPGA14DV / EAVH16S23D(6V/9W)(G) + cooling kit

Configure model	
Model name	EPGA14DV / EAVH16S23D(6V/9W)(G) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	178 %	132 %
Prated	13.00 kW	14.00 kW
SCOP	4.51	3.37
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5720 kWh	8592 kWh

## Domestic Hot Water (DHW)

### Average Climate



<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

# Model: EPGA14DV / EAVZ16S23D(6V/9W) + cooling kit

Configure model	
Model name	EPGA14DV / EAVZ16S23D(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	178 %	132 %
Prated	13.00 kW	14.00 kW
SCOP	4.51	3.37
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5720 kWh	8592 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

# Model: EPGA14DV / EAVH16SU23D6V

Configure model	
Model name	EPGA14DV / EAVH16SU23D6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling



**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	175 %	130 %
Prated	13.00 kW	14.00 kW
SCOP	4.45	3.34
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5797 kWh	8669 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

# Model: EPGA14DV7 / EAVH16S23D(6V/9W)7

## Configure model

Model name	EPGA14DV7 / EAVH16S23D(6V/9W)7
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

## General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate



### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	175 %	130 %
Prated	13.00 kW	14.00 kW
SCOP	4.45	3.34
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5797 kWh	8669 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

# Model: EPGA14DV7 / EAVX16S23D(6V/9W)7

Configure model	
Model name	EPGA14DV7 / EAVX16S23D(6V/9W)7
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	178 %	132 %
Prated	13.00 kW	14.00 kW
SCOP	4.51	3.37
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5720 kWh	8592 kWh

## Domestic Hot Water (DHW)

### Average Climate



<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

# Model: EPGA14DV7 / EAVZ16S23D6V7

Configure model	
Model name	EPGA14DV7 / EAVZ16S23D6V7
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	175 %	130 %
Prated	13.00 kW	14.00 kW
SCOP	4.45	3.34
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5797 kWh	8669 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

# Model: EPGA14DV7 / EAVH16S23D(6V/9W)7 + cooling kit

Configure model	
Model name	EPGA14DV7 / EAVH16S23D(6V/9W)7 + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling



**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	178 %	132 %
Prated	13.00 kW	14.00 kW
SCOP	4.51	3.37
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5720 kWh	8592 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

# Model: EPGA14DV7 / EAVZ16S23D6V7 + cooling kit

Configure model	
Model name	EPGA14DV7 / EAVZ16S23D6V7 + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate



### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	178 %	132 %
Prated	13.00 kW	14.00 kW
SCOP	4.51	3.37
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5720 kWh	8592 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l

# Model: EPGA14DV7 / EAVH16SU23D6V7

Configure model	
Model name	EPGA14DV7 / EAVH16SU23D6V7
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.54 kW	15.84 kW
El input	2.91 kW	5.17 kW
COP	4.99	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Cooling

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	3.97 kW
Cooling capacity	11.89
EER	2.99

**EN 14825**

This information was generated by the HP KEYMARK database on 23 Jun 2022

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	12 kW
SEER	5.04
P <sub>dc</sub> T <sub>j</sub> = 35°C	11.89 kW
EER T <sub>j</sub> = 35°C	2.99
P <sub>dc</sub> T <sub>j</sub> = 30°C	8.79 kW
EER T <sub>j</sub> = 30°C	4.15
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 25°C	5.56 kW
EER T <sub>j</sub> = 25°C	6.19
C <sub>dc</sub>	1
P <sub>dc</sub> T <sub>j</sub> = 20°C	7.86 kW
EER T <sub>j</sub> = 20°C	6.65
C <sub>dc</sub>	1
P <sub>off</sub>	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	1429 kWh

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	175 %	130 %
Prated	13.00 kW	14.00 kW
SCOP	4.45	3.34
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	12.30 kW
COP Tj = -7°C	2.85	2.17
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	7.00 kW	8.10 kW
COP Tj = +2°C	4.24	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	5.00 kW
COP Tj = +7°C	6.24	4.46
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	8.12	5.94
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	12.50 kW	12.30 kW
COP Tj = Tbiv	2.53	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	13.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.53	2.10
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.50 kW
Annual energy consumption Qhe	5797 kWh	8669 kWh

## Domestic Hot Water (DHW)

### Average Climate



<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.70
Heating up time	1:05 h:min
Standby power input	36.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	286 l